



Northeast
Nuclear Energy

Rope Ferry Rd. (Route 156), Waterford, CT 06385

Millstone Nuclear Power Station
Northeast Nuclear Energy Company
P.O. Box 128
Waterford, CT 06385-0128
(860) 447-1791
Fax (860) 444-4277

The Northeast Utilities System

SEP 2 1998

Docket No. 50-336
B17425

Re: 10 CFR 50.73(a)(2)(v)

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Millstone Nuclear Power Station Unit No. 2
Licensee Event Report 96-018-01
Gaps Discovered in Enclosure Door Seals for
Motor Control Centers B51 and B61


This letter forwards Licensee Event Report (LER) 96-018-01, documenting a condition that was discovered at Millstone Nuclear Power Station, Unit No. 2, on March 19, 1996. This LER is being submitted pursuant to 10 CFR 50.73(a)(2)(v). This LER supplement provides an update on the analyses and investigation of this condition.

The Northeast Nuclear Energy Company (NNECO) commitment described in Attachment 1 is a clarification of the original commitment associated with this LER.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

1/1
Je 22



J. A. Price
Director - Millstone Unit No. 2

cc: see page 2

090043

9809090323 980902
PDR ADOCK 05000336
S PDR

Attachments: 1. List of Regulatory Commitments
2. LER 96-018-01

cc: H. J. Miller, Region I Administrator
D. G. McDonald, Jr., NRC Senior Project Manager, Millstone Unit No. 2
D. P. Beaulieu, Senior Resident Inspector, Millstone Unit No. 2
E. V. Imbro, Director, Millstone ICAVP Inspections

Docket No. 50-336
B17425

Attachment 1
Millstone Nuclear Power Station, Unit No. 2
Commitments

September 1998

Attachment 1

Regulatory Commitment Enclosure
List of Regulatory Commitments

The following table identifies those actions committed to by NNECO in this document.

REGULATORY COMMITMENT	COMMITTED DATE OR OUTAGE
B17425.01: The HELB barrier inspection program will be improved so that the protective function of the HELB protective barriers will be verified periodically. Utilizing the above program an inspection procedure will be developed and implemented so that doors and enclosures serving as a protective barrier for safety related equipment will be inspected and maintained as committed in NNECO letter B15665, dated April 18, 1996. The procedure will be implemented and the inspection conducted prior to entry into Mode 4 from the current outage. (This commitment is the same as, and supersedes, commitment B15665.03. This commitment has been reworded for clarity).	Prior to entry into Mode 4 from the current outage

Docket No. 50-336
B17425

Attachment 2

Millstone Nuclear Power Station, Unit No. 2

LER 96-018-01

September 1998