

September 15, 1998

Mr. John K. Wood
Vice President - Nuclear, Davis-Besse
Centerior Service Company
c/o Toledo Edison Company
Davis-Besse Nuclear Power Station
5501 North State Route 2
Oak Harbor, OH 43449-9760

SUBJECT: CHANGE TO COMMITMENTS FOR THE AUXILIARY FEEDWATER PUMP TURBINE AND
INTEGRATED CONTROL SYSTEM PREVENTIVE MAINTENANCE SCHEDULE -
RESULTS OF STAFF REVIEW, DAVIS-BESSE NUCLEAR POWER STATION,
UNIT NO. 1 (TAC NO. MA1469)

Dear Mr. Wood:

By letter dated March 16, 1998, you informed the NRC of changes to commitments to preventive maintenance (PM) for the auxiliary feedwater pump turbine overspeed trip mechanism and the integrated control system (ICS). Part of the PM schedule for the trip mechanism is being modified to be consistent with the current manufacturer's recommendations, and the ICS PM approach is being modified to a situational approach based on trend data evaluation, visual inspections and ICS tuning results.

This letter is to acknowledge receipt of your commitment change letter. The staff has no questions at this time. Please contact me if you have any questions regarding this matter.

Sincerely,

Original signed by:

Allen G. Hansen, Project Manager
Project Directorate III-3
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-346

cc: See next page

DISTRIBUTION:

Docket File PUBLIC
PD33 r/f EGA1
RBellamy SCampbell, Region 3
HQMB OGC
ACRS GGrant, Region 3

DFOI 1/0

DOCUMENT NAME: G:\DAVISBES\DBA1469.LTR

OFFICE	LA:PD33	C	PM:PD33	C	PD:PD33	N
NAME	EBarnhill <i>EB</i>		AHansen <i>AH</i>		RBellamy <i>MB</i>	
DATE	9/15/98		9/15/98		9/15/	

OFFICIAL RECORD COPY

9809180101 980915
PDR ADOCK 05000346
P PDR

NRC FILE CENTER COPY



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

September 15, 1998

Mr. John K. Wood
Vice President - Nuclear, Davis-Besse
Centerior Service Company
c/o Toledo Edison Company
Davis-Besse Nuclear Power Station
5501 North State Route 2
Oak Harbor, OH 43449-9760

SUBJECT: CHANGE TO COMMITMENTS FOR THE AUXILIARY FEEDWATER PUMP TURBINE AND
INTEGRATED CONTROL SYSTEM PREVENTIVE MAINTENANCE SCHEDULE -
RESULTS OF STAFF REVIEW, DAVIS-BESSE NUCLEAR POWER STATION,
UNIT NO. 1 (TAC NO. MA1469)

Dear Mr. Wood:

By letter dated March 16, 1998, you informed the NRC of changes to commitments to preventive maintenance (PM) for the auxiliary feedwater pump turbine overspeed trip mechanism and the integrated control system (ICS). Part of the PM schedule for the trip mechanism is being modified to be consistent with the current manufacturer's recommendations, and the ICS PM approach is being modified to a situational approach based on trend data evaluation, visual inspections and ICS tuning results.

This letter is to acknowledge receipt of your commitment change letter. The staff has no questions at this time. Please contact me if you have any questions regarding this matter.

Sincerely,

A handwritten signature in black ink, appearing to read "A.G. Hansen".

Allen G. Hansen, Project Manager
Project Directorate III-3
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-346

cc: See next page

John K. Wood
Toledo Edison Company

Davis-Besse Nuclear Power Station, Unit 1

cc:

Mary E. O'Reilly
FirstEnergy
Davis-Besse Nuclear Power Station
5501 North State - Route 2
Oak Harbor, OH 43449-9760

Robert E. Owen, Chief
Bureau of Radiological Health
Service
Ohio Department of Health
P.O. Box 118
Columbus, OH 43266-0118

James L. Freels
Manager - Regulatory Affairs
Toledo Edison Company
Davis-Besse Nuclear Power Station
5501 North State - Route 2
Oak Harbor, OH 43449-9760

James R. Williams, Chief of Staff
Ohio Emergency Management Agency
2855 West Dublin Granville Road
Columbus, OH 43235-2206

Jay E. Silberg, Esq.
Shaw, Pittman, Potts
and Trowbridge
2300 N Street, NW
Washington, DC 20037

Donna Owens, Director
Ohio Department of Commerce
Division of Industrial Compliance
Bureau of Operations & Maintenance
6606 Tussing Road
P.O. Box 4009
Reynoldsburg, OH 43068-9009

Regional Administrator
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, IL 60523-4351

Ohio Environmental Protection Agency
DERR--Compliance Unit
ATTN: Zack A. Clayton
P.O. Box 1049
Columbus, OH 43266-0149

Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
1700 Rockville Pike, Suite 525
Rockville, MD 20852

State of Ohio
Public Utilities Commission
180 East Broad Street
Columbus, OH 43266-0573

Resident Inspector
U.S. Nuclear Regulatory Commission
5503 North State Route 2
Oak Harbor, OH 43449

Attorney General
Department of Attorney
30 East Broad Street
Columbus, OH 43216

James H. Lash, Plant Manager
Toledo Edison Company
Davis-Besse Nuclear Power Station
5501 North State Route 2
Oak Harbor, OH 43449-9760

President, Board of County
Commissioners of Ottawa County
Port Clinton, OH 43252

September 15, 1998

Mr. John K. Wood
Vice President - Nuclear, Davis-Besse
Centerior Service Company
c/o Toledo Edison Company
Davis-Besse Nuclear Power Station
5501 North State Route 2
Oak Harbor, OH 43449-9760

SUBJECT: CHANGE TO COMMITMENTS FOR THE AUXILIARY FEEDWATER PUMP TURBINE AND INTEGRATED CONTROL SYSTEM PREVENTIVE MAINTENANCE SCHEDULE - RESULTS OF STAFF REVIEW, DAVIS-BESSE NUCLEAR POWER STATION, UNIT NO. 1 (TAC NO. MA1469)

Dear Mr. Wood:

By letter dated March 16, 1998, you informed the NRC of changes to commitments to preventive maintenance (PM) for the auxiliary feedwater pump turbine overspeed trip mechanism and the integrated control system (ICS). Part of the PM schedule for the trip mechanism is being modified to be consistent with the current manufacturer's recommendations, and the ICS PM approach is being modified to a situational approach based on trend data evaluation, visual inspections and ICS tuning results.

This letter is to acknowledge receipt of your commitment change letter. The staff has no questions at this time. Please contact me if you have any questions regarding this matter.

Sincerely,

Original signed by:

Allen G. Hansen, Project Manager
Project Directorate III-3
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No 50-346

cc: See next page

DISTRIBUTION:

Docket File PUBLIC
PD33 r/f EGA1
RBellamy SCampbell, Region 3
HQMB OGC
ACRS GGrant, Region 3

DOCUMENT NAME: G:\DAVI-BES\DBA1469.LTR

OFFICE	LA:PD33	C	PM:PD33	C	PD:PD33	N
NAME	EBarnhill <i>EB</i>		AHansen <i>AH</i>		RBellamy <i>RB</i>	
DATE	9/15/98		9/15/98		9/15/98	

OFFICIAL RECORD COPY