



June 25, 1999

SVP-99-142

United States Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

Quad Cities Nuclear Power Station, Unit Two
License Number DPR-30
NRC Docket No. 50-265

Enclosed is Licensee Event Report (LER) 265/99-002, Revision 00, for Quad Cities Nuclear Power Station.

This report is submitted in accordance with the requirements of the Code of Federal Regulations, Title 10, Part 50.73(a)(2)(i)(B). The licensee shall report any operation or condition prohibited by the Plant's Technical Specifications.

We are committing to the following action:

Permanently cap the spare secondary containment penetration pipe by July 15, 1999.

Any other actions described in the submittal represent intended or planned actions by Commonwealth Edison (ComEd) Company. They are described for the NRC's information and are not regulatory commitments.

Should you have any questions concerning this letter, please contact Mr. W.J. Beck at (309) 654-2241, extension 3100.

Respectfully,

Joel P. Dimmette, Jr.
Site Vice President
Quad Cities Nuclear Power Station

cc: Regional Administrator - NRC Region III
NRC Senior Resident Inspector - Quad Cities Nuclear Power Station

9907010172 990625
PDR ADOCK 05000265
S PDR

11
IF22