

Commonwealth Edison Company  
Quad Cities Generating Station  
22710 200th Avenue North  
Cordova, IL 61237-0000  
Tel: 815/454-2211

# ComEd

SM-98-001

January 5, 1998

U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Attn: Document Control Desk

Reference: Quad Cities Nuclear Power Station  
Docket Number 50-254, DPR-29, Unit One

Enclosed is Licensee Event Report (LER) 97-012, Revision 1, for Quad Cities Nuclear Power Station. This event dealt with Due to Design Related Cognitive Personnel Error, it is physically possible for the Unit 1 & 2 Refuel Bridge Monorail Auxiliary Hoists to perform core alterations without a Refuel Bridge Position Interlock actuation.

This report is being submitted to make the following commitments:

1. The station has scheduled the preparation of a modification which will enforce the bridge position interlock for the monorail hoist. The modification is scheduled to be installed prior to the next refueling outage. Due 070198.
2. The procedures used to perform core alterations will be changed to prohibit use of the Monorail hoist explicit to core alterations. Due 011598.

9801140084 980105  
PDR ADOCK 05000254  
S PDR

STMGR\98\98001



IE22/1

January 5, 1998

If there are any questions or comments concerning this letter, please refer them to Charles Peterson, Regulatory Affairs Manager at 309-654-2241, ext. 3609.

Respectfully,

COMMONWEALTH EDISON  
QUAD CITIES NUCLEAR POWER STATION

*D. B. Cook*

D. B. Cook  
Station Manager

DBC/CP/plm

Enclosure

cc: A. B. Beach, Regional Administrator, Region III  
R. M. Pulsifer, Project Manager, NRR  
C. G. Miller, Senior Resident Inspector, Quad Cities  
W. D. Leech, MidAmerican Energy Company  
L. C. Tubbs, MidAmerican Energy Company  
M. E. Wagner, Licensing, ComEd  
F. A. Spangenberg, Regulatory Affairs Manager, Dresden  
INPO Records Center