

GPU Nuclear, Inc.
U.S. Route #9 South
Post Office Box 388
Forked River, NJ 08731-0388
Tel 609-971-4000

December 23, 1998
1940-98-20674

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Gentlemen:

Subject: Oyster Creek Nuclear Generating Station (OCNGS)
Docket No. 50-219
Facility Operating License No. DPR-16
Technical Specification Change Request (TSCR) No. 268
Isolation Condenser Motor Operated Valve Surveillance

In accordance with 10 CFR 50.4(b)(1), please find enclosed Technical Specification Change Request (TSCR) No. 268.

GPU Nuclear requests that Technical Specification (TS) 4.8.A.1, contained in Appendix A of the Facility License, be changed to specify a surveillance frequency of once per three months. Currently, Isolation Condenser specification 4.8.A.1 stipulates a surveillance frequency of once per month for verifying the operability of motor-operated isolation valves and condensate makeup valves. A summary of the proposed change is included as Attachment 1. The revised TS pages are provided as Attachment 2.

This license amendment application has undergone a safety review in accordance with Section 6.5 of the Oyster Creek Technical Specifications and has been evaluated under the criteria of 10 CFR 50.92. If there are any questions or additional information is required, please contact Mr. Joseph D. Lachenmayer of my staff at (973) 316-7971.

Very truly yours,

Michael B Roche

Michael B. Roche
Vice President and Director
Oyster Creek


/JDL

Attachments

cc: Administrator, Region I
NRC Senior Resident Inspector
NRC Project Manager

9812300326 981223
PDR ADOCK 05000219
P PDR

ADD 1/1



GPU Nuclear, Inc.
U.S. Route #9 South
Post Office Box 388
Forked River, NJ 08731-0388
Tel 609-971-4000

December 23, 1998
1940-98-20674

The Honorable Louis A. Amato, Jr.
Mayor of Lacey Township
818 West Lacey Road
Forked River, NJ 08731

Dear Mayor Amato:

Enclosed herewith is one copy of Technical Specification Change Request No. 268 for the Oyster Creek Nuclear Generating Station Operating License.

This document was filed with the United States Nuclear Regulatory Commission on December 23, 1998.


Very truly yours,

A handwritten signature in cursive script that reads "Michael B. Roche".

Michael B. Roche
Vice President and Director
Oyster Creek

/JDL

Attachment



GPU Nuclear, Inc.
U.S. Route #9 South
Post Office Box 388
Forked River, NJ 08731-0388
Tel 609-971-4000

December 23, 1998
1940-98-20674

Mr. Kent Tosch, Director
Bureau of Nuclear Engineering
Department of Environmental Protection
CN 411
Trenton, NJ 08625

Dear Mr. Tosch:

Subject: Oyster Creek Nuclear Generating Station
Facility Operating License No. DPR-16
Technical Specification Change Request No. 268

Pursuant to 10 CFR 50.91(b)(1), please find enclosed a copy of the subject document which was filed with the United States Nuclear Regulatory Commission on December 23, 1998.

Very truly yours,

A handwritten signature in cursive script that reads "Michael B. Roche".

Michael B. Roche
Vice President and Director
Oyster Creek

/JDL

Attachment