

Commonwealth Edison Company
Quad Cities Generating Station
22710 206th Avenue North
Cordova, IL 61242-9710
Tel: 815-454-2244

ComEd

SM-98-005

January 9, 1998

United States Nuclear Regulatory Commission
Washington, DC 20555

Attention: Document Control Desk

Reference: Quad Cities Nuclear Power Station
Docket Number 50-254, DPR-29, Unit One

Enclosed is Licensee Event Report (LER) 97-029, Revision 00, for Quad Cities Nuclear Power Station.

This report is submitted in accordance with the requirements of the Code of Federal Regulations, Title 10, Part 50.73(a)(2)(i)(B). The licensee shall report any operation or condition prohibited by the Plant's Technical Specifications.

The following commitments are being made by this letter:

1. Revise QCGP 1-4 and 1-5 to require that QIS 4-2 (in addition to QCIS 0700-11) be performed within 7 days prior-to-startup. (Due date: 020198)
2. Revise QIS 4-2 and QCIS 0700-11, "Prior to Startup Average Power Range Monitor Downscale Rod Block Functional Test," to incorporate appropriate testing of all RBM functional units in a prior-to-startup condition. (Due date: 020198).

9801160042 980109
PDR ADOCK 05000254
S PDR

SMGR98V98005

Commonwealth Edison Company




January 9, 1998

If there are any questions or comments concerning this letter, please refer them to Charles Peterson, Regulatory Affairs Manager at 309-654-2241, ext. 3609.

Respectfully,

COMMONWEALTH EDISON COMPANY
QUAD CITIES NUCLEAR POWER STATION


D. B. Cook
Station Manager

DBC/CP/plm

Enclosure

cc: A. B. Beach, Regional Administrator, Region III
R. M. Putsifer, Project Manager, NRR
C. G. Miller, Senior Resident Inspector, Quad Cities
W. D. Leech, MidAmerican Energy Company
D. C. Tubbs, MidAmerican Energy Company
M. E. Wagner, Licensing, ComEd
F. A. Spangenberg, Regulatory Affairs Manager, Dresden
INPO Records Center