

Commonwealth Edison Company
Quad Cities Generating Station
22710 206th Avenue North
Cordova, IL 61242-9740
Tel 309-654-2241

ComEd

SM-97-112

December 5, 1997

United States Nuclear Regulatory Commission
Washington, DC 20555

Attention: Document Control Desk

Reference: Quad Cities Nuclear Power Station
Docket Number 50-254, DPR-29, Unit One

Enclosed is Licensee Event Report (LER) 97-025, Revision 00, for Quad Cities Nuclear Power Station.

This report is submitted in accordance with the requirements of the Code of Federal Regulations, Title 10, Part 50.73(a)(2)(i)(B). The licensee shall report any operation or condition prohibited by the Plant's Technical Specifications.

The following commitment is being made by this letter:

1. Appropriate Unit startup procedures will be revised by 121597 to ensure the flow biased calibration is performed prior to entering Mode 1.

If there are any questions or comments concerning this letter, please refer them to Charles Peterson, Regulatory Affairs Manager at 309-654-2241, ext. 3609.

Respectfully,

COMMONWEALTH EDISON COMPANY
QUAD CITIES NUCLEAR POWER STATION

D. B. Cook

D. B. Cook
Station Manager

DBC/CP/plm



Enclosure

cc: A. B. Beach, Regional Administrator, Region III
R. M. Pulsifer, Project Manager, NRR
C. G. Miller, Senior Resident Inspector, Quad Cities
W. D. Leech, MidAmerican Energy Company
D. C. Tubbs, MidAmerican Energy Company
M. E. Wagner, Licensing, ComEd
F. A. Spangerberg, Regulatory Affairs Manager, Dresden
INPO Records Center

IE22

100036

9712120247 971203
PDR ADOCK 05000254
S FDR