

J. Bernie Beasley, Jr., P.E.  
Vice President  
Vogtle Project

Southern Nuclear  
Operating Company, Inc.  
40 Inverness Center Parkway  
P.O. Box 1295  
Birmingham, Alabama 35201

Tel 205 992 7110  
Fax 205 992 0403



Energy to Serve Your World™

LCV-1281-C

May 10, 1999

Docket Nos. 50-424  
50-425

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D. C. 20555

Ladies and Gentlemen:

VOGTLE ELECTRIC GENERATING PLANT  
LICENSEE EVENT REPORT 1-98-006  
MOTOR CONTROL CENTER BREAKER BUCKETS  
NOT SEISMICALLY QUALIFIED

Southern Nuclear Operating Company hereby submits a revision to the Vogtle Electric Generating Plant licensee event report that was transmitted to the NRC on November 6, 1998, December 11, 1998 and February 25, 1999. This revision is submitted to document the results of seismic testing that demonstrated that no condition outside of the design basis or outside of Technical Specification requirements existed.

Sincerely,

J. B. Beasley, Jr.

JBB/BHW/gmb

Enclosure: LER 1-98-006, Revision 3

xc: Southern Nuclear Operating Company  
Mr. J. T. Gasser  
Mr. M. Sheibani  
SNC Document Management

U. S. Nuclear Regulatory Commission  
Mr. L. A. Reyes, Regional Administrator  
Mr. R. R. Assa, Project Manager, NRR  
Mr. J. Zeiler, Senior Resident Inspector, VEGP

11  
1122

9905170107 990510  
PDR ADOCK 05000424  
S PDR