

NOV 04 1986

Docket No. 50-220

Niagara Mohawk Power Corporation
ATTN: Mr. C. V. Mangan
Senior Vice President
300 Erie Boulevard West
Syracuse, New York 13202

Gentlemen:

Subject: inspection No. 50-220/85-06

This refers to your letter dated September 30, 1986, in response to our letter dated May 30, 1985.


Thank you for informing us of the change in your schedule for the completion of as-built safety related pipe support drawings. These actions will be examined during a future inspection of your facility.

Your cooperation with us is appreciated.

Sincerely,

Original Signed By:
James T. Wiggins

Stewart D. Ebnetter, Director
Division of Reactor Safety



cc w/encl:

T. E. Lempges, Vice President, Nuclear Generation
J. A. Perry, Vice President, Quality Assurance
T. Perkins, General Superintendent, Nuclear Generation
W. Hansen, Manager of Quality Assurance
T. Roman, Station Superintendent
J. Aldrich, Supervisor, Operations
W. Drews, Technical Superintendent
Troy B. Conner, Jr. Esquire
John W. Keib, Esquire
Director, Power Division
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
State of New York

IEOI
||

8611110558 861104
PDR ADOCK 05000220
Q PDR

OFFICIAL RECORD COPY

RL NMP1 85-06 - 0001.0.0
11/03/86

bcc w/encl:
Region I Docket Room (with concurrences)
Management Assistant, DRMA (w/o encl)
DRP Section Chief
Robert J. Bores, DRSS

RI:DRS
K. Manoly/bc
10/3/86
Manoly

RI:DRS
J. Wiggins
10/4/86
J. Wiggins

RI:DRS
J. Burr
10/4/86
J. Burr

OFFICIAL RECORD COPY

RL NMP1 85-06 - 0001.1.0
10/30/86



NIAGARA MOHAWK POWER CORPORATION / 300 ERIE BOULEVARD WEST, SYRACUSE, N.Y. 13202 / TELEPHONE (315) 474-1511

September 30, 1986
NMP1L 0100

Mr. Stuart D. Ebnetter, Director
Division of Reactor Safety
U.S. Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, PA 19406

Re: Nine Mile Point Unit 1
Docket No. 50-220
DPR-63

Dear Mr. Ebnetter:

In your Inspection Report No. 50-220/85-06 it was indicated that the consolidation of information associated with each (safety related) support onto one as-built drawings would be completed by September 1986. Although all of the drawings have been updated, approximately 2,000 of the approximately 3,900 safety related support drawings have not been reviewed and accepted by Niagara Mohawk Engineering. The review and approval of the as-built drawings will be completed by December 31, 1986.

Very truly yours,

T. E. Lemoges
T. E. Lemoges
Vice President
Nuclear Generation

TEL:bd
72401

8610280018 1p.