

March 15, 1999

Mr. Oliver D. Kingsley, President  
Nuclear Generation Group  
Commonwealth Edison Company  
Executive Towers West III  
1400 Opus Place, Suite 500  
Downers Grove, IL 60515

SUBJECT: TECHNICAL SPECIFICATION BASES CHANGE - QUAD CITIES NUCLEAR  
POWER STATION, UNITS 1 AND 2 (TAC NOS. MA4595 AND MA4596)

Dear Mr. Kingsley:

By letter dated January 21, 1999, Commonwealth Edison Company (ComEd, the licensee) submitted a change to Facility Operating License Nos. DPR-29 and DPR-30, Apper.dix A - Technical Specifications (TS) Bases Sections 3/4.10.K, "Residual Heat Removal [RHR] and Coolant Circulation - High Water Level" and 3/4.10.L, "Residual Heat Removal and Coolant Circulation - Low Water Level." The licensee made administrative changes to these bases sections to provide clarity and consistency with the RHR Shutdown Cooling system design and with the TS footnote (e) of Section 3/4.5.A and footnote (a) of Section 3/4.5.B.

This Bases change clearly identifies that the RHR Shutdown Cooling system is not designed to be throttled sufficiently to maintain the reactor coolant temperature, and this system is considered OPERABLE if the system can be manually aligned either remotely or locally.

These changes provide clarity to Bases Sections 3/4.10.K and 3/4.10.L and consistency with the TS. The staff has no objections to this Bases change.

Sincerely,

ORIG. SIGNED BY  
Robert M. Pulsifer, Project Manager  
Project Directorate III-2  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

9903180256 990315  
PDR ADOCK 05000254  
P PDR

Docket Nos. 50-254 and 50-265

Enclosure: Revised Bases Page

cc w/encl: See next page

DISTRIBUTION:

<u>Docket File</u>	PUBLIC	PDIII-2 r/f	J. Zwolinski/SBlack
S. Richards	C. Moore	R. Pulsifer	OGC, O15B18
G. Hill (4)	W. Beckner	ACRS, T2E26	M. Ring, RIII
L. Marsh			

DOCUMENT NAME: G:\PD3-2\CM\QUAD\BASE4595.WPD

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	PM:PDIII-2	E	LA:PDIII-2	R	SRXB	E	D:PDIII-2	C		
NAME	RPulsifer:sp		C MOORE		JWERMIEL		SRICHARDS			
DATE	03/15/99		03/11/99		03/11/99	#1	03/12/99			

100051

OFFICIAL RECORD COPY

1/1  
df01

FILE CENTER COPY

Mr. Oliver D. Kingsley, President  
 Nuclear Generation Group  
 Commonwealth Edison Company  
 Executive Towers West II;  
 1400 Opus Place, Suite 500  
 Downers Grove, IL 60515

SUBJECT: TECHNICAL SPECIFICATION BASES CHANGE - QUAD CITIES NUCLEAR  
 POWER STATION, UNITS 1 AND 2 (TAC NOS. MA4495 AND MA4596)

Dear Mr. Kingsley:

By letter dated January 21, 1999, Commonwealth Edison Company (ComEd, the licensee) submitted a change to Facility Operating License Nos. DPR-29 and DPR-30, Appendix A - Technical Specifications (TS) Bases Sections 3/4.10.K, "Residual Heat Removal [RHR] and Coolant Circulation - High Water Level" and 3/4.10.L, "Residual Heat Removal and Coolant Circulation - Low Water Level." The licensee made administrative changes to these bases sections to provide clarity and consistency with the RHR Shutdown Cooling system design and with the TS footnote (e) of Section 3/4.5.A and footnote (a) of Section 3/4.5.B.

This Bases change clearly identifies that the RHR Shutdown Cooling system is not designed to be throttled and this system is considered OPERABLE if the system can be manually aligned either remotely or locally.

These changes provide clarity to Bases Sections 3/4.10.K and 3/4.10.L and consistency with the TS. The staff has no objections to this Bases change.

Sincerely,

Robert M. Pulsifer, Project Manager  
 Project Directorate III-2  
 Division of Licensing Project Management  
 Office of Nuclear Reactor Regulation

Docket Nos. 50-254 and 50-265

Enclosure: Revised Bases Page

cc w/encl: See next page

DISTRIBUTION:

Docket File	PUBLIC	PDIII-2 r/f	J. Zwolinski
S. Richards	C. Moore	R. Pulsifer	OGC, O15B18
G. Hill (4)	W. Beckner	ACRS, T2E26	M. Ring, RIII
L. Marsh			

DOCUMENT NAME: G:\PD3-2\CM\QUAD\BASE4595.WPD

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	PM:PDIII-2	E	LA:PDIII-2	2	SP&B	1	D:PDIII-2		SR&B
NAME	RPulsifer:sp		CMOORE		LMARSH		SRICHARDS		J. Wernick
DATE	02/18/99		02/18/99		02/18/99		02/18/99		02/18/99

OFFICIAL RECORD COPY

#9



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

March 15, 1999

Mr. Oliver D. Kingsley, President  
Nuclear Generation Group  
Commonwealth Edison Company  
Executive Towers West III  
1400 Opus Place, Suite 500  
Downers Grove, IL 60515

SUBJECT: TECHNICAL SPECIFICATION BASES CHANGE - QUAD CITIES NUCLEAR  
POWER STATION, UNITS 1 AND 2 (TAC NOS. MA4595 AND MA4596)

Dear Mr. Kingsley:

By letter dated January 21, 1999, Commonwealth Edison Company (ComEd, the licensee) submitted a change to Facility Operating License Nos. DPR-29 and DPR-30, Appendix A - Technical Specifications (TS) Bases Sections 3/4.10.K, "Residual Heat Removal [RHR] and Coolant Circulation - High Water Level" and 3/4.10.L, "Residual Heat Removal and Coolant Circulation - Low Water Level." The licensee made administrative changes to these bases sections to provide clarity and consistency with the RHR Shutdown Cooling system design and with the TS footnote (e) of Section 3/4.5.A and footnote (a) of Section 3/4.5.B.

This Bases change clearly identifies that the RHR Shutdown Cooling system is not designed to be throttled sufficiently to maintain the reactor coolant temperature, and this system is considered OPERABLE if the system can be manually aligned either remotely or locally.

These changes provide clarity to Bases Sections 3/4.10.K and 3/4.10.L and consistency with the TS. The staff has no objections to this Bases change.

Sincerely,

Robert M. Pulsifer, Project Manager  
Project Directorate III-2  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-254 and 50-265

Enclosure: Revised Bases Page

cc w/encl: See next page

O. Kingsley  
Commonwealth Edison Company

Quad Cities Nuclear Power Station -  
Units 1 and 2

cc:

Commonwealth Edison Company  
Quad Cities Station Manager  
22710 206th Avenue North  
Cordova, Illinois 61242-9740

Vice President - Law and  
Regulatory Affairs  
MidAmerican Energy Company  
One River Center Place  
106 E. Second Street  
P.O. Box 4350  
Davenport, Iowa 52808

U.S. Nuclear Regulatory Commission  
Quad Cities Resident Inspectors Office  
22712 206th Avenue N.  
Cordova, Illinois 61242

Mr. David Helwig  
Senior Vice President  
Commonwealth Edison Company  
Executive Towers West III  
1400 Opus Place, Suite 900  
Downers Grove, Illinois 60515

Chairman  
Rock Island County Board  
of Supervisors  
1504 3rd Avenue  
Rock Island County Office Bldg.  
Rock Island, Illinois 61201

Mr. Gene H. Stanley  
PWR Vice President  
Commonwealth Edison Company  
Executive Towers West III  
1400 Opus Place, Suite 900  
Downers Grove, Illinois 60515

Illinois Department of Nuclear Safety  
Office of Nuclear Facility Safety  
1035 Outer Park Drive  
Springfield, Illinois 62704

Mr. Christopher Crane  
BWR Vice President  
Commonwealth Edison Company  
Executive Towers West III  
1400 Opus Place, Suite 900  
Downers Grove, Illinois 60515

Regional Administrator  
U.S. NRC, Region III  
801 Warrenville Road  
Lisle, Illinois 60532-4351

Commonwealth Edison Company  
Site Vice President - Quad Cities  
22710 206th Avenue North  
Cordova, Illinois 61242-9740

William D. Leach  
Manager - Nuclear  
MidAmerican Energy Company  
907 Walnut Street  
P.O. Box 657  
Des Moines, Iowa 50303

Commonwealth Edison Company  
Reg. Affairs Manager - Quad Cities  
22710 206th Avenue N.  
Cordova, Illinois 61242-9740

Mr. R. M. Krich  
Vice President - Regulatory Services  
Commonwealth Edison Company  
Executive Towers West III  
1400 Opus Place, Suite 500  
Downers Grove, Illinois 60515

Ms. Pamela B. Stroebel  
Senior Vice President and General Counsel  
Commonwealth Edison Company  
P.O. Box 767  
Chicago, Illinois 60690-0767

Document Control Desk-Licensing  
Commonwealth Edison Company  
1400 Opus Place, Suite 400  
Downers Grove, Illinois 60515

BASES3/4.10.I Single Control Rod Removal3/4.10.J Multiple Control Rod Removal

These specifications ensure that maintenance or repair of control rods or control rod drives will be performed under conditions that limit the probability of inadvertent criticality. The requirements for simultaneous removal of more than one control rod are more stringent since the SHUTDOWN MARGIN specification provides for the core to remain subcritical with only one control rod fully withdrawn.

Refueling interlocks restrict the movement of control rods and the operation of the refueling equipment to reinforce operational procedures that prevent the reactor from becoming critical. These interlocks prevent the withdrawal of more than one control rod. Under these conditions, since only one control rod can be withdrawn, the reactor core will always be shut down even with the highest worth control rod withdrawn if adequate SHUTDOWN MARGIN exists. Verification that all the other control rods are fully inserted is required to assure the SHUTDOWN MARGIN is within the limits. Verification that the five-by-five array of control rods are inserted and disarmed while the scram function for the withdrawn control rod is not available is required to ensure that the possibility of criticality remains precluded.

During refueling operations, no more than one control rod is permitted to be withdrawn from a core cell containing one or more fuel assemblies. When all four fuel assemblies are removed from a core cell, the control rod may be withdrawn with no restrictions. With no fuel assemblies in the core cell, the associated control rod has no reactivity control function and is not required to remain inserted. Prior to reloading fuel into the core cell, the associated control rod must be inserted to ensure that an inadvertent criticality does not occur.

3/4.10.K Residual Heat Removal and Coolant Circulation - High Water Level3/4.10.L Residual Heat Removal and Coolant Circulation - Low Water Level

The requirement that at least one shutdown cooling mode loop of the residual heat removal (RHR) system be OPERABLE or that an alternate method capable of decay heat removal be demonstrated ensures that sufficient cooling capacity is available to remove decay heat and maintain the water in the reactor pressure vessel below 140°F as required during REFUELING. The RHR Shutdown Cooling subsystem configuration was not designed to be throttled to sufficiently maintain constant reactor coolant temperature. Continuous or intermittent operation of one subsystem can maintain and reduce the reactor coolant temperature as required. Each RHR shutdown cooling subsystem is considered OPERABLE if it can be manually aligned either remotely or locally in the shutdown cooling mode.

The requirement to have two shutdown cooling mode loops of the RHR system OPERABLE when there is less than 23 feet of water above the reactor pressure vessel flange ensures that a single failure of the operating loop will not result in a complete loss of shutdown cooling capability. With the reactor vessel head removed and 23 feet of water above the reactor pressure vessel flange a large heat sink is available for core cooling. Thus, in the event of a failure of the operating shutdown cooling loop, adequate time is provided to initiate alternate methods capable of decay heat removal or emergency procedures to cool the core.