

Union Electric

One Ameren Plaza
1901 Chouteau Avenue
PO Box 66149
St. Louis, MO 63166-6149
314.621.3222

July 28, 1999

U.S. Nuclear Regulatory Commission
Attn.: Document Control Desk
Mail Station P1-137
Washington, DC 20555-0001



Gentlemen:

ULNRC-04076

CALLAWAY PLANT
DOCKET NUMBER 50-483
AMENDMENT NUMBER 131

This is to inform the Commission of the implementation of Amendment No. 131 to the Callaway Facility Operating License No. NPF-30. Amendment No. 131 revised the operating license to reflect a requirement in Specification 3/4.7.1.7 for four operable ASD lines and associated revisions, rather than three operable ASDs. This amendment became effective as of its date of issuance on April 20, 1999, and was fully implemented as of May 14, 1999.

Very truly yours,

A handwritten signature in cursive script that reads "Alan C. Passwater".

Alan C. Passwater
Manager-Corporate Nuclear Services

DJW/jdg

030169

A0011/0

9908030288 990728
PDR ADOCK 05000483
P PDR

cc: M. H. Fletcher
Professional Nuclear Consulting, Inc.
19041 Raines Drive
Derwood, MD 20855-2432

Regional Administrator
U.S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive
Suite 400
Arlington, TX 76011-8064

Senior Resident Inspector
Callaway Resident Office
U.S. Nuclear Regulatory Commission
8201 NRC Road
Steedman, MO 65077

Mr. Jack Donohew (2)
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
1 White Flint, North, Mail Stop 13E16
11555 Rockville Pike
Rockville, MD 20852-2738

Manager, Electric Department
Missouri Public Service Commission
P.O. Box 360
Jefferson City, MO 65102