



Entergy Operations, Inc.
P.O. Box B
Killona, LA 70066
Tel 504 739 6242

Early C. Ewing, III
Director
Nuclear Safety & Regulatory Affairs
Waterford 3

W3F1-99-0126
A4.05
PR

July 29, 1999

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Subject: Waterford 3 SES
Docket No. 50-382
License No. NPF-38
Reporting of Licensee Event Report

Gentlemen:

Attached is Licensee Event Report (LER) 99-008 for Waterford Steam Electric Station Unit 3. This report provides details of the failure to perform testing of Emergency Safety Features filtration units per Technical Specification Surveillance Requirements.

This condition is being reported pursuant to 10CFR50.73(a)(2)(i)(B) as a condition prohibited by the Technical Specifications.

All of the commitments contained in this submittal are identified on the attached commitment identification/voluntary enhancement form.

Very truly yours,

Edward P. Pectus (for E.C. Ewing)
E.C. Ewing
Director,
Nuclear Safety & Regulatory Affairs

ECE/GCS/rtk
Attachments

cc: E.W. Merschoff, (Region IV), C.P. Patel, A.L. Garibaldi,
P. Lewis- INPO Records Center, J. Smith, N.S. Reynolds,
NRC Resident Inspectors Office, Administrator - LRPD

IE22/1

030074
9908030347 990729
PDR ADOCK 05000382
S PDR