

Commonwealth Edison Company
Quad Cities Generating Station
22710 206th Avenue North
Cordova, IL 61242-9740
Tel 809-654-2241

ComEd

LWP-97-102

October 23, 1997

U.S. Nuclear Regulatory Commission
Washington, DC 20555

Attn: Document Control Desk

Reference: Quad Cities Nuclear Power Station
Docket Number 50-265, DPR-30, Unit Two

Enclosed is Licensee Event Report (LER) 97-005, Revision 1, for Quad Cities Nuclear Power Station.

This revision is being submitted in accordance with 10 CFR 50.73(a)(2)(i)(B). The licensee shall report any operation or condition prohibited by the Plant's Technical Specifications. The event dealt with The Unit Two and Shared Emergency Diesel Generators being declared inoperable due to a Parts Issue with the Air Start Motors (ASM).

The following commitment is submitted in this report:


1. Quad Cities Station will implement Parts Evaluation Procedure changes revising the alternate parts replacement procedure to ensure that any differences in form fit and function are reviewed by design engineering and to ensure that the differences are adequately addressed.

IER221

9710310161 971023
PDR ADOCK 05000265
S PDR

STMGR\LER\97\97102

A Unicom Company




October 23, 1997

If there are any questions or comments concerning this letter, please refer them to Charles Peterson, Regulatory Affairs Manager at 309-654-2241, ext. 3609.

Respectfully,

COMMONWEALTH EDISON COMPANY
QUAD CITIES NUCLEAR POWER STATION



L. W. Pearce
Site Vice President
and Acting Station Manager

LWP/CP/plm

Enclosure

cc: A. B. Reach, Regional Administrator, Region III
R. M. Pulsifer, Project Manager, NRR
C. G. Miller, Senior Resident Inspector, Quad Cities
W. D. Leech, MidAmerican Energy Company
D. C. Tubbs, MidAmerican Energy Company
M. E. Wagner, Licensing, ComEd
F. A. Spangenberg, Regulatory Affairs Manager, Dresden
INPO Records Center