

October 13, 1999

Mr. Theodore A. Sullivan
Vice President Nuclear and Station Director
Entergy Nuclear Generation Company
Pilgrim Nuclear Power Station
600 Rocky Hill Road
Plymouth, MA 02360

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION (RAI) REGARDING GENERIC LETTER 87-02 (UNRESOLVED SAFETY ISSUE A-46), "VERIFICATION OF SEISMIC ADEQUACY OF MECHANICAL AND ELECTRICAL EQUIPMENT IN OPERATING PLANTS," PILGRIM NUCLEAR POWER STATION (TAC NO. M69471)

Dear Mr. Sullivan:

By letter dated August 6, 1999, you provided additional information on the unresolved safety issue (USI) A-46 implementation methodology used at the Pilgrim Nuclear Power Station. The NRC has reviewed this information and determined that additional information is needed to complete the review. Enclosed is the staff's RAI. We request that you respond by October 30, 1999, as discussed with and agreed upon by Stephen Brennon of your staff.

Questions regarding this request should be sent to my attention at the above address or you can contact me at (301) 415-1445.

Sincerely,

Original signed by:

Alan B. Wang, Project Manager, Section 2
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-293

Enclosure: Request for Additional Information

NRC FILE CENTER COPY

cc w/encl: See next page

DISTRIBUTION

Docket File	TClark	YKim
PUBLIC	OGC	CAndersen, RGN-I
PDI-2 Reading	ACRS	EAdensam (e-mail)
JClifford	RRothman	
AWang	Cwu	

DFOI

OFFICE	PDI-2/PM	PDI-2/LA	PDI-2/SC		
NAME	AWang:lcc	TClark <i>JRC</i>	JClifford		
DATE	10/7/99	10/9/99	10/7/99		

OFFICIAL RECORD COPY
DOCUMENT NAME: M69471.RAI 0023

9910150141 991013
PDR ADOCK 05000293
P PDR



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

October 13, 1999

Mr. Theodore A. Sullivan
Vice President Nuclear and Station Director
Entergy Nuclear Generation Company
Pilgrim Nuclear Power Station
600 Rocky Hill Road
Plymouth, MA 02360

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION (RAI) REGARDING GENERIC LETTER 87-02 (UNRESOLVED SAFETY ISSUE A-46), "VERIFICATION OF SEISMIC ADEQUACY OF MECHANICAL AND ELECTRICAL EQUIPMENT IN OPERATING PLANTS," PILGRIM NUCLEAR POWER STATION (TAC NO. M69471)

Dear Mr. Sullivan:

By letter dated August 6, 1999, you provided additional information on the unresolved safety issue (USI) A-46 implementation methodology used at the Pilgrim Nuclear Power Station. The NRC has reviewed this information and determined that additional information is needed to complete the review. Enclosed is the staff's RAI. We request that you respond by October 30, 1999, as discussed with and agreed upon by Stephen Brennon of your staff.

Questions regarding this request should be sent to my attention at the above address or you can contact me at (301) 415-1445.

Sincerely,

A handwritten signature in cursive script that reads "Alan Wang".

Alan B. Wang, Project Manager, Section 2
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-293

Enclosure: Request for Additional Information

cc w/encl: See next page

Pilgrim Nuclear Power Station

cc:

Resident Inspector
U. S. Nuclear Regulatory Commission
Pilgrim Nuclear Power Station
Post Office Box 867
Plymouth, MA 02360

Chairman, Board of Selectmen
11 Lincoln Street
Plymouth, MA 02360

Chairman, Duxbury Board of Selectmen
Town Hall
878 Tremont Street
Duxbury, MA 02332

Office of the Commissioner
Massachusetts Department of
Environmental Protection
One Winter Street
Boston, MA 02108

Office of the Attorney General
One Ashburton Place
20th Floor
Boston, MA 02108

Dr. Robert M. Hallisey, Director
Radiation Control Program
Commonwealth of Massachusetts
Executive Offices of Health and
Human Services
174 Portland Street
Boston, MA 02114

Regional Administrator, Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. C. Stephen Brennon
Licensing Superintendent
Pilgrim Nuclear Power Station
600 Rocky Hill Road
Plymouth, MA 02360-5599

Mr. Jack Alexander
Manager, Reg. Relations and
Quality Assurance
Pilgrim Nuclear Power Station
600 Rocky Hill Road
Plymouth, MA 02360-5599

Mr. David F. Tarantino
Nuclear Information Manager
Pilgrim Nuclear Power Station
600 Rocky Hill Road
Plymouth, MA 02360-5599

Ms. Jane Periov
Secretary of Public Safety
Executive Office of Public Safety
One Ashburton Place
Boston, MA 02108

Mr. Steve McGrail, Director
Attn: James Muckerheide
Massachusetts Emergency Management
Agency
400 Worcester Road
P.O. Box 1496
Framingham, MA 01701-0317

Chairman, Citizens Urging
Responsible Energy
P.O. Box 2621
Duxbury, MA 02331

John M. Fulton
Assistant General Counsel
Pilgrim Nuclear Power Station
600 Rocky Hill Road
Plymouth, MA 02360-5599

Chairman
Nuclear Matters Committee
Town Hall
11 Lincoln Street
Plymouth, MA 02360

Ms. Mary Lampert, Director
Massachusetts Citizens for Safe Energy
148 Washington Street
Duxbury, MA 02332

Mr. William D. Meierert
Nuclear Engineer
Massachusetts Municipal Wholesale
Electric Company
P.O. Box 426
Ludlow, MA 01056-0426

REQUEST FOR ADDITIONAL INFORMATION

PILGRIM NUCLEAR POWER STATION, UNIT 1

1. What is the status of all identified outliers for USI A-46 resolution? For those outliers that have not been implemented please provide a completion schedule.
2. The Generic Implementation Procedure, Revision 2 (GIP-2) provides for several methods of comparing seismic capacity to seismic demand. Method A.1 compares the Seismic Qualification Utility Group Bounding Spectrum to the plant's safe shutdown earthquake (SSE) ground response spectrum. However, GIP-2 places limitations on the use of Method A.1. These limitations are that the SSE ground response spectrum can be used for comparison to the Bounding Spectrum when:
 - The equipment is mounted in the nuclear plant at an elevation below about 40 feet above the effective grade.
 - The equipment, including its supports, has a fundamental natural frequency greater than about 8 Hz.
 - The amplification factor between the free field ground response spectrum (GRS) and the in-structure response spectra (IRS) is not more than about 1.5.

In your letter entitled "USI A-46 Supplementary Information," dated August 6, 1999, Figures 1, 2, 3, and 4 contain plots of the IRS and GRS for the Reactor Building at elevation 23 feet, the Turbine Building at elevation 37 feet, the Radwaste Building at elevation 37 feet and the Diesel Generator Building at elevation 34.5 feet. You used GIP-2 Method A.1 to compare the seismic demand to seismic capacity for safe shutdown equipment list items at these locations. However, the amplification factors, above 8 Hz, of these IRS with respect to the GRS appear to be significantly above the 1.5 limit set by GIP-2. Provide a building specific quantitative justification for the use of Method A.1 at the locations where the amplification exceeds the 1.5 limit above 8 Hz.