



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

JUN 23 1989

Docket No. 50-254
Docket No. 50-265

Commonwealth Edison Company
ATTN: Mr. Cordell Reed
Senior Vice President
Post Office Box 767
Chicago, IL 60690

Gentlemen:

Commonwealth Edison's letters of May 15 and August 28, 1986; April 24, November 24, and December 23, 1987; and January 15, 1988, pertaining to Quad Cities Units 1 and 2, contained your response to IEB 85-03, "Motor-Operated Valve Common Mode Failures During Plant Transients Due to Improper Switch Settings". Our review of the responses indicated the need for additional information which was contained in your letters of May 2 and 18, 1989. In addition, your letter of June 3, 1988, contained your response to Supplement 1 to IEB 85-03. The review of these latest three responses indicates that they do not include all of the valves addressed by the BWROG positions expressed in NEDC-31322 dated September 1986 and in Supplement 1 to NEDC-31322 dated July 1988. Provide a commitment to include all of the valves addressed by the BWROG. This additional information is requested within one month of the date of this letter.

The written report shall be submitted to the Regional Administrator, Region III, under oath of affirmation under provisions of Section 182a, Atomic Energy Act of 1954, as amended. Also, the original copy of the cover letter and a copy of the report shall be transmitted to the U.S. Nuclear Regulatory Commission Document Control Desk, Washington, DC 20555 for reproduction and distribution.

Questions addressing this issue may be forwarded to Richard J. Kiessel, NRR (301) 492-1154.

Sincerely,

Edward G. Greenman, Director
Division of Reactor Projects

Enclosure: Request for
Additional Information

See Attached Distribution

8907050162 890623
PDR ADOCK 05000254
Q PNU

JEH
1/1

JUN 23 1989

Distribution

cc w/enclosure:

T. Kovach, Nucl

Licensing Manager

R. L. Bax, Station Manager

DCD/DCB (RIDS)

Licensing Fee Management Branch

Resident Inspector, RIII

Richard Hubbard

J. W. McCaffrey, Chief, Public

Utilities Division

R. J. Kiessel, NRR

T. M. Ross, NRR