

June 23, 1998

Mr. M. L. Marchi  
Site Vice President - Kewaunee Plant  
Wisconsin Public Service Corporation  
P.O. Box 19002  
Green Bay, WI 54307-9002

SUBJECT: KEWAUNEE NUCLEAR POWER PLANT - REQUEST FOR ADDITIONAL  
INFORMATION REGARDING THE REVIEW OF PROPOSED AMENDMENT  
REGARDING F\* AND EF\* CRITERIA FOR STEAM GENERATOR TUBES (TAC  
NO. MA1977)

Dear Mr. Marchi:

By application dated June 1, 1998, Wisconsin Public Service Corporation (WPSC) submitted for staff review a proposed amendment (PA156) to revise the F\* and EF\* criteria for steam generator (SG) tubes in the Kewaunee Technical Specifications (TS). The proposed amendment would revise the existing F\* distance and EF\* distance in TS 4.2.b to reflect the changes to the primary to secondary differential pressure due to SG tube plugging and sleeving and a minor error made in the original calculations. In order to continue its review, the staff requests that WPSC respond to the attached questions.

If you have any questions regarding this request, please contact me at (301) 415-3026.

Sincerely,

Original signed by:

William O. Long, Sr. Project Manager  
Project Directorate III-3  
Division of Reactor Projects III/IV  
Office of Nuclear Reactor Regulation

Docket No. 50-331

Enclosure: As stated

cc w/encl: See next page

DISTRIBUTION:

JTsao Docket File  
PD3-3 Reading G. Grant, III  
PUBLIC

DF0111

DOCUMENT NAME: G:\KEWAUNEE\F\_STAR.PAI

|        |         |   |           |           |      |          |           |
|--------|---------|---|-----------|-----------|------|----------|-----------|
| OFFICE | PD33:PM | E | PD33:LA   | E         |      | PD33:D   | E         |
| NAME   | WLong   |   | EBarnhill | <i>EB</i> |      | RBellamy | <i>RB</i> |
| DATE   | 6/15/98 |   | 6/19/98   |           | 1/98 | 6/24/98  |           |

OFFICIAL RECORD COPY

9806240145 980623  
PDR ADOCK 05000331  
P PDR

**NRC FILE CENTER COPY**

June 23, 1998

Mr. M. L. Marchi  
Site Vice President - Kewaunee Plant  
Wisconsin Public Service Corporation  
P.O. Box 19002  
Green Bay, WI 54307-9002

SUBJECT: KEWAUNEE NUCLEAR POWER PLANT - REQUEST FOR ADDITIONAL  
INFORMATION REGARDING THE REVIEW OF PROPOSED AMENDMENT  
REGARDING F\* AND EF\* CRITERIA FOR STEAM GENERATOR TUBES (TAC  
NO. MA1977)

Dear Mr. Marchi:

By application dated June 1, 1998, Wisconsin Public Service Corporation (WPSC) submitted for staff review a proposed amendment (PA156) to revise the F\* and EF\* criteria for steam generator (SG) tubes in the Kewaunee Technical Specifications (TS). The proposed amendment would revise the existing F\* distance and EF\* distance in TS 4.2.b to reflect the changes to the primary to secondary differential pressure due to SG tube plugging and sleeving and a minor error made in the original calculations. In order to continue its review, the staff requests that WPSC respond to the attached questions.

If you have any questions regarding this request, please contact me at (301) 415-3026.

Sincerely,

Original signed by:

William O. Long, Sr. Project Manager  
Project Directorate III-3  
Division of Reactor Projects III/IV  
Office of Nuclear Reactor Regulation

Docket No. 50-331

Enclosure: As stated

cc w/encl: See next page

DISTRIBUTION:

JTsao                      Docket File  
PD3-3 Reading          G. Grant, III  
PUBLIC

DOCUMENT NAME: G:\KEWAUNEE\F\_STAR.RAI

|        |         |   |           |    |       |          |    |
|--------|---------|---|-----------|----|-------|----------|----|
| OFFICE | PD33:PM | E | PD33:LA   | E  |       | PD33:D   | E  |
| NAME   | WLong   |   | EBarnhill | EB |       | RBellamy | RB |
| DATE   | 6/15/98 |   | 6/19/98   |    | 1/198 | 6/12/98  |    |

OFFICIAL RECORD COPY



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

June 23, 1998

Mr. M. L. Marchi  
Site Vice President - Kewaunee Plant  
Wisconsin Public Service Corporation  
P.O. Box 19002  
Green Bay, WI 54307-9002

SUBJECT: KEWAUNEE NUCLEAR POWER PLANT - REQUEST FOR ADDITIONAL  
INFORMATION REGARDING THE REVIEW OF PROPOSED AMENDMENT  
REGARDING F\* AND EF\* CRITERIA FOR STEAM GENERATOR TUBES  
(TAC NO. MA1977)

Dear Mr. Marchi:

By application dated June 1, 1998, Wisconsin Public Service Corporation (WPSC) submitted for staff review a proposed amendment (PA156) to revise the F\* and EF\* criteria for steam generator (SG) tubes in the Kewaunee Technical Specifications (TS). The proposed amendment would revise the existing F\* distance and EF\* distance in TS 4.2.b to reflect the changes to the primary to secondary differential pressure due to SG tube plugging and sleeving and a minor error made in the original calculations. In order to continue its review, the staff requests that WPSC respond to the enclosed questions.

If you have any questions regarding this request, please contact me at (301) 415-3026.

Sincerely,

A handwritten signature in cursive script that reads "William O. Long".

William O. Long, Sr. Project Manager  
Project Directorate III-3  
Division of Reactor Projects III/IV  
Office of Nuclear Reactor Regulation

Docket No. 50-331

Enclosure: As stated

cc w/encl: See next page

M. L. Marchi  
Wisconsin Public Service Corporation

Kewaunee Nuclear Power Plant

cc:

Foley & Lardner  
ATTN: Bradley D. Jackson  
One South Pinckney Street  
P.O. Box 1497  
Madison, WI 53701-1497

Chairman  
Town of Carlton  
Route 1  
Kewaunee, WI 54216

Harold Reckelberg, Chairman  
Kewaunee County Board  
Kewaunee County Courthouse  
Kewaunee, WI 54216

Attorney General  
114 East, State Capitol  
Madison, WI 53702

U.S. Nuclear Regulatory Commission  
Resident Inspectors Office  
Route #1, Box 999  
Kewaunee, WI 54216-9511

Regional Administrator - Region III  
U.S. Nuclear Regulatory Commission  
801 Warrenville Road  
Lisle, IL 60532-4531

James D. Loock, Chief Engineer  
Public Service Commission  
of Wisconsin  
P. O. Box 7854  
Madison, WI 53707-7854

REQUEST FOR ADDITIONAL INFORMATION  
REGARDING PROPOSED AMENDMENT  
ON F\* AND EF\* CRITERIA FOR  
STEAM GENERATOR TUBING  
AT KEWAUNEE NUCLEAR POWER PLANT  
DOCKET NO. 50-305

By application dated June 1, 1998, Wisconsin Public Service Corporation (WPSC) submitted for staff review a proposed amendment to revise existing F\* and EF\* criteria for steam generator (SG) tubes in the Kewaunee technical specifications (TS). The proposed amendment would revise the existing F\* distance and EF\* distance in TS 4.2.b to reflect the changes to the primary to secondary differential pressure due to SG tube plugging and sleeving and a minor error made in the original calculations. In order to continue its review, the staff requests that WPSC respond to the following questions:

1. Discuss the differences between the original analysis and revised analysis in which the primary to secondary differential pressure was increased from 1565 psi to 1600 psi; e.g., what were the assumptions applied to the SG tubing in the revised analysis that were different from the original analysis?
2. Confirm that F\* and EF\* distances, including nondestructive examination (NDE) uncertainty of 0.20 inches, will be 1.31 inches and 1.71 inches, respectively. Confirm that the F\* and EF\* criteria will not be applied to any non-sleeved hardroll whose length is less than F\* and EF\* distances of 1.31 inches and 1.71 inches, respectively. Discuss the changes, if any, to the eddy current technique (e.g., probe design) to reflect the proposed changes to the distances. Discuss in detail how the NDE uncertainty of 0.20 inches was derived.
3. TS 4.2.b.6.b specifies that the EF\* region is located a minimum of 4 inches below the top of the tubesheet. Discuss the technical basis of the 4-inch distance.
4. In the footnote on Page 2-1 of WCAP-14677, Revision 1, "F\* and Elevated F\* Tube Alternate Repair Criteria For Tubes With Degradation In The Tubesheet Region Of The Kewaunee Steam Generators," an attachment to the June 1, 1998, application, it is stated that based on NDE, the factory hardrolls in the hot leg tubesheet of SG A in Kewaunee range from about zero to about 2.25 inches in axial length. It is also stated that the typical length is 1.25 inches. The staff understands that the licensee has repaired the undersized, non-sleeved, factory hardrolls by installing additional roll expansion joints directly above the factory hardrolls. However, it is not clear that the average length of the existing non-sleeved hardrolls is 1.25 inches. Provide the average length of the existing non-sleeved hardrolls. Provide the number of the non-sleeved hardrolls that have length shorter than the F\* distance of 1.31 inches and assess their structural and leakage integrity.
5. On page 3 of Attachment 1 to the June 1, 1998, letter, it is stated that Westinghouse corrected a minor error in the original calculation of F\* and EF\* distance. Discuss the error in detail: (1) Discuss whether the error affects F\* and EF\* criteria in existing technical specifications in plants other than Kewaunee; (2) Discuss whether Westinghouse

investigated the error under 10 Code of Federal Regulation Part 21, "Reporting of Defects and Noncompliance." (3) By removing the error, the F\* distance would decrease from 1.12 inches to 1.10 inches and the EF\* distance would increase from 1.44 inches to 1.49 inches. Why did the error cause an increase in one case and a decrease in another case?

6. Discuss whether the revised F\* and EF\* distances, which were calculated by theory, can be supported by the tensile test results in WCAP-14679, "Qualification of Additional Roll Expansion for the Kewaunee Nuclear Power Plant Steam Generators," which was submitted on July 3, 1996, as a part of license amendment 129.