

**Official Transcript of Proceedings**  
**NUCLEAR REGULATORY COMMISSION**

Title: Advisory Committee on Reactor Safeguards  
Kairos Power Licensing Subcommittee

Docket Number: (n/a)

Location: teleconference

Date: Tuesday, April 18, 2023

Work Order No.: NRC-2367

Pages 1-130

**NEAL R. GROSS AND CO., INC.**  
**Court Reporters and Transcribers**  
1716 14th Street, N.W.  
Washington, D.C. 20009  
(202) 234-4433

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

KAIROS POWER LICENSING SUBCOMMITTEE

+ + + + +

TUESDAY

APRIL 18, 2023

+ + + + +

The Subcommittee met via hybrid in-person and Video Teleconference, at 1:00 p.m. EDT, David Petti, Chairman, presiding.

COMMITTEE MEMBERS:

- DAVID PETTI, Chair
- RONALD G. BALLINGER, Member
- CHARLES H. BROWN, JR., Member
- VICKI BIER, Member
- VESNA DIMITRIJEVIC, Member
- GREGORY HALNON, Member
- WALT KIRCHNER, Member
- JOSE MARCH-LEUBA, Member
- JOY L. REMPE, Member
- MATTHEW SUNSERI, Member

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1       ACRS CONSULTANT:

2               DENNIS BLEY

3               STEPHEN SCHULTZ

4

5       DESIGNATED FEDERAL OFFICIAL:

6               WEIDONG WANG

7               LARRY BURKHART

8

9       ALSO PRESENT:

10              ODUNAYO "AYO" AYEGBUSI, NRR

11              BENJAMIN BEASLEY, NRR

12              ANDREW BIELEN, RES

13              MATTHEW DENMAN, Kairos Power

14              KIERAN DOLAN, Kairos Power

15              TIMOTHY DRZEWIECKI, Kairos Power

16              JORDAN HAGAMAN, Kairos Power

17              MICHELLE HART, NRR

18              BRANDON HAUGH, Kairos Power

19              EDWARD HELVENSTON, NRR

20              MATTHEW HISER, NRR

21              DREW PEEBLES, Kairos Power

22              JEFFREY SCHMIDT, NRR

23              KENNETH CHARLES WAGNER, Kairos Power

24

25

## CONTENTS

	<u>Page</u>
1	
2	
3	ACRS Chairman Introductory Remarks 4
4	NRC Staff Introductory Remarks N/A
5	Hermes PSAR Section 12.9 6
6	Hermes SE Section 12.9 15
7	Hermes Chapter 12 Memo N/A
8	Hermes PSAR Chapter 13 - Maximum 23
9	Hypothetical Accident
10	Hermes SE Chapter 13 - Maximum 54
11	Hypothetical Accident
12	Hermes PSAR Chapter 13 - Other Sections 68
13	
14	
15	
16	
17	
18	
19	
20	
21	
22	
23	
24	
25	

P-R-O-C-E-E-D-I-N-G-S

1:00 p.m.

1 CHAIR PETTI: Okay. This meeting will now  
2 come to order. This is a meeting of the Kairos Power  
3 Licensing Subcommittee of the Advisory Committee on  
4 Reactor Safeguards. I'm David Petti, Chairman of  
5 today's subcommittee meeting.  
6

7  
8 ACRS members in attendance are Charles  
9 Brown, Jose March-Leuba, Joy Rempe, Matt Sunseri, Ron  
10 Ballinger, Walt Kirchner, Vesna Dimitrijevic, Vicki  
11 Bier, and Greg Halnon. Our consultants, Dennis Bley  
12 and Steve Schultz, are also present. Weidong Wang of  
13 the ACRS staff is the Designated Federal Official of  
14 this meeting.

15 During today's meeting, the subcommittee  
16 will continue its review of the staff safety  
17 evaluation on the Kairos Power Hermes Non-Power  
18 Reactor Preliminary Safety Analysis. The subcommittee  
19 will hear presentations by and hold discussions with  
20 the NRC staff, Kairos Power representatives, and other  
21 interested persons regarding this matter.

22 A part of presentations by the applicant  
23 and the NRC staff may be closed in order to discuss  
24 information that is proprietary to the licensee and  
25 its contractors, pursuant to 5 USC 552(b)(c)(4).

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Attendance at the meeting that deals with such  
2 information will be limited to the NRC staff and its  
3 consultants, Kairos Power, and those individuals and  
4 organizations who have entered in an appropriate  
5 confidentiality agreement with them. Consequently, we  
6 will need to confirm that we have only eligible  
7 observers and participants in the closed part of the  
8 meeting.

9 The rules for participation in all ACRS  
10 meetings including today's were announced in the  
11 Federal Register on June 13th, 2019. The ACRS section  
12 of the U.S. NRC public website provides our charter,  
13 bylaws, agendas, letter reports, and full transcripts  
14 of all full and subcommittee meetings, including  
15 slides presented there. The meeting notice and the  
16 agenda for this meeting were posted there. We have  
17 received no written statements or requests to make an  
18 oral statement from the public.

19 The subcommittee will gather information,  
20 analyze relevant issues and facts, and formulate  
21 proposed positions and actions, as appropriate, for  
22 deliberation by the full Committee. A transcript of  
23 the meeting is being kept and will be made available.

24 Today's meeting is being held in-person and  
25 over Microsoft Teams for ACRS staff and members, NRC

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 staff, and the applicant. There's also a telephone  
2 bridge line and a Microsoft Teams link allowing  
3 participation of the public. In addressing the  
4 subcommittee, participants should first identify  
5 themselves and speak with sufficient clarity and  
6 volume so that they may be readily heard. When not  
7 speaking, we request that participants mute their  
8 computer microphone or phone by pressing \*6.

9 We'll now proceed with the meeting. Ed, do  
10 you want to say something to kick us off?

11 MR. HELVENSTON: I have no introductory  
12 remarks for the staff, so I think we'll turn it over  
13 to Kairos for the presentation on Section 12.9,  
14 Quality Assurance.

15 MR. HAGAMAN: Thank you. Good afternoon.  
16 My name is Jordan Hagaman. I'm the Director of  
17 Reliability Engineering and Quality Assurance and  
18 Kairos Power. Today, we're talking about Section 12.9  
19 of the PSAR. For a broader context, Chapter 12, in  
20 general, describes all the plans for conduct of  
21 operations at Hermes. This includes facility  
22 operating, emergency planning, security plan, QA plan,  
23 operator training, requalifications, startup, and  
24 environmental reports.

25 CHAIR PETTI: We don't see any slides.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 MR. HAGAMAN: Okay. Let me pause there and  
2 see.

3 CHAIR PETTI: This is interesting. Those  
4 that have computers in the room see them, but we're  
5 not getting them on our screens. So let's pause a  
6 minute.

7 PARTICIPANT: I think there may have been  
8 two different schedulers. There was one that said, it  
9 said placeholder or something. It's possible that  
10 we're in the wrong --

11 CHAIR PETTI: Well, except that this is  
12 where the court reporter is and this is where -- let's  
13 see. Any of the ACRS virtual members online? Matt,  
14 Vesna, Walt?

15 MEMBER SUNSERI: Yes, this is Matt. I see  
16 the slides.

17 MEMBER DIMITRIJEVIC: Yes.

18 CHAIR PETTI: Okay. So I think we're in  
19 the right place.

20 MEMBER KIRCHNER: Yes, I do, too. This is  
21 Walt.

22 (Long pause.)

23 MR. HAGAMAN: All right. Once again, my  
24 name is Jordan Hagaman. And the main thing I wanted  
25 to point out at the title slide is we're looking at

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Section 12.9, which is just one small part of Chapter  
2 12, which describes all of the conduct of operations  
3 for the Hermes plant.

4 So with that, we can jump to the next  
5 slide. 10 CFR 50.34 requires construction permit  
6 applicants to provide a QA program description to be  
7 used to design, build, and operate the structure  
8 systems and components for the reactor. We started  
9 with NUREG 1537, which pointed us to guidance in Reg  
10 Guide 2.5 and ANS 15.8, which was used to develop the  
11 format and content of the quality assurance program  
12 description for the Hermes non-power reactor. This is  
13 provided in full as an appendix to Chapter 12.

14 On the applicability of this QA standard,  
15 ANS 15.8 describes that the type of QA program  
16 appropriate to a research and test reactor is  
17 different than the type of QA program applied to  
18 commercial power reactors. The front matter of the  
19 standard describes the characteristics that are  
20 different between non-power and commercial power  
21 reactors that affect the type of QA program  
22 recommended. The key of these characteristics could  
23 be summarized as the relative simplicity of the safety  
24 case for research and test reactors, which is  
25 fundamentally different than the safety cases for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 larger commercial power reactors. The safety  
2 characteristic of research and test reactors could  
3 also be applied to Hermes.

4 We'll discuss later today in the Chapter 13  
5 presentation about the preliminary safety analysis  
6 prepared for Hermes that shows very large margins to  
7 Part 100 dose consequence limits. This is the key  
8 metric for a simplified safety case, helping us to  
9 establish that the Hermes safety profile is similar to  
10 that of other research and test reactors.

11 We can go the next slide. The Hermes  
12 quality assurance program description applies to  
13 design phase, construction phase, and operations phase  
14 activities affecting quality for safety-related  
15 structures, systems, and components. I'd like to  
16 briefly expand on that to help describe the  
17 applicability of the program. We've discussed the  
18 Hermes definition of safety related in previous  
19 subcommittee meetings. That definition of safety  
20 related is repeated in the Hermes QAPD for  
21 consistency. To summarize, it includes all SSCs that  
22 are responsible for at least one of three things: the  
23 first one being SSCs responsible for the integrity of  
24 the vessel, maintaining coolant above the core; the  
25 second being SSCs responsible for reactivity shutdown

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 capability; and the third is SSCs that provide  
2 capability to prevent or mitigate accident  
3 consequences beyond Part 100 limits.

4 As far as program applicability is  
5 concerned, there's a table in Chapter 3 of the PSAR.  
6 That's Table 3.6-1. This table lists all of the SSCs  
7 for Hermes and notes both safety classification and  
8 quality program applicability. You'll note that all  
9 SSCs designated as safety related are also listed as  
10 quality related. Therefore, the requirements of the  
11 Hermes QA program apply to those SSCs.

12 Examples of the safety-related SSCs are the  
13 reactor vessel, the reactivity shutdown elements, the  
14 decay heat removal system, the reactor protection  
15 system. Quality-affecting activities associated with  
16 those SSCs include the final design, fabrication,  
17 construction and testing.

18 We can go to the next slide, please. All  
19 right. As mentioned in the previous slide, the Hermes  
20 quality assurance program description describes  
21 requirements for design, construction, and operations  
22 phase activities affecting quality. However, at the  
23 CP stage, only the design and construction portions of  
24 the QAPD were subject to review. As a result, the  
25 requirements for facility operations do not appear on

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 this slide, but we do look forward to discussing those  
2 requirements during the review for the operating  
3 license.

4 Also not listed here is the 19th  
5 requirement in the design and construction section of  
6 ANS 15.8. Requirement 19 is custom for research and  
7 test reactors. That's for experimental equipment.  
8 The Hermes demonstration reactor is not being designed  
9 or licensed for experiments. Rather, the project  
10 mission is to demonstrate the construction and  
11 operation of a Kairos FHR and to demonstrate delivery  
12 of low-cost nuclear heat. Without formal defined  
13 experiments, Requirement 19 for experimental equipment  
14 does not apply. What does apply are the traditional  
15 18 QA criteria that we're familiar with. The  
16 requirements described in ANS 15.8 are, more or less,  
17 directly accepted into the Hermes quality assurance  
18 program with only editorial changes.

19 And with that, that's the end of my  
20 prepared remarks.

21 MEMBER HALNON: Hey, Jordan, this is Greg  
22 Halnon. Did I hear you right that there's only two of  
23 the criteria that are in play right now, and it's the  
24 design and what was the other one?

25 MR. HAGAMAN: Design and construction were

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 the ones that are subject to review during the  
2 construction permit stage.

3 MEMBER HALNON: Okay. So I understand your  
4 point on, you know, they'll be more operationally  
5 phased. I'm interested in the corrective action  
6 portion. How, if that's not in -- do you have a  
7 corrective action program now that will just carry  
8 over to the operation phase, it's just not subject to  
9 review right now, or are you waiting to put that in  
10 place later on?

11 MR. HAGAMAN: So the third from the bottom  
12 on the right-hand, the corrective action program,  
13 Requirement 16, is part of the design and construction  
14 phase.

15 MEMBER HALNON: Okay. Thanks.

16 CHAIR PETTI: Members, any other questions?

17 MEMBER BALLINGER: Yes, I have a --

18 CHAIR PETTI: Go ahead.

19 MEMBER BALLINGER: -- I guess it's a  
20 theoretical question. So it's not designed for  
21 experiments. So you build this thing and you start  
22 operating it, and you find out that something doesn't  
23 work and that not work would translate into the FHR.  
24 Are you saying that you cannot, because of the  
25 restrictions, you cannot do an experiment or what

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 would be called an experiment with this plant to solve  
2 a problem which you've discovered that will translate  
3 into the FHR?

4 MR. HAGAMAN: So we would expect anything  
5 that gets implemented in terms of modifications for  
6 the Hermes plant to be subject to the same reasonable  
7 assurance that it's going to perform a safety function  
8 as any of the originally-designed SSCs. So we will  
9 have that reasonable assurance before we put those  
10 SSCs into service, so they wouldn't be considered an  
11 experiment. They'll be just the same as any other SSC  
12 that was part of the original design.

13 CHAIR PETTI: But I think Ron's question  
14 was a little different. Let's say you find, you know,  
15 something doesn't go as planned, not just related  
16 necessarily to SSCs, but something where, in order to  
17 fix it, you might have to go outside your tech spec  
18 and have to change the tech spec. There's a process  
19 for that, I would think, right, so that you could do  
20 that?

21 MR. HAGAMAN: That should fall under our  
22 normal 50.59 process.

23 MEMBER BALLINGER: Yes, okay.

24 CHAIR PETTI: Any other questions, members?

25 MEMBER REMPE: The staff talk about it,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 but, if you explore Ron's question, I thought we kind  
2 of discussed this a while back. If the reactivity  
3 coefficients are as anticipated or you want to try and  
4 better understand some instabilities you see, there  
5 are tech specs and you are going to have to try and  
6 get more data. It seems like that, you know, with an  
7 operating plant, the staff would be cognizant of that  
8 ahead of time. The applicant knows they have to  
9 discuss this with the staff, the staff would say, yes,  
10 okay, you're going to be doing some sort of test.  
11 It's the whole reactor is sort of an experiment, and  
12 they have to communicate it to the staff, and the  
13 staff would have some process in place ahead of time  
14 before the licensee would be able to do that test with  
15 the entire reactor. And I thought the staff had told  
16 us at that time in whatever chapter it was that, yes,  
17 they need to do that and that will be clear.

18 MR. HELVENSTON: Yes, I think when we talk  
19 about there not being experiments, you know, we sort  
20 of mean in the traditional sense where, you know,  
21 they're not necessarily doing some of the, you know,  
22 sample irradiations, radiography, isotope production,  
23 things like that that you'd associate with a  
24 traditional operating non-power reactor. But in a  
25 sense, like you said, it really is the reactor itself

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 would be considered somewhat of an experiment. And we  
2 expect Kairos, Your Honor, in the operating license  
3 phase to have startup plans and sort of, you know,  
4 procedures in place to look at, as they're starting  
5 up, in a phase approached and taking observations and  
6 learning as they go, and, you know, that could still  
7 inform the future operations of the facility.

8 And, certainly, you know, the NRC has, you  
9 know, the regulations have processes in place, like  
10 the 50.59, the license amendment process, you know, if  
11 there needs to be some change to how the reactor is  
12 operated or some system based on the operational  
13 experience that's been collected up to that point.

14 MEMBER REMPE: Thank you.

15 CHAIR PETTI: Okay. Then did the staff  
16 have any slides on QA? Thank you. Go ahead.

17 MR. HELVENSTON: Are you sharing the  
18 slides, Ben? You can go ahead to the next slide.

19 So I'll just start off like we did on, I  
20 think, the previous meeting, just go into the agenda  
21 and a couple of the highlighted level items that apply  
22 to all the sections we're going to be presenting over  
23 the next couple of days, you know, to avoid having to  
24 do this at the beginning of each section again. So  
25 I'll just briefly go over, we'll start out with a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 presentation on PSAR Section 12.9 on quality  
2 assurance. Also, later this afternoon, we'll provide  
3 a presentation on the sections of the PSAR of the  
4 Chapter 13. They're specific to the maximum  
5 hypothetical accident. And then I believe tomorrow  
6 morning we'll follow that up with a discussion of the  
7 remaining sections of Chapter 13 on the postulated  
8 bounded events.

9 In terms of the agenda for each chapter of  
10 the staff's presentation, that will be pretty similar.  
11 We'll start with an overview of the chapter and the  
12 relevant PDCs, if there are any; any topical reports;  
13 what we did for our technical evaluation; and then the  
14 staff's findings and conclusions.

15 Next slide. So in terms of the reg basis  
16 that we looked at in our review of these chapters, the  
17 three regulations that are in common for every section  
18 we looked at is 50.34(a), 50.35, and 50.40, as well as  
19 the guidance in NUREG 1537, Part 2, which provides the  
20 review plan and the acceptance criteria for the  
21 application. In some of the subsequent presentations,  
22 there may be some additional regulations and guidance  
23 that are applicable to that specific section that  
24 we'll go into detail on the following presentations.

25 So with that, I'll turn it over to Ayo who

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 will present on the NRC staff's review of PSAR Section  
2 12.9 on quality assurance.

3 MR. AYEGBUSI: Thanks, Ed. So good  
4 afternoon. My name is Ayo Ayegbusi. Can you hear me?  
5 All right. Like I said, good afternoon. My name is  
6 -- is this better? All right. My name is Ayo  
7 Ayegbusi, and I am a reactor operations engineer in  
8 the Quality Assurance and Vendor Branch in NRR. My  
9 presentation today will discuss the staff's review of  
10 the quality assurance section in the Kairos Hermes  
11 PSAR.

12 Next slide, please. All right. So in  
13 Section 12.9 of the PSAR, Kairos states that its  
14 quality assurance program is based on Reg Guide 2.5  
15 which endorses ANS 15.8, which is the quality  
16 assurance program requirements for research reactors.  
17 The Kairos Hermes QAPD is described in Appendix B of  
18 PSAR Chapter 12. So that's just background  
19 information, some of which Kairos has covered.

20 Next slide, please. In addition to the  
21 regulations and guidance mentioned earlier during the  
22 common regulatory basis that Ed covered, the staff  
23 specifically reviewed the Kairos Hermes QAPD against  
24 the ANS 15.8 standard.

25 Next slide, please. So for the staff's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 evaluation, the staff evaluated Sections 1 and 2 of  
2 the QAPD because those two sections directly apply to  
3 the construction permit application. As Kairos  
4 mentioned, those sections cover design and  
5 construction.

6 The staff's evaluation found that Kairos  
7 followed the ANS 15.8 standards closely. My many  
8 slides will cover areas where Kairos deviated from the  
9 ANS 15.8 standard. However, the staff did not  
10 evaluate Section 3 of the QAPD because it covers  
11 facility operations, which, at this point, is not  
12 relevant to issuing a construction permit.

13 Next slide, please. The first deviation  
14 from the ANS 15.8 standard is that Kairos proposed an  
15 alternate definition for safety related to match what  
16 is used in PSAR Chapter 3. The staff found this  
17 proposal acceptable because it's consistent with the  
18 Hermes design and the safety related definition in the  
19 ANS 15.8 standard. At this point, my understanding is  
20 that ACRS has been given a draft copy of our safety  
21 evaluation. That does not include our evaluation in  
22 what we found here, but we will be revising that  
23 safety evaluation to discuss our findings as far as it  
24 relates to the safety related definition that Kairos  
25 proposed.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           The next deviation from ANS 15.8 standard  
2           is that the QAPD did not include a section for  
3           experimental equipment. Kairos already covered that.  
4           Again, the staff found this acceptable because the  
5           PSAR states that no experiments will be carried out,  
6           and I'm paraphrasing that.

7           The next deviation from the ANS 15.8  
8           standard is that the QAPD did not include Section 4  
9           and 5 from the standard, namely applicability to  
10          existing facilities and decommissioning respectively.  
11          In this case, the staff found this acceptable because  
12          the QAPD will not utilize an existing facility, and  
13          decommissioning plans are not required for the  
14          construction permit application. And I --

15                 MEMBER HALNON: This is Greg, just real  
16                 quick. You paraphrased to say that they're not going  
17                 to do experiments. Is the demarcation between  
18                 experiment and test clear enough such that we're not  
19                 going to be arguing on whether it's an experiment or  
20                 a test? Because it's like a 50.59 experiment test and  
21                 modification, so is that clear enough in the  
22                 regulation for them to be able to ascertain that no  
23                 experiments will be done?

24                 MR. AYEGBUSI: So like I mentioned earlier,  
25                 because I hear you mentioned regulation, our review

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 was based on the ANS 15.8 standard, which is what  
2 we've endorsed, right. Section 2.19 has to do with,  
3 I forget the title, but it has to do with experiments,  
4 right. I think it's experimental equipment, equipment  
5 for experiments. And so that's focused on  
6 experiments, right. It doesn't address testing.

7 So to your question for testing, I would  
8 have to defer to Ed. What he said earlier is they  
9 would have to address it --

10 MEMBER HALNON: It's not a real fine point.  
11 I'm just curious because, at least in the operating  
12 reactor world, in light water, we always had that  
13 struggle internally. When we did test procedures,  
14 someone said is this experimental or not, and we never  
15 really found a good demarcation of where that line was  
16 between a test and experiment. Now, it may be in the  
17 test reactor world it's much more clear, and that's  
18 what I was kind of getting to, if that's more clear in  
19 the test reactor world, or the research reactor, I'm  
20 sorry.

21 MR. AYEGBUSI: Honestly, I would have to  
22 defer to the other technical staff because this  
23 section really focuses on quality assurance, so, in  
24 essence, the quality of the activities of the design  
25 and construction of the plant so --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1                   MEMBER HALNON: Okay. Well, you said they  
2 were clearly within 2.9, and I'm satisfied with that.  
3 But maybe at another time I'll have that philosophical  
4 discussion. Maybe there's some hard information  
5 somewhere we can get to.

6                   MR. AYEGBUSI: Okay. Next slide, please.  
7 I already spoke to this slide, so I'm going to go on  
8 to the next slide, please.

9                   So the staff's safety evaluation  
10 recommended that the construction permit should  
11 include a condition for the quality assurance program.  
12 The condition requires that the QA program is  
13 implemented, as described in the PSAR, and any changes  
14 that reduce the commitments in the QAPD are submitted  
15 to NRC for approval prior to implementation.

16                   Next slide, please. So in conclusion, the  
17 staff found the preliminary design information to be  
18 consistent with the applicable criteria in NUREG 1537.  
19 The staff concluded that the information in Section  
20 12.9 and Appendix 12(b) of the PSAR is sufficient for  
21 the issuance of a construction permit. Lastly, the  
22 staff concluded that reviews related to the conduct of  
23 operations and decommissioning can be left at the  
24 operating license application phase.

25                   Next slide, please. So that concludes my

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 presentation. Thank you. And are there any  
2 questions?

3 MR. SCHULTZ: I presume that Kairos has  
4 accepted the recommended change that you indicated in  
5 terms of changes to the QA program that can be made  
6 without NRC approval and then submitted 90 days prior  
7 or subsequent? On the previous slide it was  
8 described.

9 MR. HELVENSTON: Yes. We have a proposed  
10 recommended permit condition that's described on that  
11 slide, but that is something that we would likely  
12 verify with Kairos before that's finalized to make  
13 sure they understand and are in agreement with that  
14 condition.

15 MR. SCHULTZ: That sounds like a good idea.  
16 Thank you.

17 CHAIR PETTI: Other comments, members?  
18 Okay. Thank you. With that, we can go to the Chapter  
19 12 memo. The Chapter 12 memo does not have a section  
20 explicitly on Section 12.9, so I think, in expediency,  
21 it's probably not worth, we've already seen the  
22 Chapter 12 memo in March, so I think we can just keep  
23 the schedule moving and move on to Chapter 13.

24 MEMBER SUNSERI: Dave, this is Matt.  
25 You're correct. I mean, we did address the QA program

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 in that memo. We kind of got ahead a little bit, so  
2 it's already been discussed and incorporated into the  
3 memo.

4 CHAIR PETTI: Thank you. So let's move on  
5 to Chapter 13 then. Kairos.

6 MR. DENMAN: Hello. My name is Dr. Matthew  
7 Denman. I'm a reliability engineer at Kairos Power,  
8 and it's my pleasure today to talk to you about the  
9 Hermes Chapter 13 PSAR accident analysis.

10 Next slide. In 10 CFR 50.34(a)(4), it  
11 requires a preliminary safety analysis to assess the  
12 risk to public health and safety from the operation of  
13 a facility and determination of the margins to safety.  
14 In order to demonstrate compliance with 10 CFR 100.11  
15 dose reference values, a maximum hypothetical accident  
16 was developed that bounds the postulated events, and  
17 this is analyzed for dose consequences by challenging  
18 the performance of our functional containment. The  
19 Hermes MHA approach is consistent with the guidance in  
20 NUREG 1537. It's not a physical accident. It is  
21 hypothetical in nature. It includes conservatisms  
22 that maximize the source term and the release off-  
23 site, and it includes a postulated release of  
24 radioactive material.

25 To ensure that postulated events are indeed

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 bound by the MHA, we developed a list of postulated  
2 events that is comprehensive to ensure that any event  
3 with potential significant radiological consequence  
4 will be considered. Initiating events and scenarios  
5 are grouped so that limiting cases for each group can  
6 be qualitatively described in the construction permit  
7 application. Quantitative results will be included at  
8 OL. Acceptance criteria are provided for the  
9 important figures of merit in each postulated event  
10 group to ensure that the potential consequences of  
11 that event group remain bound by the MHA as the design  
12 progresses. Prevention of event initiators are also  
13 justified in the PSAR.

14 Next slide.

15 MR. SCHULTZ: Matt, before you leave that  
16 slide, this is Steve Schultz. You've indicated in  
17 that last group of bullets that, when you go to the  
18 operating license application, you're going to provide  
19 the quantitative results. Is that going to be group  
20 by group or by accident by accident? How are you  
21 going to present those quantitative results?

22 MR. DENMAN: Thank you very much for that  
23 question. The OL will present the results group by  
24 group, but we will have internal analysis to justify  
25 that our grouping or that the presented results is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 bounding of the group.

2 MR. SCHULTZ: Good. Thank you.

3 MR. DENMAN: Okay. So just another slide  
4 to kind of conceptualize this relationship between the  
5 dose limits, the maximum hypothetical accident, and  
6 our postulated events, the MHA is constructed to be  
7 extremely conservative and non-physical to  
8 overestimate the potential off-site dose consequences,  
9 ensure that we have sufficient margin to safety, and  
10 ensure that reasonable design constraints will result  
11 in a bounded postulated event.

12 If you look over at the qualitative figure  
13 on the right, you'll see that we've got our  
14 100.11(a)(1) and (2) dose reference values. That's a  
15 mouthful. There's going to be a sufficient margin  
16 between those reference values and where our MHA dose  
17 is going to occur. Because of the hypothetical and  
18 conservative assumptions that go into the MHA that  
19 will not be included in the postulated events, you're  
20 going to have a standoff of additional dose, and then  
21 you'll have a range of doses or calculated doses where  
22 the potential postulated events will arise, and these  
23 will be due to our traditional design basis  
24 conservatisms that go into both the thermal fluid  
25 calculations and our mechanistic dose or source term

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 methodology. At the PSAR stage, only the MHA dose is  
2 quantitatively evaluated, and this is the only event  
3 that is needed to ensure that sufficient margin exists  
4 to the 100.11 dose reference values.

5 MEMBER MARCH-LEUBA: Hi, this is Jose. You  
6 say on the PSAR stage. Is there any other stage where  
7 the dose would be for other postulated events?

8 MR. DENMAN: Thank you very much for that.  
9 As was mentioned on the previous slide, we are  
10 proposing a series of figures of merit which will,  
11 assuming that we -- sorry, not assuming. We will  
12 demonstrate that those figures of merit meet certain  
13 acceptance criteria and that, by going to the figures  
14 of merit NEPA acceptance criteria, that will map to a  
15 dose less than the MHA.

16 MEMBER MARCH-LEUBA: So only the MHA will  
17 be evaluated. The rest will have to do with figures  
18 of merit?

19 MR. DENMAN: That is what we described.

20 MEMBER MARCH-LEUBA: Thanks.

21 MR. DENMAN: Okay. Next slide. So the  
22 maximum hypothetical accident. I've got a couple of  
23 slides on the overall narrative here. A key feature  
24 of the maximum hypothetical accident is this time-  
25 temperature curve or curves. There's one for the fuel

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 and one for the coolant. What should be noted here is  
2 that explicit system performance is not modeled. In  
3 fact, the boxy nature of the time-temperature curves  
4 are slightly intended to demonstrate that we're not  
5 mechanistically modeling our system performance and  
6 our temperature history. Instead, these temperature  
7 curves are designed to ensure that a bounding  
8 radionuclide release from our functional containment  
9 will occur, so it's not just the high temperatures but  
10 it's the extended and exaggerated time intervals over  
11 which we're at these high temperatures will ensure  
12 that the functional containment will be maximally  
13 stressed and off-site doses will be conservatively  
14 high.

15 MEMBER REMPE: Before you leave this slide,  
16 could I ask a couple of questions? I struggled on  
17 where to bring this up, but I think this temperature  
18 plot is the best place to bring this up.

19 When I look at your various scenarios or  
20 challenges and events you have, you have an event  
21 where you have air ingress into your primary system,  
22 and you note that the graphite oxidizes, as well as  
23 the carbon matrix. And I don't see anywhere in the  
24 PSAR or that topical report you generated or even in  
25 the staff SE about combustible gas generation that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 would occur when you oxidize the graphite CO with CO2.  
2 And I'm wondering, I guess you haven't done it yet  
3 because I'm guessing you're waiting, because you've  
4 created this maximum hypothetical accident that's  
5 going to bound all possible challenges, so I'm  
6 guessing you didn't use your codes to evaluate how  
7 much combustible gas got generated, and I don't think  
8 there's any system that I've seen in your description  
9 of what you're going to do with the combustible gas  
10 that gets generated and I'm not sure you know how much  
11 is. And I'm just thinking that somebody needs to  
12 think about combustible gas generation, and maybe it's  
13 a small amount, but anytime you get above 500 - 600 C,  
14 which this plot has, that could be a problem,  
15 especially when you get up to temperatures like 1,000  
16 C or whatever, 850 or whatever.

17 And so, anyway, I'm just kind of thinking  
18 that somebody needs to think about combustible gas  
19 generation and if it could be an issue.

20 MR. HAUGH: Hi, Joy. This is Brandon  
21 Haugh, Director of Modeling Simulation. Great point,  
22 good question. We are considering that. It's, you  
23 know, it requires a lot of, I'm going to say, design  
24 fidelity to understand the predictability of that, but  
25 we are creating models and, if we deem that's a risk,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 we'll be able to understand how much is generated.

2 MEMBER REMPE: So you don't know, and you  
3 might have to add a system or you might want to try  
4 and have a primary system that can withstand the shock  
5 of an ignition, a combustion event or something. It  
6 just seems like somebody ought to do some scoping  
7 calculations early on before you pour concrete and  
8 start ordering components on this.

9 MR. HAUGH: It's great feedback. We have  
10 done that and we are doing that.

11 MEMBER REMPE: So how much gas do you get  
12 and where does it go, if you've already done that and  
13 you don't think it's a problem?

14 MR. HAUGH: Well, it's highly dependent on  
15 the chemistry and the temperatures in the system  
16 because it re-oxidizes back to be non-combustible  
17 depending on the situation. So it's very scenario-  
18 dependent on the amount of air ingress and the  
19 temperature time history. So there's a good amount to  
20 unpack there, and it's probably more than this  
21 discussion is needed, but it will be covered at the  
22 operating license application phase.

23 MEMBER REMPE: Okay. So, again, I'm just  
24 one member, but I strongly recommend that the memo can  
25 point this out and that our letter point this out

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 because this is something that I don't see in Appendix  
2 A, and it's something I think people ought to make  
3 sure gets addressed. And I'll stop there. Thank you.

4 CHAIR PETTI: So just another point, this  
5 is, of course, a big deal in helium gas-cooled  
6 reactors, and you have to go way back, but my  
7 understanding is studies were done, I want to say by  
8 Brookhaven, the CO that's generated is usually on the  
9 lean side, so it's not combustible, at least that's  
10 what they found in HTGRs. So it's probably worth you  
11 guys trying to find that information, as well, and  
12 understand that chemistry, as you think about the  
13 chemistry.

14 MR. DENMAN: Thank you very much. One  
15 other point I just want to clarify is that the time-  
16 temperature curves you're seeing here are bounding  
17 temperatures for our fuel and our fuel covered by our  
18 Flibe, right. So pebbles that are suspended above the  
19 Flibe would, A, not expected to be at these  
20 temperatures and, B, would be handled separately from  
21 the MHA analysis.

22 MEMBER REMPE: Yes, but I don't have any  
23 curves to show me what those temperatures are, I don't  
24 have a risk assessment to show that the frequency of  
25 such events is very low. So, again, I need more

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 information. Of course, you can go ahead and pour  
2 concrete, you can wait until the operating license;  
3 but I think it definitely is something that everybody  
4 needs to think about and have a good answer on.

5 MR. DENMAN: Understood. Thank you for  
6 that comment.

7 MEMBER BALLINGER: This is Ron Ballinger.  
8 You know, this curve puts you squarely at the upper  
9 limit on the stainless steel, and so you're into  
10 Division 5. But the best estimate for some of these  
11 things is considerably lower. So with this bounding  
12 calculation, you're definitely having to consider  
13 creep; is that right?

14 MR. DENMAN: Well, first off thank you very  
15 much for your question. I'll note two things. One,  
16 the MHA is designed to maximize release of radioactive  
17 material from our functional containment. It is not  
18 an accident that is designed to analyze stress on  
19 vessels or other components within the system. In  
20 fact, our commitment on our vessel temperature in the  
21 CPA is lower than the 816 ASME steel temperature  
22 limit. We are using this higher temperature as the  
23 stressor on our functional containment and then that  
24 delta between where the temperatures actually are  
25 going to wind up in our system and these evaluated

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 temperatures will play into why our MHA will end up  
2 releasing more radionuclides than our postulated  
3 events will.

4 MEMBER BALLINGER: Okay. Thanks.

5 CHAIR PETTI: So I view it as sort of an  
6 artificial thing, right.

7 MEMBER BALLINGER: You could artificially  
8 fail the --

9 CHAIR PETTI: Well, right, in this  
10 hypothetical sense. But, yes, the few curves that are  
11 in the appendix of the technical report I think shows  
12 there's good margin there, and I actually noted that  
13 in our letters. Keep going.

14 MR. DENMAN: Okay. Thank you. So for our  
15 maximum hypothetical accident, we have radionuclides  
16 that are postulated to diffuse from TRISO particles.  
17 The distribution of TRISO particles included in the  
18 MHA account for both manufacturing defects and  
19 potential in-service failures prior to the transient  
20 occurring.

21 Pre-transient diffusion of radionuclides  
22 from kernels are hypothetically and conservatively not  
23 modeled to maximize the fuel inventory available for  
24 release during the MHA. Radionuclides are postulated  
25 to evaporate and de-gas from the Flibe, as driven by

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 the conservative natural circulation boundary  
2 conditions. No hold up of any gases are credited  
3 within the Flibe portion of the functional  
4 containment.

5 Tritium is conservatively assessed to  
6 maximize both its initial inventory and its subsequent  
7 release. The initial inventory of Tritium is  
8 conservatively assessed and released. Tritium is  
9 conservatively postulated to desorb from in-vessel  
10 graphite as a function of temperature and  
11 instantaneously release from both steel and Flibe.

12 CHAIR PETTI: Matt.

13 MR. DENMAN: Yes, sir.

14 CHAIR PETTI: The question on the tritium.  
15 Did you include all the sources besides the Flibe?  
16 Did you look at lithium impurity in graphite and  
17 ternary fission sources? I'd like at the ternary  
18 fission, and I scaled it. I don't think it's an  
19 issue. I always am not sure on the lithium and  
20 graphite.

21 MR. DENMAN: I agree with you. The ternary  
22 fission is very insignificant and, in fact, that is  
23 part of our fuel inventory that subsequently would  
24 diffuse out through our grouping structures. The  
25 lithium impurities in the graphite is considered.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 CHAIR PETTI: Okay. That's good. I mean,  
2 in the old days, there used to be a lot of lithium in  
3 graphite, and people got very worried about it. I  
4 don't think it's a problem today. I think they're  
5 just better quality graphite. But if you go and read  
6 the old literature, you can get a little confused that  
7 it's still a problem. I don't think it's as problem.  
8 I'm glad you confirmed it. Thanks.

9 MR. DENMAN: Okay. And then --

10 MR. SCHULTZ: Matt, this is Steve Schultz.  
11 It's not stated on this slide, but, in the  
12 documentation, with regard to the TRISO particles, the  
13 TRISO behavior during the accident, the release is  
14 from diffusion only, and then it would be a different  
15 release if the particles are failed before the  
16 accident. But the particles do not fail during the  
17 accident; is that correct?

18 MR. DENMAN: That is correct. The  
19 diffusion is an effective diffusion term, so it, you  
20 know, accounts for multiple different ways  
21 radionuclides can move through the system and just  
22 approximate it as a diffusivity. In-service failures  
23 are pre-transient. We do not expect there to be a  
24 statistically-significant fraction of in-transient  
25 failures, as will be shown in our postulated events.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Thus, the transient failures are not included in the  
2 MHA.

3 MR. SCHULTZ: Okay. And you demonstrate  
4 that statement regarding the events that are evaluated  
5 will demonstrate that there isn't going to be particle  
6 failure as a result in those events that we'll see  
7 evaluated at the operating license stage?

8 MR. DENMAN: Correct.

9 CHAIR PETTI: So, Steve, if you look at the  
10 database on TRISO, the failure rates under the  
11 accidents that go up to 1600 degrees is like 10 to the  
12 minus 5, and they're assuming 10 to the minus 3 order,  
13 so it's down in the --

14 MR. SCHULTZ: Good. Thank you, Matt.

15 MR. DENMAN: Thank you. Okay. So going  
16 through the methodology in a little bit more detail,  
17 the Hermes MHA uses a methodology or methodologies  
18 from the approved KP-FHR mechanistic source term  
19 methodology topical report, KP-TR-12-P-A. The  
20 concepts, the following concepts will directly  
21 leverage the topical report. This includes our  
22 radionuclide grouping and transport approaches for our  
23 TRISO fuel and our Flibe coolant mass transfer  
24 correlations for tritium into graphite reflectors and  
25 pebbles. That's part of the inventory calculation.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Gas face is not credited for confinement of  
2 radionuclides that release from the Flibe free surface  
3 and a two-hour hold up assumption for radionuclide  
4 transporting through the reactor building is modeled.  
5 Conservative unfiltered ground-level releases are  
6 modeled to maximize off-site doses. So all of these  
7 come directly from that topical report.

8 MR. SCHULTZ: Matt, Steve Schultz again.  
9 The ground-level release assumption, is that based  
10 upon the configuration that you expect from the  
11 facility? In other words, that's where you would  
12 expect to see the release? It's not apparent to me  
13 that that maximizes off-site doses at ground-level  
14 release versus an elevated release.

15 MR. DENMAN: Steve, thank you very much for  
16 the question. The ground-level release is not  
17 indicative of what we would expect a release to look  
18 like from the facility. However, as part of the  
19 topical report, we and the staff agreed that this was  
20 a suitably conservative approach.

21 MR. SCHULTZ: Okay. Maybe the staff will  
22 come in on that one in their presentation. Thank you.

23 MR. DENMAN: Okay. The following  
24 additional non-physical conditions provide additional  
25 hypothetical challenges to the functional containment

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 beyond which is described in our mechanistic source  
2 topical report. The hypothetical time-temperature  
3 histories are applied to the transient. You've  
4 already seen a preview of that, and we'll go back and  
5 show you a little bit more in subsequent slides. This  
6 ensures that the MHA will bound the system  
7 temperatures from postulated event groups. The pre-  
8 transient diffusion of radionuclides from the fuel and  
9 the reactor core is negligible. This ensures that the  
10 maximum inventory is available for release at the  
11 initiation of the transient. A bounding vessel void  
12 fraction is assumed to facilitate the release of low  
13 volatile species in the vessel via our bubble burst  
14 release model. And additional conservatisms in  
15 tritium modeling are used to address limitations  
16 associated with the tritium modeling in graphite as  
17 described in our approved topical report.

18 CHAIR PETTI: What was that specific, the  
19 tritium that was adjusted, if you will?

20 MR. DENMAN: So we have a couple of things.  
21 May I table that to the next few slides --

22 CHAIR PETTI: Sure.

23 MR. DENMAN: -- and we'll talk a little bit  
24 more when we get to the inventory discussion, as well  
25 as the release discussion. I don't want to have to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 try to --

2 CHAIR PETTI: Yes, no problem.

3 MR. DENMAN: Thank you. Okay. So our  
4 basic approach for the MHA is kind of three stages.  
5 The first stage, we identify and account for all  
6 sources of material at risk and all barriers that that  
7 material is going to see as it releases through the  
8 system. We're going to evaluate release fractions for  
9 every combination of barrier radionuclide group and  
10 time interval associated with the MHA, and then we're  
11 going to use the RADTRAD and ARCON code to evaluate  
12 our dose consequences at the exclusionary boundary and  
13 the low population zone.

14 And then here we have kind of a graphical  
15 representation. All of our MAR and fuel kernel is  
16 first going to be held up in our TRISO fuel. Then  
17 it's going to propagate into the Flibe into the gas  
18 face. Circulating activity is going to start in the  
19 Flibe but then can evaporate or de-gas into the gas  
20 face. Our structural MAR is tritium and argon-41.  
21 These are both gases, so, once they release from the  
22 graphite, they bypass the Flibe and move directly into  
23 the gas face.

24 Diving a little bit deeper into our sources  
25 of material at risk, most of our material at risk in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 our system is contained within the TRISO fuel. The  
2 Serpent 2 code is used to evaluate fuel inventories  
3 for our reactor. Pre-transient depletion of  
4 radionuclides from the fuel is neglected in order to  
5 maximize the inventory of available material at risk.  
6 The circulating activity uses a bounding circulating  
7 activity distribution of radionuclides. This is  
8 expected to be controlled by technical specifications.  
9 And, importantly, the circulating activity, because  
10 this is a bounding value, is accommodating what we  
11 expect to see from nominal release of radionuclides  
12 from the TRISO fuel into the Flibe coolant. So any  
13 radionuclides that would have nominally left the TRISO  
14 fuel into the Flibe coolant during normal operations  
15 are effectively being double-counted here because that  
16 TRISO fuel assumes that there's no depletion of that  
17 radionuclides.

18 Next slide. So we also have our structural  
19 MAR. We'll focus on tritium first. The inventory  
20 conservatively bounds the operating lifetime at a full  
21 capacity factor with margin while accounting for  
22 differential uptake rates of our pebbles and  
23 reflector. The transfer from Flibe to structures, the  
24 tritium is assumed to be born in the Flibe but  
25 transferred to and absorbed into structures.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Primarily, this is the graphite that's going to uptake  
2 the tritium and store it up for release in the maximum  
3 hypothetical accident.

4 Transport speciation is conservatively  
5 assigned to tritium fluoride to maximize the tritium  
6 absorption into our system, e.g. our graphite. And  
7 then transfer from Flibe to structures is determined  
8 by max transfer coefficients from our predicted Flibe  
9 flow characteristics at steady state in our reactor.

10 When we talk about absorption within  
11 structures, the tritium absorbs solely as a function  
12 of mass transfer from the Flibe to structures, i.e.  
13 there's no diffusion resistance. If it can transfer  
14 in, it gets stored and locked up. And then retention  
15 of that tritium is modeled without any steady-state  
16 release mechanism, so this a perfect absorber of  
17 graphite. It just sucks in tritium due to mass  
18 transfer during the operation of the facility and then  
19 this should maximize the quantity of tritium that then  
20 would be available for release during the transfer.

21 CHAIR PETTI: So, Matt, just a question.  
22 In reality, there will be partitioning between the  
23 Flibe and the graphite, and the question is if, in  
24 fact, you made the graphite less sorb to, so the  
25 inventory was higher in the salt, doesn't it come out

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 of the salt easier than it comes out of the graphite?  
2 So is that truly a conservative assumption to put it  
3 all in the graphite? Wouldn't it be more conservative  
4 to keep it in salt? Did you look at that sort of  
5 stuff?

6 MR. DENMAN: Thank you very much for the  
7 question. I would note that the quantity of tritium  
8 that we end up absorbing into the graphite are orders  
9 of magnitude higher than the quantity of tritium that  
10 is expected to be circulating through the salt. We  
11 did look at a lot of these sensitivities, and it was  
12 much more conservative, given these set of boundary  
13 conditions have as much tritium absorbed into the  
14 salt. Also, due to our -- sorry. Not in the salt, in  
15 the graphite.

16 Also, due to our highly-conservative  
17 release models, the tritium in the graphite gets  
18 released in a non-physical rapid rate. So even  
19 though, yes, the graphite is going to hold it a little  
20 bit more than the Flibe as we model the system in the  
21 MHA, it's not that much more.

22 CHAIR PETTI: Okay.

23 MR. DENMAN: And we can talk a little bit  
24 more about that as we get to the release models.

25 CHAIR PETTI: Okay. Thanks.

1 MR. DENMAN: Not a problem. And thank you  
2 for your question. Okay. So moving on -- no, no,  
3 argon-41.

4 MR. PEEBLES: Before we move on from that,  
5 we did have a correction to make. So, Kieran, are you  
6 online?

7 MR. DOLAN: Yes, I'm here. Can you hear  
8 me?

9 MR. PEEBLES: Yes. Can you provide a  
10 correction to an earlier statement about lithium  
11 impurities?

12 MR. DOLAN: Yes. So a couple of slides  
13 ago, we were talking about which sources of tritium  
14 are included for these calculations on tritium MAR for  
15 the MHA. So in our initial analysis here, we are just  
16 including the tritium sources produced by neutron  
17 irradiation of Flibe, so the numbers fed to the MHA in  
18 the current state do not include evaluations of  
19 tritium produced by lithium impurities in the  
20 graphite. We don't expect those to be significant  
21 contributors to the overall tritium production or  
22 tritium source term, but that is a detail we could  
23 evaluate for source term tritium calculations in the  
24 operating license application.

25 CHAIR PETTI: I think you're right. It's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 just worth confirming it when you get to the OL.

2 MR. DOLAN: Right.

3 MR. DENMAN: Thank you very much, Kieran.  
4 My apologies on that misstatement. Okay. So for  
5 argon-41 released, argon-41 is primarily produced via  
6 neutron activation of argon-40 to argon-41, and we are  
7 assuming that the inventory available for release from  
8 our system consists of the argon-41 contained within  
9 the graphite's closed porosity.

10 Okay. Next slide. For our release models,  
11 we will talk first about our TRISO fuel. The time-  
12 temperature history for this fuel, and this fuel is in  
13 the in-core fuel or, you know, submerged within the  
14 Flibe, you can see the time-temperature history as  
15 pointed out. It's, first, this higher dotted line,  
16 and then it moves into the more solid darker line.  
17 All of the fuel within the core is assumed to be at  
18 this temperature simultaneously.

19 Transport through the TRISO layers are  
20 modeled using fixed law of diffusion. The CORSOR  
21 model is used for kernel diffusivity or diffusion of  
22 radionuclides out of the kernel. And then the IAEA  
23 correlations described in the construction permit  
24 application are used for layered diffusivity or  
25 movement of radionuclides through each of those

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 layers.

2 Diffusion, again, is driven by this  
3 hypothetical temperature curve. Each layer and the  
4 kernel all have the exact same temperature as  
5 described this temperature curve. And transient  
6 diffusion of fission products was shown, given the low  
7 temperatures that we see in this hypothetical  
8 temperature curve, even though they're bounding of our  
9 postulated events, they're low for TRISO accident  
10 analysis in general, is negligible if even a single  
11 pick layer remains intact. Thus, the total release  
12 from our fuel is really dominated by releases from  
13 exposed kernels within the TRISO configuration.

14 Okay. Next slide. The --

15 MEMBER KIRCHNER: This is Walt Kirchner.  
16 Could I ask, could you -- I'm not sure this is a  
17 proprietary because you're using EPRI's spec. What's  
18 your assumption on the exposed kernel fraction?  
19 Because you're right. At these temperatures, that  
20 would be the dominate source of uranium and/or fission  
21 products.

22 MR. DENMAN: I'm not sure if that number is  
23 proprietary. Let me look to my --

24 CHAIR PETTI: I hope not. It's in our  
25 letter. It's been in our memos.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER KIRCHNER: Yes. It's in the EPRI  
2 spec, if that's what you're using.

3 MR. DENMAN: It's very close to that spec.

4 MEMBER KIRCHNER: Can you hazard a number?

5 CHAIR PETTI: Yes, aren't you assuming a  
6 much higher number than EPRI?

7 MR. PEEBLES: So we can confirm that it's  
8 not proprietary and then get back to you after the  
9 break, if that works.

10 MR. DENMAN: I'd want to look up the exact  
11 number. I don't have it right in front of me, but we  
12 can get back to you.

13 Okay. So maximum hypothetical releases  
14 from our Flibe coolant. The Flibe provides a  
15 secondary functional containment barrier bounding,  
16 this bounds the circulating activity or, sorry, Flibe  
17 provides secondary functional containment barrier to  
18 both the bounding circulating activity and our in-  
19 transient releases of fission products from TRISO.

20 There are two primary release pathways from  
21 the Flibe. These include bubble burst as the initial  
22 assumed conservative void fraction, bursts at the top  
23 of our Flibe free surface, and then the evaporation,  
24 which is driven by the time-temperature curve.

25 Certain radionuclide groups effectively

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 bypass Flibe's functional containment as no credit is  
2 given for gas retention within our Flibe in the MHA,  
3 and highly-volatile noble metals who have a high-vapor  
4 pressure or are modeled as having a high-vapor  
5 pressure evaporate extremely quickly in our MHA.  
6 Thus, they effectively have no hold up.

7 CHAIR PETTI: So, Matt, just to be clear  
8 since most of those fission products aren't that  
9 important, iodine is like a noble gas that follows  
10 that pathway?

11 MR. DENMAN: Per our mechanistic source  
12 term topical report, iodine is grouped as a salt-  
13 soluble fluoride.

14 CHAIR PETTI: Oh, okay. So it's like  
15 cesium. It stays in the salt.

16 MR. DENMAN: Correct.

17 CHAIR PETTI: And then has -- okay.

18 MR. SCHULTZ: Matt, Steve Schultz. You  
19 sort of mentioned this before, but, the bounding  
20 circulating activity, you assume what is in technical  
21 specifications for that value in the calculation?

22 MR. DENMAN: Yes. Thank you very much for  
23 the question. The circulating activity is assumed to  
24 be maintained via technical specifications, although  
25 those values will not be provided until OL.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1           MR. SCHULTZ: But in the numbers that you  
2 provided in the MHA calculation, you depict a typical  
3 number that might be used in the technical  
4 specifications or just bounded it in some fashion?

5           MR. DENMAN: We bounded what we believe to  
6 be, what would be in the circulating activity given  
7 the state of the design as reflected in the PSAR.

8           MR. SCHULTZ: Okay. Thank you.

9           MEMBER KIRCHNER: This is Walt Kirchner.  
10 You would then, Matthew, do the same thing with the  
11 argon cover gas, right? Because on the previous  
12 slide, you talked about argon-41 release that had been  
13 trapped in structure, but the cover gas would be  
14 activated, as well. So that would be controlled by  
15 tech specs, and that would be added into the MHA?

16          MR. DENMAN: Yes.

17          MEMBER KIRCHNER: Thank you.

18          MR. DENMAN: Okay. So I think we can move  
19 on to the next slide. For structural MAR, tritium is  
20 assumed to be held within the graphite grains. No  
21 hold up of tritium, and the Flibe instantly drops the  
22 concentration of tritium outside the graphite grains  
23 to zero. So, effectively, the grains are modeled as  
24 a sphere. You have a constant flux of tritium that's  
25 pushing more and more tritium into that graphite

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 grain. The flux drops to zero outside of the grain,  
2 and now all of that tritium that was being forced into  
3 the grain is now able to rapidly diffuse out of the  
4 grain due to this immediate and non-physical  
5 concentration gradient.

6 The MAR outside of the graphite grains are  
7 instantly released at the start of the transient; and  
8 within tens of hours, basically, all of the tritium  
9 that is stored within these grains are modeled to be  
10 released, which is non-physical and extremely  
11 conservative.

12 Next slide. So then we can move on to our  
13 gas and atmospheric transport. Once you have any  
14 gases and evaporated materials that leave our  
15 functional containment, they bypass the vessel head  
16 and go directly into the reactor building. That's  
17 what they're modeled to do. In reality, the vessel  
18 head would contain these radionuclides, but they're  
19 modeled to bypass the vessel head. And then they're  
20 input into RADTRAD. RADTRAD has two depletion  
21 mechanisms that we use for radionuclides that enter  
22 the reactor building. That is radioactive decay and  
23 aerosol settling through the Henry correlation. There  
24 is a conservative two-hour hold-up assumption applied  
25 to radionuclides that enter the reactor building, and,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 after that two-hour hold-up assumption is applied,  
2 they are released to the environment. This is where  
3 ARCON 96 is used to calculate our dispersion  
4 estimates, our chi over Qs. It inputs hourly  
5 radiological data. It evaluates distances from the  
6 reactor building to the exclusionary boundary in low-  
7 population zone, and it uses multiple approved values  
8 from the KP-TR-12 topical report. And once all that  
9 information is fed in, out is provided the time  
10 average dispersion values which you can see on the  
11 table.

12 Next slide.

13 MR. SCHULTZ: Matt, Matt, this is Steve.  
14 I'm sorry. Are you finished here?

15 MR. DENMAN: Yes.

16 MR. SCHULTZ: If you didn't assume any  
17 depletion mechanisms, how much would that affect your  
18 answer for release in RADTRAD?

19 MR. DENMAN: Steve, thank you for your  
20 question. I believe, as part of our methodology, we  
21 always look at the release, we always calculate the  
22 release fraction from the building. Those release  
23 fractions are, the equation for the building release  
24 fraction that we propose is in our mechanistic source  
25 term topical report. I believe, and it's been a while

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 since I've looked at it, but it's roughly on the order  
2 of a release fraction of 0.9-ish.

3 It's a little different for different  
4 radionuclides. They have different decay rates.  
5 Gases, obviously, don't settle. Our off-site releases  
6 are heavily dominated by gases, but it's roughly on  
7 the order of 0.9.

8 MR. SCHULTZ: That makes sense. Thank you.

9 MEMBER KIRCHNER: May I ask a question?  
10 This is Walt again. Matthew, since you don't take  
11 credit for confinement, when you look at the leakage  
12 from the reactor building, I presume it would be at  
13 the upper level, not the ground level. Did you look  
14 at how that might impact your results?

15 MR. DENMAN: Thank you very much for your  
16 question. Can I restate it, restate your question to  
17 make sure I understand?

18 MEMBER KIRCHNER: Sure.

19 MR. DENMAN: You're asking, I believe  
20 you're asking did we look at the delta between an  
21 elevated release and a ground-level release to see  
22 what the dispersion changes would --

23 MEMBER KIRCHNER: Yes, that's one part.

24 MR. DENMAN: -- or how that would impact  
25 dispersion changes. Thank you for that question. No,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 we did not model the difference between an elevated  
2 release versus a ground-level release due to the  
3 approval of the ground-level release being  
4 conservative in our mechanistic source term topical  
5 report.

6 MEMBER KIRCHNER: Okay. I can go back and  
7 review again the mechanistic source term topical  
8 report. But then a second question is do you have  
9 separation. A two-hour hold up, that's based on, if  
10 I remember correctly, that's based on civil  
11 engineering code standards for unventilated building,  
12 but you're dealing with hot, potentially hot gases or  
13 at least a fairly warm environment, and you're dealing  
14 with tritium. Does that factor into these analyses?

15 MR. DENMAN: Thank you very much for that  
16 question. The two-hour hold up, again, is a parameter  
17 that was approved within a mechanistic source term  
18 topical report. It was actually pulled from NRC  
19 guidance for design basis accident dose calculations  
20 from fuel handling accidents in the spent fuel  
21 building and releases in open containment. So if  
22 you're doing, if you're moving fuel within the  
23 containment of a light water reactor, you have the  
24 doors open, and you have a release of radioactive  
25 material and it's just allowed to migrate out of an

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 open building, that's where the two-hour hold-up  
2 assumption came from, and that was the basis for our  
3 argument within the approved source term topical  
4 report.

5 MEMBER KIRCHNER: Okay. Thank you.

6 MEMBER HALNON: Just one other question.  
7 This is Greg. The ARCON 96, did you do any  
8 sensitivity runs on that based on different site  
9 layouts? In other words, different buildings may be  
10 in the way versus a clear path to the site boundary?

11 MR. DENMAN: Thank you very much for that  
12 question. No, we did not do any calculations of a  
13 torturous path of the plume through the building. We  
14 used the straightest path from the exterior of our  
15 building to the site boundary.

16 MEMBER HALNON: Do you feel like that's the  
17 most conservative, given the potential wave effect of  
18 different buildings that may be in the way that could  
19 actually cause a redirection of different air flows?

20 MR. DENMAN: Yes, we believe that that is  
21 the conservative path.

22 MEMBER HALNON: Okay. Thanks.

23 MR. DENMAN: Okay. So now to the results.  
24 As is seen on this table, the dose results meet the 10  
25 CFR 100.11 reference values at the EAB and LPZ with

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 significant margin both for the exclusionary boundary,  
2 whole-body dose, and thyroid, and the low-population  
3 zone over 30 days.

4 Okay. Next slide. To conclude, the MHA  
5 dose consequence results meet the site dose reference  
6 values in 10 CFR 100.11(a)(1) and (2) at the EAB and  
7 LPZ with significant margin, and the MHA dose is  
8 bounding because it employs various non-physical  
9 conditions that are beyond the expectations of design  
10 basis calculations.

11 And with that, thank you very much for your  
12 time, attention, and questions.

13 CHAIR PETTI: Members, any additional  
14 questions?

15 MEMBER KIRCHNER: How are you going to  
16 proceed, Dave? Are we going to hear from the staff on  
17 MHA, or are we going to events next?

18 CHAIR PETTI: MHA first, I think.

19 MEMBER KIRCHNER: Okay.

20 CHAIR PETTI: And then tomorrow will be the  
21 accident detail. So then why don't we hear from the  
22 staff. Is it Michelle? Yes.

23 MS. HART: Good afternoon. I'm Michelle  
24 Hart from the staff; I'll just say that.

25 (Laughter.)

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MS. HART: I forget who I work for. We're  
2 here today to talk about the staff's review of the  
3 preliminary analysis of the maximum hypothetical  
4 accident for the Hermes PSAR.

5 Next slide, please. Okay. So Kairos just  
6 provided a thorough description of the maximum  
7 hypothetical accident assumptions, methods, and  
8 consequence analysis, as described in the PSAR. As  
9 they described, the MHA describes a hypothetical  
10 radionuclide release intended to result in  
11 consequences that are bounding for the postulated  
12 events.

13 With respect to the MHA as bounding, PSAR  
14 Section 13.2.2 described the postulated event  
15 methodology and the figures of merit and acceptance  
16 criteria that Kairos developed to provide assurance  
17 that the MHA consequence analysis is bounding for  
18 postulated events, and we'll be describing our  
19 evaluation of that information at tomorrow's meeting.

20 There are a couple of referenced topical  
21 reports that are relevant to the MHA analysis, and  
22 that is the fuel qualification methodology and the  
23 mechanistic source term methodology.

24 Next slide, please. We had a lot of  
25 discussion about the MHA hypothetical temperature

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 versus time profile that is given to give bounding  
2 radionuclide releases for the MHA. As Kairos had  
3 described, it's not a specific scenario. It's not  
4 physical. And because fission product release and  
5 transport is mainly through diffusion driven by  
6 temperature, it would maximize the releases. And  
7 final determination of that temperature versus time  
8 curve is conservative for the postulated events will  
9 be done during the operating license review.

10 As Kairos has described, it assumes that  
11 the safety related systems function as designed but  
12 includes consideration of the single failure  
13 criterion, even though it's not directly modeled in  
14 the MHA analysis and there are no incremental fuel  
15 particle coding failures from the transient.

16 Next slide, please. So for the consequence  
17 analysis, they do refer to the accident source term  
18 methodology that was in the approved topical report.  
19 It models the system as sources of radioactive  
20 material at risk of release or MAR and the barriers to  
21 release. They apply a release fraction to each  
22 barrier to eventually result in release to the  
23 environment, and that's consistent with the  
24 description of a functional containment. And they do  
25 also model gravitational settling of Flibe aerosols in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 the reactor building consistent with the approval in  
2 the topical report.

3 Next slide, please. To go to a little bit  
4 of our evaluation of the MHA source term modeling, as  
5 we've described several times, that temperature-time  
6 profile does drive the diffusion releases from fuel,  
7 Flibe, and graphite. The MHA assumes conservative  
8 fuel, Flibe, structural and cover gas releases. In  
9 effect, the complete fuel inventory is available for  
10 release into the Flibe. The bounding failed fuel  
11 fractions by cohort are assumed. That's the different  
12 particle layer of failures and bare particles, as  
13 well. Flibe and cover gas radionuclide inventories  
14 are set to technical specification values which will  
15 be provided at the OL.

16 Except for the fuel transient releases,  
17 tritium and argon-41 modeling, the MHA uses approved  
18 mechanistic source term models from the topical  
19 report. The fuel releases are modeled using accepted  
20 methods, and the staff reviewed the fuel release  
21 references to find those models acceptable.

22 The tritium modeling that they have in the  
23 MHA resulted in higher total releases than would be  
24 expected from the topical report methodology, and the  
25 staff also evaluated the modeling assumptions for both

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 the tritium releases and argon-41 in the audit, and we  
2 found them to be conservative.

3 Next slide, please. As noted before, the  
4 mechanistic source term topical report methodology  
5 will not be fully implemented until it's used by the  
6 applicant in the operating license application FSAR.  
7 And the staff will review the final implementation of  
8 that topical report for the Hermes, including the  
9 limitations and conditions in the topical report SE in  
10 its review of the operating license application.

11 Staff presents its evaluation of the site  
12 characteristic accident atmospheric dispersion factors  
13 to the subcommittee on March 23rd.

14 Next slide, please. So to go into some of  
15 the audit, some of the information that we audited.  
16 We did look at the preliminary consequence analysis  
17 and MHA source term information. So we did see their  
18 calculation packages, output from codes, things like  
19 that.

20 In the audit, we were able to confirm the  
21 PSAR description of their MHA analysis. In those  
22 calculation and reference reports supporting those  
23 calculations, we were able to see how they determined  
24 the initial radionuclide inventory and MAR sources,  
25 including for fuel and Flibe, and those calculations

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 of tritium generation and argon-41 inventories, how  
2 they modeled those in the graphite. We were able to  
3 see the calculations estimating releases from the  
4 graphite and the modeling of radionuclide transport  
5 across barriers and the release fractions for those  
6 barriers, as well.

7 We also were able to have an in-person  
8 discussion with the staff that they could show us how  
9 they went through that process using cesium as an  
10 example, isotope, to show us how they could actually  
11 put it into the RADTRAD code to generate the doses.

12 MR. BLEY: Michelle, Dennis Bley with a  
13 question. It actually goes back a slide.

14 MS. HART: Okay.

15 MR. BLEY: But conservative is a word that  
16 makes me a little nervous whenever I hear it. Can you  
17 talk a little bit about what you found conservative?  
18 Was it the results in the quantity released? Was it  
19 the models? Was it the assumptions? Where did you  
20 find the conservatism?

21 MS. HART: So the majority of the  
22 conservatism that we really had and in the discussions  
23 with the staff at Kairos was there was a lot of  
24 conservative-leaning assumptions. They made bounding  
25 assumptions. You know, we were able to see that they

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 had used appropriate models or models that we were  
2 aware are appropriate for the use.

3 MR. BLEY: So if I understand you right,  
4 given the assumptions, you think the modeling was  
5 reasonable, but it's the assumptions that you found to  
6 be conservative?

7 MS. HART: Do you want to add something to  
8 that, Jeff?

9 MR. SCHMIDT: Yes. This is Jeff Schmidt  
10 from the staff. So, you know, Matt kind of laid out  
11 a bunch of conservatisms as he went through there. So  
12 it's things like graphite being a perfect absorber and  
13 then the release fractions from that graphite. Like,  
14 they looked at different diffusivities to maximize  
15 that release. Pebble release fractions were -- I hope  
16 this isn't proprietary -- were near one at those  
17 temperatures. So the mass transport of tritium into  
18 the graphite was a conservative calculation. The fact  
19 that the fuel inventory, nothing was allowed to leak  
20 away while the coolant activity is also at its tech  
21 spec value is a conservatism.

22 So I think it's hard to break out, like,  
23 single -- there are multiple levels of conservatism in  
24 this calculation. And I think a lot of those were  
25 just covered.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. BLEY: Okay. Thanks.

2 CHAIR PETTI: Michelle, do you remember  
3 what isotopes dominated the dose?

4 MS. HART: So from what I remember, it was  
5 mostly tritium and argon.

6 CHAIR PETTI: Okay. That's what I would  
7 have expected. That's what my gut said.

8 MEMBER MARCH-LEUBA: If you went on the  
9 blaming game and you have to blame somebody for how  
10 low these numbers are, would you blame the fact that,  
11 and, by blame, I mean the fact that the various  
12 fractions of TRISO fuel has failed, and the fraction  
13 that has not failed does not raise anything. Is that  
14 why we're getting these ridiculously low numbers with  
15 these conservative assumptions?

16 MS. HART: So I would say it's fair to  
17 state that the TRISO particles are retaining the  
18 majority of the fission products. Flibe does retain  
19 some. Did we look at specific failure fractions and  
20 did they provide sensitivity analysis on that? No,  
21 not at this stage.

22 MEMBER MARCH-LEUBA: What gives me comfort  
23 when I look at this design, it's not that they assume  
24 various fraction of particles that are failed but that  
25 they measure it when they operate by measuring the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 contamination in the activity of the Flibe.

2 MS. HART: Right.

3 MEMBER MARCH-LEUBA: So if we start  
4 operating and suddenly we see a hundred times the  
5 Flibe, we'll stop and we'll figure out what's going  
6 on. So the fact that it's something that we're  
7 measuring and we can know what it is is good.

8 MEMBER KIRCHNER: Jose, this is Walt. If  
9 I could observe, at the time-temperature curve that  
10 they're using for the TRISO fuel, the fuel meets the  
11 spec. You're hardly challenging it. So as I think  
12 Michelle answered, it's going to be tritium and argon  
13 because you're not assuming the actual produced fuel  
14 performs that well. That's the reason why the numbers  
15 are so very, very low.

16 Now, as you said, if they have a batch of  
17 fuel that turns out not to be up to spec, they'll see  
18 it right away in the circulating inventory and in the  
19 cover gas. You'll see that almost instantly if  
20 there's a large, a much larger defect fraction for  
21 kernels and particles that are either defective or  
22 there's tramp uranium outside of the particles.

23 CHAIR PETTI: Those are not the most  
24 difficult QC techniques. If you get bad fuel, you  
25 know it in QC. It's pretty obvious. You know, you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 get zero, and then you get integral, most of the time,  
2 integral measurements of kernels. So, oh, that pebble  
3 has three exposed kernels, that one has none. It's  
4 very clear when you do the test.

5 MEMBER KIRCHNER: On that subject, I guess,  
6 you're more familiar with this. It's been a long time  
7 since I've looked at these equations for the TRISO  
8 particle performance, but I would submit, at these  
9 temperatures, you're not going to see much of an  
10 impact, assuming, again, the fuel meets the spec.

11 CHAIR PETTI: These temperatures are so  
12 much lower than you have in an HTGR that the diffusion  
13 --

14 MEMBER KIRCHNER: From a calculational  
15 standpoint, you're not going to see anything using the  
16 approved equations, methods, for analyzing TRISO  
17 performance.

18 MEMBER MARCH-LEUBA: The dose at the  
19 perimeter of the plant is controlled by your  
20 fabrication. You don't make any mistakes, and that's  
21 easy to quality control. It's reliable.

22 CHAIR PETTI: And the fact that they assume  
23 in-service failure, normal operation failure, a  
24 hundred times with the AGR program demonstration.

25 MEMBER MARCH-LEUBA: It's a good margin,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 but we still haven't operated a reactor. Let's get a  
2 couple of years of running it and see what happens.

3 MS. HART: All right. So the only other  
4 thing I wanted to say about this is, because we did  
5 have this extensive audit, there was no need for me to  
6 do a consequence analysis, a confirmatory analysis.

7 Next slide, please. So our evaluation  
8 findings were that we do find that the MHA serves as  
9 a bounding hypothetical analysis for the Hermes  
10 reactor. The combination of bounding conditions  
11 analyzed are beyond what is assumed for postulated  
12 events. The preliminary dose analysis for the MHA are  
13 subsequently below the regulatory dose reference  
14 values for test reactor siting in 10 CFR 100.11. And  
15 because the assumptions of the MHA are bounding,  
16 calculated doses would likely not be exceeded by any  
17 accident considered credible and the staff will  
18 confirm calculations as part of the OL application  
19 review.

20 Next slide, please. We did have to talk a  
21 little bit about control room habitability. It was  
22 really described in PSAR Section 7.4. They did not  
23 provide a dose analysis or design details for control  
24 room radiological habitability in the PSAR. However,  
25 we expect that they will do some kind of analysis to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 show compliance with PDC-19. They did identify that  
2 as the relevant design basis for control room  
3 habitability design, and an additional description of  
4 the control room habitability design and dose analysis  
5 corresponding to the final design will be provided in  
6 the OL application.

7 MEMBER MARCH-LEUBA: This is Jose. Maybe  
8 because we have such a serious concern about the  
9 assumptions in our numbers, but the release inside the  
10 plant is very large. Everything goes in there. So  
11 habitability with this conservative analysis may be an  
12 issue that you exceed applicable doses. Doses for  
13 tritium are really, really low, and that will apply  
14 mostly to the reactor areas but they move to the  
15 control room, too.

16 MS. HART: Yes, it is certainly something  
17 that we have in our sights to evaluate in the OL  
18 application when we do that in the shielding analysis  
19 and any further --

20 MEMBER MARCH-LEUBA: Yes, the steady state  
21 you can release in the normal operating because the  
22 temperatures are so high that it's going to leak like  
23 a sieve.

24 CHAIR PETTI: But the assumptions that  
25 they've used are very cavalier, shall we say, because

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 it still meets the off-site dose. But when you start  
2 talking about worker safety, they're going to need a  
3 sharper pencil, and I'm sure they will. It will be  
4 clean-up systems. It's probably going to be a very  
5 different sort of look than what you see in the PSAR.

6 MEMBER KIRCHNER: And we talked a little  
7 bit about that at the March meeting, as well.

8 CHAIR PETTI: Yes.

9 MS. HART: Next slide, please. And so, in  
10 conclusion, the NRC staff does find the preliminary  
11 design information and analysis are consistent with  
12 the applicable criteria in NUREG 1537 and that we  
13 conclude that the information on the MHA is sufficient  
14 for the issuance of a CP, and any further information  
15 can be reasonably left for OL application.

16 Are there any further questions?

17 MEMBER KIRCHNER: Michelle, this is Walt  
18 Kirchner. I know we've got the groups of events that  
19 were analyzed as part of Chapter 13 coming next or  
20 coming tomorrow. When you, the staff, went through  
21 the applicant's selection of events that they thought  
22 were limiting, did you flag any in particular that you  
23 would be concerned about and want to go back and re-  
24 examine whether or not they might, any of those  
25 individual events might challenge this MHA assumption?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Because, basically, as we've been discussing, this MHA  
2 doesn't really involve any significant release from  
3 the fuel.

4 MS. HART: Nor does it really look at  
5 oxidation of exposed graphite. We kind of mostly were  
6 thinking about doing comparisons to the salt spill and  
7 the pebble handling system failure. I don't know,  
8 Jeff, if you had some additional thought on that.

9 MR. SCHMIDT: Yes, this is Jeff Schmidt.  
10 I just want to echo what Michelle said. So I did a  
11 lot of the evaluations for what I would call the dose  
12 accidents in Chapter 13 for the postulated events, and  
13 she's right. Those are the ones I kind of were  
14 constantly questioning whether the MHA would bound  
15 those because I really didn't have a great engineering  
16 feel for how much salt is spilled, what's the release  
17 from the salt, what's the aerosol generation from the  
18 salt spill. So, you know, I used some of their  
19 illustrative examples in the appendices of KP-TR-018  
20 to get some sense for it. I asked for some  
21 temperature profiles, what was holding the heat in a  
22 salt spill, how much would I heat up due to a salt  
23 spill accident, for example, to threaten those  
24 temperatures of the MHA.

25 So those are the accidents, the salt spill

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 and the PHHS event, were the ones I kind of focused  
2 on.

3 MEMBER KIRCHNER: Okay. Those are the same  
4 two that I have concerns about, the potential for any  
5 of the pebbles to be exposed in the pebble handling  
6 machine or system. Until we see the detailed design,  
7 it's hard to know where the level will wind up in the  
8 reactor vessel. Certainly, there's discussion from  
9 the applicant of unmitigated air ingress. How much  
10 graphite is exposed is going to be a design detail, I  
11 suspect. Could it result in any of the pebbles being  
12 uncovered by Flibe would be something of concern, as  
13 well.

14 Okay. Thank you.

15 CHAIR PETTI: Any other questions, members?  
16 Okay. Well, we're well ahead of schedule. I just  
17 think we should keep pushing through. Are you ready  
18 to talk about the other part of Chapter 13 today?

19 PARTICIPANT: Yes, we are.

20 CHAIR PETTI: Okay. We can do the break  
21 early. I had it circled at 3:10. It's 2:40. Okay.  
22 Then let's take a break until 3:00, and then we'll  
23 come back and we'll start the other sections. Thank  
24 you.

25 (Whereupon, the above-entitled matter went

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 off the record at 2:41 p.m. and then went back on the  
2 record at 3:00 p.m.)

3 CHAIR PETTI: Okay. We're back and ready  
4 to start with Kairos. Matthew.

5 MR. PEEBLES: This is Drew Peebles, Senior  
6 Licensing Manager. Just before we get started, we  
7 were talking about the exposed kernel fraction. We  
8 did check, and that is marked as proprietary in the  
9 topical report. But in our fuel qualification  
10 methodology topical, KP-TR-011, it's Table 313, if  
11 that helps. But I can say in the public session that  
12 the fraction that we assumed is not less conservative  
13 than the AGR 2 spec.

14 CHAIR PETTI: Okay. Yes, we had a side  
15 discussion and came to the same conclusions. Thanks.

16 MR. PEEBLES: Okay. I'll turn it over to  
17 Matt. Thank you.

18 MR. DENMAN: Okay. Well, thank you. So my  
19 name is Matthew Denman once again, and thank you very  
20 much for the opportunity to talk to you about Chapter  
21 13 accident analysis focusing on postulated events.

22 You will see these next two slides are a  
23 little bit of repeat from what you heard earlier  
24 today. We were expecting to give these tomorrow  
25 morning, and we wanted to provide context again. But

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 just as a refresher, 10 CFR 50.34(a)(4) does require  
2 a preliminary safety analysis to assess the risk of  
3 public health and safety from operations of a  
4 facility, including determination of margins to  
5 safety. I won't go too far into the MHA again, other  
6 than that this is, the MHA is supposed to bound  
7 postulated events and it is analyzed for dose  
8 compliance with 10 CFR 100.11.

9 The list of postulated events are  
10 comprehensive to ensure that any event with a  
11 potential for significant radiological consequences  
12 has been considered. Initiating events and scenarios  
13 are grouped so that the limiting case for each group  
14 can be qualitatively described in the CPA, and  
15 acceptance criteria are provided for important figures  
16 of merit in each postulated event group to ensure that  
17 potential consequences of that event group are bound  
18 by the MHA as the design progresses. Additionally,  
19 prevention of initiators are justified in the PSAR.

20 If we go to the next slide, again, this is  
21 a conceptual slide to show the relationship between  
22 the 100.11(a)(1) and (2) reference values. The MHA  
23 and the potential postulated event doses where the MHA  
24 demonstrates your margin to the reference value and  
25 then the hypothetical natures and assumptions and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 boundary conditions and models within the MHA provide  
2 that stand-off between the MHA doses and the potential  
3 postulated event doses.

4 Next slide. So getting into the postulated  
5 event analysis methodology, postulated events are  
6 identified in Chapter 13 of the PSAR. Postulated  
7 events include any potential upset of plant operations  
8 within the design basis that causes an unplanned  
9 transient to occur. Justification is provided for  
10 those events excluded from the design basis. Figures  
11 of merit are provided or, sorry, figures of merit  
12 provide the means to measure and demonstrate the  
13 resulting doses from postulated events are bound by  
14 the doses of the MHA.

15 The preliminary methods and sample  
16 calculations of postulated event groups are provided  
17 in KP-TR-18, Rev 2. This methodology describes how  
18 analyzed figures of merit for, how the figures of  
19 merit for each postulated group are analyzed and how  
20 acceptance criteria will ensure proper mapping between  
21 the off-site dose consequences of the postulated  
22 events and the MHA which bounds those events.

23 The final safety analysis results will be  
24 provided with the operating license, including  
25 verification and validation of the evaluation models

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 that will be used.

2 So for the next slide, I'm going to  
3 transition to my colleague, Tim. Tim, please  
4 introduce yourself.

5 MR. DRZEWIECKI: Thank you. This is Tim  
6 Drzewiecki. I'm a safety analysis manager here at  
7 Kairos Power. I'm going to spend a few minutes  
8 talking about a postulated event analysis methodology.

9 So we do follow the steps that are outlined  
10 on the in-depth process Reg Guide 1.203. Some of  
11 those elements are discussed in our technical report  
12 KP-TR-18. Postulated events with similar  
13 characteristics are grouped into categories which is  
14 consistent with NUREG 1537. Limiting event in each  
15 category is then identified and, again, qualitatively  
16 assessed from the event initiation until a safe state  
17 is reached. That safe state is defined in the methods  
18 for each event category as the point where the  
19 transient figures of merit have been stabilized in a  
20 safe condition and generally involves things like, you  
21 know, some criticality and decay heat removal.

22 Next slide, please. As far as the inputs  
23 for the postulated events analyses, these are actually  
24 shown in Table 44 of KP-TR-18. There are 15  
25 parameters in total. Some of them are biased in a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 conservative direction. Some are nominal. But  
2 several are also varied over a range, and the bases  
3 for these are described in that table.

4 Again, a range of values are assessed to  
5 identify a limiting scenario for each postulated event  
6 and key modeling uncertainties and initial conditions  
7 are applied to the methods to ensure that the figures  
8 of merit are conservatively predicted. And those  
9 figures of merit again are shown in Table 13.11 of the  
10 PSAR.

11 Next slide, please. So I was going to hit  
12 a couple of events, and then I'm going to just kind of  
13 walk through what a typical event is going to look  
14 like in our reactor. So for the loss of forced  
15 circulation, the limiting event here was a pump  
16 seizure that would disable primary salt pump, and in  
17 that event is we do see is a heat up of the system  
18 which is then detected by the protection system. That  
19 causes a trip early in this event.

20 And then other events that are predicted  
21 here are things like a pump trip or a loss of normal  
22 heat sink. The next category is the insertion of  
23 excess reactivity. This is a control system or  
24 operator error that causes an element to withdraw  
25 continuously at the maximum speed, and this is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 detected by the protection system either by a high  
2 flux or a high temperature. Events that also fall  
3 under this category are errors in fuel loading,  
4 reflector shifting, or venting of gas level. And,  
5 last, a category I'm going to cover on this slide is  
6 general challenges to normal operation. So this would  
7 be any kind of challenge to operation that's not  
8 covered by the other event categories. We think these  
9 are bounded by the loss of poor circulation, and they  
10 include things like spurious trips, operator errors,  
11 and equipment failures.

12 So this next slide, I'm going to walk  
13 through just a loss of forced circulation overheating  
14 event. Now, those images that you see are actually  
15 the same image or at least the image on the right.  
16 That's adapted from a figure from KP-TR-18 just so who  
17 the time scale a little more clearly because the one  
18 on the right goes out to about 72 hours and is on a  
19 standard scale, as opposed to a semi-log scale.

20 So this event starts with a pump seizure or  
21 a locked rotor. We do see the heat-up that occurs in  
22 the first minute of this event at about 30 seconds,  
23 and that would show up, on the left is one of those  
24 peak lines there. We do see a reactor trip. And then  
25 following that, there is a heat-up period in which our

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 decay heat is higher than the heat that's being pulled  
2 out by our DHRS, or decay heat removal system. That  
3 heat-up period lasts for about 20 hours, at which  
4 point the heat removal from decay heat removal system  
5 exceeds our decay heat loads and then we see a  
6 decrease in the system temperature.

7 So if there's no questions, I'll hand it  
8 back to my colleague, Matt.

9 MR. DENMAN: Well, thank you very much,  
10 Tim. So I'm going to cover some of the postulated  
11 events that really involve releases of radioactive  
12 material outside of the vessel.

13 So the first event is the mishandling or  
14 malfunction of the pebble handling and storage system.  
15 The limiting event involves a break in the fuel  
16 transfer line during removal of fuel from the core  
17 that results in a spill of pebbles within the transfer  
18 line into the surrounding room. The reactor  
19 protection system detects this condition and initiates  
20 a trip of the pebble handling and storage system to  
21 prevent additional pebbles from moving into the pebble  
22 transfer line. Grouped events include transfer line  
23 breaks when pebbles are inserted into an empty core,  
24 core at power, storage canisters, and mishandling fuel  
25 outside of the reactor.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1                   MEMBER KIRCHNER: Matthew, this is Walt  
2                   Kirchner. Just quickly, you say the reactor  
3                   protection system detects this condition. What would  
4                   be the sensor for that? Gamma detection?

5                   MR. DENMAN: Pressure.

6                   MEMBER KIRCHNER: Well, you wouldn't detect  
7                   it on neutrons from your core flux monitoring system.  
8                   So is the idea that in the reactor cavity you would  
9                   have a sensor?

10                  MR. DENMAN: So this would be a pressure-  
11                  related trip on the cover gas system.

12                  MEMBER KIRCHNER: Well, it's pretty low  
13                  pressure. Okay. Okay. Thank you.

14                  MR. DENMAN: Okay. I will also note here  
15                  that the pebbles themselves do have a low decay heat  
16                  level and, thus, temperatures will be manageable.

17                  The radioactive release material from a  
18                  subsystem or component, the limiting event is assumed  
19                  to be a seismic event that results in the failure of  
20                  all systems containing radioactive material that are  
21                  not qualified to maintain structural integrity during  
22                  a design basis earthquake. This is effectively a  
23                  common mode failure. Design requirements on the  
24                  amount of MAR for these structure systems and  
25                  components will be set to ensure that the amount of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MAR that could be released is less than the MAR  
2 derived from the maximum hypothetical accident  
3 releases. And grouped events include releases from  
4 the tritium management system, inert gas system,  
5 chemistry control system, and inventory management  
6 systems.

7 Next slide. Salt spills. So in this  
8 scenario, a hypothetical double-ended guillotine break  
9 occurs in the primary heat transport system hot leg  
10 piping. The reactor protection system detects the  
11 salt spill due to a low coolant level and initiates a  
12 reactor trip. The grouped events for this scenario  
13 include spurious draining of the primary heat  
14 transport system, leaks from other Flibe-containing  
15 systems, mechanical impact or collision of Flibe-  
16 bearing structure systems and components, and heat  
17 rejection radiator tube breaks.

18 Finally, internal and external hazards are  
19 considered. These include internal fires, internal  
20 water flood, seismic events, high wind, toxic  
21 releases, mechanical impacts or collisions, structure  
22 systems and components, and external floods as  
23 described in Chapter 2 of the PSAR. Events in this  
24 category are bound or considered as initiators to  
25 other event categories. A good example of this is the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 release of radioactive material from subsystems or  
2 components that I talked about on the previous slide  
3 where an external hazard provides that common mode for  
4 release pathway for all of those.

5 So in conclusion, postulated events within  
6 the design basis are identified and grouped by  
7 characteristics and modeling approaches used to  
8 evaluate these postulated events. Design features  
9 which are credited with mitigating the effects of  
10 postulated events are described. Figures of merit are  
11 derived for the postulated events to provide surrogate  
12 metrics which demonstrate that the resulting doses are  
13 bound by the dose consequences of the maximum  
14 hypothetical accident analysis. The acceptance  
15 criteria for these figures of merit represent design  
16 limits that ensure that the MHA will remain bounding.

17 And with that, I appreciate the ACRS for  
18 their attention and questions. And thank you.

19 CHAIR PETTI: Matt, I had a question. It  
20 wasn't clear to me in some of the events whether the  
21 single failure criteria is applied or even has to be  
22 applied in these events, particularly in core sort of  
23 events.

24 MR. DRZEWIECKI: Yes, Dave, this is Tim  
25 Drzewiecki. And, yes, we do apply single failure

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 criteria. We do, you know, account for a stuck rod,  
2 as well. The single failure is generally associated  
3 with our decay heat removal system. That's generally  
4 seen to be our limiting single failure.

5 CHAIR PETTI: But let's look at the  
6 reactivity event. Is there a delayed detection? You  
7 say that the high flux is out, but then the higher  
8 power gets you, shuts it down? What's the timing  
9 there?

10 MR. DRZEWIECKI: The timing. So in terms,  
11 those specific, you know, like, details, in terms of  
12 what trip would come in then, those would have to be,  
13 you know, looked at. But the one thing I do want to  
14 highlight is in terms of our, you know, RPS is  
15 designed to, you know, be single failure-proof or to  
16 actually handle single failures. You know, that's  
17 accordance with the standard that it's designed to.

18 CHAIR PETTI: So you think that the event  
19 that's modeled in the appendix of the technical report  
20 is still fairly reasonable once you get the final  
21 design details? You're not going to see a greater  
22 response, if you will.

23 MR. DRZEWIECKI: I can't speak to that  
24 because our methods are still being developed. You  
25 know, those calculations were based on preliminary

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 design information, so I think it's representative of  
2 what we're going to see. But I can't say that it's  
3 bounding. There are things in there that are very  
4 conservative. For example, reactivity insertion.  
5 Those are very conservative, so it could be bounding  
6 but I can't commit to that.

7 MEMBER HALNON: This is Greg. Pardon me if  
8 we've talked about this. The occupational dose with  
9 the RBHVAC, I assume that you're assuming that, since  
10 it's non-safety, it's essentially not there. Is that  
11 another analysis another time, or is it factored into  
12 this MHA?

13 MR. DENMAN: So occupational dose  
14 evaluation will be provided at the OL.

15 MEMBER HALNON: And just surmising that  
16 this MHA is going to exceed any occupational dose  
17 allowables, what happens then? Do you have to come  
18 back and re-look at the MHA, or do you have to design  
19 something into the RBHVAC to control the environment  
20 better?

21 MR. DENMAN: The MHA is intended to analyze  
22 off-site doses, not occupational doses.

23 MEMBER HALNON: Okay. So that will be,  
24 this will be unaffected by any inside dose, if you  
25 will.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. DENMAN: Correct.

2 MEMBER HALNON: Okay.

3 CHAIR PETTI: Any other questions, members?

4 MEMBER REMPE: To follow up, on page 47 out  
5 of 99, you talk about the spilled pebbles, and you say  
6 since the temperatures are high they'll react with the  
7 air in the building to generate heat because it's an  
8 exothermic reaction, and I just wondered do you know  
9 what temperature they're at?

10 MR. DENMAN: Thank you very much for that  
11 question. So the pebbles are, by the time they  
12 actually make it out of the core and make it into the  
13 cover gas space above the Flibe free surface, they're  
14 going to be very, very, very close to the cover gas  
15 temperature because the decay heat is so low and the  
16 pebbles are fairly small. As they move through the  
17 pebble handling and storage system, that trend is  
18 going not follow. So as you get the temperatures in  
19 the pebble transfer line, the temperatures of the  
20 pebbles are going to start to decrease. And then in  
21 a spill event, they're assumed to still be above the  
22 400 C oxidation threshold temperature, but it's not  
23 expected to be a rapid process, nor at a process where  
24 you're likely going to see exothermic temperatures.  
25 It will likely be endothermic. But, again, these are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 all preliminary design information feeding into these  
2 temperatures, and we'll have to look to OL to know for  
3 sure and we will be ready to evaluate any condition  
4 that we find.

5 MEMBER REMPE: So I think the answer is  
6 that you're not exactly sure because you're modeling  
7 hasn't progressed that far, right, is what the answer  
8 is? Because I didn't hear a temperature really coming  
9 out.

10 MR. DENMAN: Yes. So --

11 MEMBER REMPE: Okay. Thank you.

12 MR. DENMAN: Okay.

13 CHAIR PETTI: Okay. Hearing no more  
14 comments, let's move to the staff. Jeff?

15 MR. SCHMIDT: Jeff Schmidt with staff.  
16 I'll wait for my slides.

17 Okay. So we're going to talk about the  
18 same things that Kairos just got done talking about,  
19 postulated events in other sections.

20 Next slide, please.

21 Kairos, as we talked about, uses the MHA.  
22 The MHA is supposed to bound the radiological release,  
23 and there has been some reference to this PSAR Table  
24 13.1-1, which I think is worth bringing up again,  
25 because what that table is trying to communicate is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 that different events have different release pathways,  
2 and you've got to control some of the variables or the  
3 figures of merit in the table to ensure that the MHA  
4 remains bounding.

5 I think we've said that multiple times, but  
6 it's important to understand what the -- what the  
7 purpose of that table is.

8 Postulated events considered are consistent  
9 with those listed in 1537, as Tim just said. Though  
10 there were some technology-specific events or event  
11 sequences that are precluded by design, we'll talk  
12 about two that the staff had additional questions on.

13 And, obviously, we've talked about these in  
14 previous meetings. The Flibe interaction with water  
15 or concrete are precluded by design, and that's listed  
16 in that PSAR section.

17 Some technology-specific events such as  
18 increased pebble packing fraction and the potential  
19 reactivity insertion due to that have been evaluated,  
20 at least to the design information available.

21 Next slide, please.

22 As we talked about, the postulated event  
23 methodologies in KPTR-018 Rev 2. As Tim mentioned  
24 also, KPTR-018 Table 4 has input parameters, which  
25 kind of outline the overall methodology that's going

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 to be applied to the postulated events. It covers  
2 things like initial power level, reactor coolant  
3 temperatures.

4 We spent some time with Kairos flushing out  
5 the details of that to ensure it was a very I think  
6 thorough and consistent overall calculational  
7 framework, relatively along the lines of, let's say,  
8 like a NUREG-0800 Chapter 15 analysis.

9 FSAR analyses will consider the full range  
10 of sensitivities based on the Table 4-4. KP-SAM and  
11 KP-BISON have the capability to model postulated  
12 events, corresponding fuel releases. We talked a  
13 little bit about that in our previous meeting and the  
14 capability of those codes. Just to remind everybody,  
15 code verification and validation will be reviewed  
16 prior to or as part of the OL application.

17 Next slide, please.

18 So I'm going to walk through each one of  
19 the events kind of the way they're listed, the way --  
20 I'm sorry, the way they're listed in the -- in the  
21 PSAR. So the first one is insertion of excess  
22 reactivity. Seems to continuously draw the highest  
23 worth control rod at the maximum speed. Reactor trips  
24 on high power or high temperature. Range of  
25 reactivity insertion rates and initial core power

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 levels will be evaluated at the OL.

2 So right now they've done the max -- like  
3 a maximum reactivity insertion, but usually you look  
4 at a different range of insertions because different  
5 trips will pick up different reactivity insertion  
6 rates.

7 Uncertainties will be quantified as part of  
8 the OL application. Internal element injection is  
9 precluded due to the low differential pressure between  
10 the reactor and atmosphere, so that's a consideration  
11 in, you know, what the events are for -- that are  
12 considered as part of insertion of excess reactivity.

13 Temperatures stay below the MHA,  
14 hypothetical temperature versus time curve, except for  
15 the maximum reflector temperature, which slightly  
16 exceeds the MHA-free surface and graphite temperature  
17 limits for a short period of time.

18 Again, you know, it's important to stress  
19 that these are preliminary calculations. At short  
20 deviation was considered by the staff in that review  
21 and thought to -- that the MHA was still going to be  
22 bounding because it's a fairly short duration and a  
23 relatively small deviation from the acceptance line.

24 Staff scoping analysis yielded similar  
25 results, as we show in the following slides. So we're

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 going to have -- at the end of this presentation,  
2 we're going to go through some of the scoping analyses  
3 that were performed by the staff, and basically go  
4 through a comparison of their calculations to our  
5 calculations. Andy Bielen will be handling that.

6 The staff has reasonable assurance that the  
7 MHA dose bounds that of the insertion of excess  
8 reactivity because of conservatisms in the MHA  
9 analysis. As we talked about, there's a number of  
10 conservatisms in the MHA analysis. There is no real  
11 separate or different pathway to exposure here, say  
12 like for the pebble handling system or the salt  
13 system. So that was how we reached the conclusion  
14 that the MHA was going to be bounding, just based on  
15 the temperature profile that's used as part of the  
16 MHA.

17 Next slide, please?

18 So the salt spill is the next postulated  
19 event. This is a loss of coolant inventory resulting  
20 in different release pathways in the MHA. As was  
21 stated earlier, some safety-related systems work as  
22 intended, assumes water or concrete interactions are  
23 precluded by design. That's really referring to, you  
24 know, the -- where the salt is spilled.

25 Methodology includes evaluating a range of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 break sizes and locations as part of the calculational  
2 framework. As Matt described, their day-to-day,  
3 double-ended guillotine break of the hot leg.

4 Release pathways, different from the MHA,  
5 include radionuclide by the break, evaporation from  
6 the spilled fuel pool, and oxidation of any exposed  
7 graphite. And we've talked a little bit about that as  
8 -- you know, right now we have preliminary estimates  
9 of like the amount of salt spilled, but how much  
10 graphite that is exposed during that transient the  
11 staff is not sure of yet.

12 But that's one of the figures of merit that  
13 has to be controlled, is that, you know, you have to  
14 limit the oxidation such that, you know, oxidation  
15 doesn't release or doesn't lead to, you know,  
16 contributing to a release that's greater than the MHA.

17 Heat-up due to loss of inventory is  
18 expected to be low. The staff asked for some  
19 information on that during the audit, and bounded by  
20 the MHA versus -- time versus temperature curve. So  
21 the massive salt spilled, at least preliminary, is  
22 fairly low to the total mass of the system. And a lot  
23 of the heat of the system is tied up in the graphite,  
24 so you would expect that the temperature increase due  
25 to the -- to the loss of salt is pretty low.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 MR. HALNON: How does it get out into the  
2 environment? It just infiltrates through the  
3 building, or is there --

4 MR. SCHMIDT: Yeah. It just -- it spills  
5 into an apartment or building and that just --

6 MR. HALNON: Is there any difference if the  
7 RBHKC continues to operate and sucks it out and pushes  
8 it out through --

9 MR. SCHMIDT: No.

10 MR. HALNON: -- point?

11 MR. SCHMIDT: No. We didn't look at that.  
12 This just goes -- just goes into the reactor building  
13 and out, part of that process, but --

14 MR. HALNON: Okay. Is that not a concern,  
15 then, that it could be funneled and dragged out by an  
16 operating fan and pushed out into -- with some  
17 velocity?

18 MR. SCHMIDT: Yeah. That would -- I guess  
19 that would have to be looked at as part of that. Its  
20 failure -- I mean, that's a control system that would  
21 lead potentially to a worse answer. But right now  
22 these are more, I would think, qualitative evaluation  
23 and not to that level of detail.

24 MR. HALNON: Okay.

25 MR. SCHMIDT: Methodologies for break air

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 salt generation and Flibe, vessel-free surface  
2 evaporation. Methodologies are from the approved  
3 mechanistic source term topical report. Salt spill  
4 uses lower event-specific temperatures and, hence,  
5 lower fuel wetted graphite surface, tritium, and lower  
6 Flibe vessel preservice temperatures. That's just  
7 basically saying that the MHA temperatures are  
8 bounding this event.

9 Staff has reasonable assurance that the MHA  
10 would bound a salt spill based on the minimal heat-up  
11 in the low salt mass spilled. Quantitative dose  
12 assessment comparison between the salt spill and the  
13 MHA will be performed as part of the OL application.

14 Next slide?

15 The next event is loss of poor circulation.  
16 This, as Tim pointed out, is seizure of the primary  
17 salt pump, reactor trips on high outlook temperature,  
18 uncertainties as -- with most of these accidents will  
19 be quantified as part of the OL application.

20 Again, temperatures stay below the assumed  
21 MHA, hypothetical time or temperature versus time  
22 curve, except for the maximum reflector temperature  
23 and upper plenum temperature, which slightly exceed  
24 the free surface and graphite temperature limits for  
25 a short period of time. The same argument goes again.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           The staff looked at some of the  
2 conservatisms that are in these calculations, and  
3 there are some significant conservatisms in these  
4 calculations that could be refined such that, you  
5 know, there is at least reasonable assurance that some  
6 of these values could be brought down. But we'll --  
7 that will be determined as part of the OL.

8           Staffing scoping analysis, again, we did  
9 this event as well. It yielded similar results, as  
10 Andy will go through in the following slides. Staff  
11 has reasonable assurance the MHA does balance that --  
12 balance that of the loss of poor circulation. Again,  
13 this isn't really a different release path than the  
14 MHA with effectively lower temperatures.

15           Next slide?

16           The pebble handling and storage system  
17 event, as was described as a break in the pebble  
18 handling system, it does have different release  
19 pathways. Reactor protection system trips to stop the  
20 pebble movement, as was described. Pebbles spill onto  
21 the transfer room, and no active heat removal is  
22 credited to limit the spilled pebbles temperature.

23           And I believe in the -- either the last  
24 figure or the second-to-last figure in APTR-018 has  
25 what the temperatures are for the pebbles. So that is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 available. And I can't remember -- it's one of the  
2 last figures in their illustrative examples for salt  
3 spill.

4 Release pathways, different from the MHAs.  
5 We've talked about this is basically the mobilized  
6 graphite dust that could come out as part -- that  
7 accumulated in the pebble handling system and then is  
8 expelled from the break, and then the pebble oxidation  
9 -- as Dr. Kirchner was talking about, there's  
10 assumption of spilled pebbles, and then any pebbles  
11 that remain in the pebble handling system that may be  
12 exposed to air.

13 We've had significant discussion with them  
14 to include -- make sure that all of those pebbles were  
15 included in the analysis, or will be included in the  
16 analysis, I should say.

17 MEMBER REMPE: So I see the temperature  
18 curve. Thank you. And it starts at xxx, and it just  
19 drops down. So I'm guessing they don't consider  
20 exothermic reactions if they start at xxx and they  
21 have --

22 MR. SCHMIDT: Yeah. I think it stated  
23 regime 1, if I remember correctly.

24 MEMBER REMPE: But I would think that you  
25 would have some exothermic reactions.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. SCHMIDT: It's very -- the oxidation at  
2 those temperatures is fairly low.

3 CHAIR PETTI: Yeah. But notice -- this is  
4 proprietary. We have to be careful.

5 MEMBER REMPE: Yeah. But I didn't say a  
6 number. I just said it's going down. I mean, it's

7 CHAIR PETTI: No. You did mention a  
8 number. You didn't mention what temperature scale, so  
9 you're okay.

10 MEMBER REMPE: Okay.

11 CHAIR PETTI: But if you notice that  
12 temperature scale, that's very low.

13 MEMBER REMPE: I've got documents that say  
14 anytime you're above 500C that you can have oxidation.

15 CHAIR PETTI: Oh, you can -- oh, for sure  
16 you can have oxidation.

17 MEMBER REMPE: Yeah.

18 CHAIR PETTI: But it's --

19 MEMBER REMPE: Yeah.

20 CHAIR PETTI: -- how much.

21 MEMBER REMPE: How much, but it can be  
22 exothermic, too, is what I --

23 CHAIR PETTI: Well, it's always exothermic.

24 MEMBER REMPE: Right. So then does this  
25 fit your --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 CHAIR PETTI: But there's a huge amount of

2 MEMBER REMPE: Yes. Again, we --

3 CHAIR PETTI: You'll see --

4 MEMBER REMPE: -- do you know if their  
5 models considered the --

6 MR. SCHMIDT: There is an oxidation  
7 correlation that's used, and I did look at it. I'm  
8 not sure I remember it off the top of my head, but,  
9 yeah, there is an oxidation model. Yeah.

10 MEMBER REMPE: And it considers the --

11 MR. SCHMIDT: It was an oxidation model  
12 based on -- the Chinese had done a pebble matrix.  
13 They created an A3-3-type pebble, and they had  
14 developed a correlation that Kairos is referencing.

15 CHAIR PETTI: The U.S. has also done  
16 measurements of matrix material. It's in the  
17 literature.

18 MR. SCHMIDT: I was just referring to the  
19 ones that they referenced.

20 CHAIR PETTI: Yeah.

21 MR. SCHMIDT: It seemed like an appropriate  
22 reference over the appropriate temperature.

23 MEMBER REMPE: And so they are considering  
24 the heat input from that oxidation?

25 MR. SCHMIDT: The correlation is developed

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 on basically mass loss. So whatever happens happens.

2 MEMBER REMPE: Okay. And then what about  
3 the reflector surfaces, too, within a system and that  
4 oxidation?

5 MR. SCHMIDT: That I think is part of the  
6 graphite topical report, and the oxidation rate of the  
7 graphite material is different than the ones I'm  
8 referring to for the pebbles.

9 MEMBER REMPE: Okay. So, anyway, it's just  
10 something that I thought --

11 MR. SCHMIDT: It's picked up in the  
12 graphite --

13 MEMBER REMPE: -- and that -- again, the  
14 answer may be there is not much combustible gas  
15 generated, but I just --

16 MR. SCHMIDT: Yeah.

17 MEMBER REMPE: -- didn't see those words  
18 anymore.

19 MR. SCHMIDT: You know, on this break, you  
20 know, I don't -- I don't personally have a good handle  
21 on how much structural graphite is exposed in this  
22 type of --

23 CHAIR PETTI: Well, you should -- you  
24 should look two figures earlier. There is the actual  
25 oxidation.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER REMPE: Okay. I see that.

2 CHAIR PETTI: So they are actually doing  
3 that.

4 MEMBER REMPE: And is this for the pebbles,  
5 or is this for -- so I'd have to go back and

6 CHAIR PETTI: This is for this accident,  
7 pebble handling.

8 MEMBER REMPE: -- pebbles. But this isn't  
9 the --

10 CHAIR PETTI: This could be for the  
11 pebbles.

12 MEMBER REMPE: -- reflectors, though. This  
13 is just the --

14 CHAIR PETTI: This is for pebble handling.

15 MEMBER REMPE: Just -- okay. But there is  
16 also --

17 CHAIR PETTI: In the pebble handling event

18 MEMBER REMPE: Okay.

19 CHAIR PETTI: -- the pebbles that spill on  
20 the floor.

21 MEMBER REMPE: Okay.

22 MR. SCHMIDT: Yeah. So, and the spilled  
23 pebbles are assumed to be at their maximum burn up,  
24 and, hence, maximum material at risk for the oxidation  
25 calculation, and then the dust activation uses the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 same assumptions.

2 Next slide?

3 Is that -- oh, yeah. I'm just basically  
4 saying I reviewed the pebble matrix oxidation and dust  
5 generation calculations, or methodologies to be more  
6 appropriate. The methodologies, I get those.

7 Fuel qualification topical report, so this  
8 is an important tieback to the fuel qualification  
9 topical report. You know, they're going to do tests  
10 for their own specific pebble matrix material, and  
11 that will inform how these calculations are done as  
12 part of the OL, right?

13 So right now they're using this surrogate  
14 A3-A that the Chinese had developed, but they're going  
15 to do their own testing to come up with their own, to  
16 see if that correlation is either still valid or needs  
17 a different correlation.

18 And, again, another tieback to the fuel  
19 qualification topical report, pebble wear will also be  
20 looked at, right? There's an assumption of the wear  
21 rate of these pebbles to generate that dust, right,  
22 that's expelled as part of the pebble handling. And  
23 I'm just referring back to they are doing tests to try  
24 to, you know, quantify that dust generation rate.

25 And, again, the dust generation

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 resuspension from the break is already discussed and  
2 approved in the mechanistic source from topical  
3 report.

4 PHS event uses lower temperatures. Again,  
5 I don't expect this to be really a temperature-driven  
6 event. The loss of mass is expected to be low. The  
7 salt, hence lower fuel wetted graphite surface  
8 temperatures with lower tritium releases, lower Flibe,  
9 vessel-free surface releases.

10 So, again, the concept is that the MHA  
11 temperatures will easily bound the PHSS, but you have  
12 to pick up these other figures of merit that have to  
13 do with dust and oxidation.

14 A quantitative dose comparison between the  
15 PHS event and the MHA will be performed at the OL  
16 application. These will be specifically compared at  
17 the OL application -- as part of the OL application.

18 Next slide?

19 This is a fairly simple thing that Matt was  
20 discussing from Kairos. So this is a radioactive  
21 release from a subsystem or component. The short  
22 answer is that the materials at risk have to be  
23 limited such that if there was, say, a single event,  
24 say, speculated seismic event, that the non-protected  
25 structures or non-safety-related structures, I should

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 say, will release, but that will still be bounded by  
2 the MHA based on the quantities of material at risk in  
3 these areas.

4 Next slide?

5 So general challenges to normal operation,  
6 as was discussed, are caused by inadvertent operator  
7 action, failure of a control system or  
8 instrumentation. The reactor protection system will  
9 sense to terminate the event, assuming setpoints are  
10 reached. Events caused by operator action, control  
11 system, instrument failures, are typically bounded by  
12 events analyzed in Chapter 13 due to the use of  
13 bounding assumptions and analyses.

14 Consequences caused by inadvertent operator  
15 action, control system, or instrument failure will be  
16 reviewed in more detail as part of the OL application.

17 Next slide?

18 Internal or external events. Again, these  
19 are -- typically limiting internal events are  
20 primarily just by Chapter 13. Kind of an aside to  
21 that is the fire protection, which isn't really  
22 addressed by Chapter 13. Programs are addressed as  
23 part of PSAR Section 9.4 and will protect safety-  
24 related systems that perform event mitigation  
25 function.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           Most external events are addressed by  
2 designing SSCs commensurate with the hazard of the  
3 applicable standard. Seismic-induced reactivity event  
4 due to unique -- that's unique to the pebble bed, this  
5 was kind of a -- this is a different, you know,  
6 technology-specific accident that's, you know, driven  
7 by an external hazard being a seismic event.

8           So there was -- Kairos did look at some of  
9 the increase in pebble -- pebble packing fraction,  
10 sorry, and associated reactivity increase. As we'll  
11 discuss probably in the excess reactivity, this will  
12 be I think easily bounded by the insertion of excess  
13 reactivity event.

14           They did look at the change in moderation  
15 near the reflector where it's a positive reactivity,  
16 and then a corresponding negative reactivity insertion  
17 towards the middle of the pebble bed. No final  
18 numbers were generated, but there is a release  
19 reported in the -- in the technical report.

20           But -- so there is a plus and a minus  
21 component associated with this packing fraction  
22 increase. I did a little research as far as relative  
23 to high-temperature gas reactors, especially the  
24 Chinese -- I think it's H-10, HT-10.

25           CHAIR PETTI: HRT-10.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. SCHMIDT: HTR-10. Thank you. And one  
2 of the -- you know, one of the reactivity increases  
3 that you don't expect to see in this type of positive  
4 buoyancy bed is slumping of the core relative to, say,  
5 control rod insertion. Right? So if you were to  
6 repack this thing, you would expect that since it's  
7 positively buoyant to actually pack towards the top of  
8 the core and not slumped towards the bottom.

9 So you're going to be moving the core  
10 effectively in the direction of the control rods. You  
11 know, there's a pretty big reactivity insertion  
12 potentially, depending on where your rods are inserted  
13 in a high-temperature gas reactor because the pebble  
14 bed will slump on an increase in peaking factor, and  
15 you'll effectively have less rod insertion as part of  
16 that.

17 So there's like a two-part reactivity  
18 insertion, one due to the slumping, due to the  
19 increased packing fraction.

20 So that -- that situation should not occur  
21 in the Kairos design. Therefore, I expect that the  
22 excess reactivity event, which we'll talk about in  
23 detail when we get to the following slides, will bound  
24 this basic --

25 MEMBER MARCH-LEUBA: Do you have any idea

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 what the packing fraction is? Was it the maximum  
2 theoretical -- is it 0.1 percent, or is it 10 percent?

3 MR. SCHMIDT: Do you mean as far as --

4 MEMBER MARCH-LEUBA: With respect to the  
5 with respect to the maximum theoretical you can put  
6 the bolts on?

7 MR. SCHMIDT: So I want to say it's like 60  
8 percent of .6 is -- is the number that I'm recalling.  
9 But I'm not 100 percent sure on that.

10 MEMBER KIRCHNER: That's about right, Jeff.  
11 This is Walt. Yeah.

12 MR. SCHMIDT: Okay.

13 MEMBER KIRCHNER: For a static pebble bed  
14 reactor, that's about it. It depends also on the  
15 diameter, because you have --

16 MR. SCHMIDT: Right.

17 MEMBER KIRCHNER: -- the edge effects on  
18 the density of pebbles.

19 MEMBER MARCH-LEUBA: I'm not asking about  
20 how much space there is for the Flibe. I'm saying  
21 what you are talking about actually when you shake it  
22 during the --

23 MR. SCHMIDT: Oh. How much --

24 MEMBER MARCH-LEUBA: -- and it compresses,  
25 are you going to get more?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. SCHMIDT: Right.

2 MEMBER MARCH-LEUBA: So what this -- with  
3 respect to the maximum theoretical you could have  
4 spheres.

5 MR. SCHMIDT: I don't remember that number.  
6 I think it was actually in the article I read for a  
7 high-temperature gas reactor, but I don't recall it.  
8 And I don't know if I thought it was --

9 MEMBER MARCH-LEUBA: Because you --

10 MR. SCHMIDT: -- overly applicable to this.

11 MEMBER MARCH-LEUBA: -- you need the number  
12 to know what the --

13 MR. SCHMIDT: Yeah, yeah. You do. You do.  
14 You're right. You know, this -- like I said, I expect  
15 the bed to actually move up, and it will densify to  
16 some amount.

17 MEMBER MARCH-LEUBA: Because I --

18 MR. SCHMIDT: Yeah. Due to the shaking.

19 CHAIR PETTI: If it's the paper I think you  
20 read, because there aren't that many out there --

21 MR. SCHMIDT: Yeah. No, it was hard to  
22 find.

23 CHAIR PETTI: -- it was done by people I  
24 know. I think they went -- they assumed it went to  
25 maximum packing, which Ron says is .72.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. SCHMIDT: Yeah. So that does seem --  
2 that sounds familiar, the .72. But I'm --

3 MEMBER MARCH-LEUBA: .72 is the maximum  
4 packing. So what is the normal operating --

5 MR. SCHMIDT: .6 roughly I think is --

6 MEMBER MARCH-LEUBA: Okay. So --

7 MEMBER BALLINGER: Basically, it's .74.

8 MR. SCHMIDT: .74, okay.

9 MEMBER MARCH-LEUBA: You just calculated  
10 it?

11 (Off mic comment.)

12 MEMBER MARCH-LEUBA: So you calculated from  
13 .6 to .7, so that's -- that's not the packing.

14 MR. SCHMIDT: Yeah. Again, I think we're  
15 going to have -- my last bullet there is we're going  
16 to have to look at this in detail at the OL. So I  
17 think this will be one thing that will be revisited.  
18 I was just looking for information that I could use  
19 for a reasonable assurance finding that excess  
20 reactivity would bound this event.

21 MEMBER MARCH-LEUBA: Just go with the  
22 binding, the earthquakes takes it to the maximum  
23 theoretical.

24 MR. SCHMIDT: Right.

25 MEMBER MARCH-LEUBA: And you just need to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 know what the normal is.

2 MR. SCHMIDT: Right. Right. But there is  
3 -- yeah, right. You could do that, but there is  
4 actually a negative reactivity insertion --

5 MEMBER MARCH-LEUBA: Into the control --

6 MR. SCHMIDT: -- due to Flibe -- well, the  
7 Flibe -- let's just also -- the bed moving up relative  
8 to the control rods, but you could also assume that  
9 the controls rods are not -- that you're fully  
10 withdrawn.

11 MEMBER MARCH-LEUBA: That's a good, handy  
12 theoretical approach.

13 MR. SCHMIDT: Yeah. I think we'll address  
14 that as part of the OL. How about that?

15 All right. Next slide, please.

16 Okay. So this is an area of -- so it's  
17 prevented events, so these are events that are not  
18 analyzed as part of the PSAR, and I'm going to --  
19 there is a list in this PSAR Section 13.1.10. I'm not  
20 going to go -- I didn't -- I'm not going to go through  
21 all of the prevented events, but I will highlight two  
22 that I thought were the most significant that the  
23 staff passed RAIs on.

24 The first one was RAI-348, asks the basis  
25 of why recriticality or unprotected events are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 excluded from consideration. Kairos modified -- in  
2 response to that RAI, Kairos modified PSAR Section  
3 4.2.2.3 to further describe the shutdown element  
4 testing to ensure the shutdown margin analysis remains  
5 valid, and in part lower the probability of an  
6 unprotected event.

7 So, as you recall from our previous  
8 discussions, the shutdown rods go into the pebble bed.  
9 So the staff was concerned that -- didn't have a lot  
10 of experience, the insertion of rods into the pebble  
11 bed and that they would sufficiently go in to both  
12 meet the shutdown margin assumption and actually go  
13 into the core enough to prevent the unprotected event.

14 So staff asked that -- what type of  
15 qualification testing was going to be performed to  
16 ensure that those two items were met, and Kairos  
17 modified the PSAR section to address that.

18 The main thing the staff wanted to get out  
19 of that is to ensure that if you were to insert all of  
20 the control rods, would they successfully go into the  
21 pebble bed to a sufficient depth to ensure shutdown  
22 margin and prevent recriticality, because, you know,  
23 as you cool down, right, you're going to add positive  
24 reactivity to the system again, and you have to have  
25 enough excess reactivity to maintain shutdown. And

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 the other one was just to ensure that you didn't have  
2 an unprotected event from a mechanical-induced  
3 mechanism.

4 And then RAI-350 asked in part how  
5 component integrity is ensured for the duration of an  
6 air ingress event, including air ingress beyond the  
7 heat rejection blower trip, and that was addressed in  
8 SE Section 5.1.3.2.6, addresses the material  
9 qualification testing after seven days.

10 And then there was discussion beyond what  
11 happened -- what happens beyond seven days, and could  
12 this system be placed in a safe state, because the air  
13 for the air ingress event could -- might proceed  
14 beyond seven days.

15 In the discussions with the Applicant, the  
16 staff reached reasonable assurance finding that the  
17 reactor could be placed in a safe state, protect  
18 public health and safety.

19 And so now I'm going to turn it over to  
20 Andy Bielen in Research, and he is going to go through  
21 some of the scoping analysis.

22 MR. BIELEN: Hello? Can you hear me?

23 MR. SCHMIDT: Yeah, we can hear you.

24 MR. BIELEN: Okay. I'm going to make you  
25 look at my face, because I did put on a jacket.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 (Laughter.)

2 MR. BIELEN: Okay. So, yes, I'm Andy  
3 Bielen. I'm in the Fuel and Source Term Branch of the  
4 Office of Nuclear Regulatory Research. At DANU's  
5 request we performed a series of scoping calculations  
6 for the PSAR review.

7 So first I want to remind you that as part  
8 of our non-LWR RADIS plan we have been over the last  
9 several years doing some public demonstrations and  
10 workshops of our ability to simulate the relevant  
11 phenomena and characteristics of non-LWR systems.  
12 Specifically, Volume 3 covers severe accidents and  
13 source term analyses.

14 Within that suite of models that we've  
15 developed is included the UC Berkeley Mark 1 design  
16 which represents TRISO Pebble Fuel Molten Salt Cooled  
17 FHR technology. Oak Ridge National Laboratory uses  
18 scale suite to generate inventory and reactor physics  
19 data, among other things, which is then provided to  
20 the MELCOR severe accident source term code that  
21 Sandia develops so we could model different accident  
22 progressions.

23 Next slide, please. So it's nice that we  
24 did these workshops for the past few years because  
25 when DANU actually had an application in hand, they

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 asked us if we could provide any support, and we were  
2 able to really go in and do some modifications to our  
3 existing models to make it look more like Hermes and  
4 then run some analyses that I think they found to be  
5 useful in informing their engineering judgment.

6 One of the things I want to kind of point  
7 out here is, as I mentioned, the original  
8 demonstration workshops were very much in the severe  
9 accident source term regime. We focused on the UCB  
10 Mark 1 design as we understood it. We focused on  
11 fission product release from the TRISO and into the  
12 buildings and all these other sorts of things.

13 The focus was on beyond-design basis  
14 events. We were explicitly doing elemental tracking,  
15 radioisotopes and that sort of thing to figure out if  
16 something went very, very, very wrong, where would all  
17 this stuff end up.

18 In contrast to that, with respect to  
19 Hermes, we were asked to do this. We were asked to  
20 basically provide an independent verification of some  
21 of the specific event evaluations that Kairos had  
22 presented to ensure that the temperature stayed within  
23 the MHA envelope that they've been describing over the  
24 last few hours.

25 We wanted to do this with a very quick

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1       turnaround to support the licensing schedule. We  
2       wanted to keep this as quick and transparent as  
3       possible. All of our information in the models was  
4       informed by the PSAR information that was readily  
5       available, or in the absence of specifics, engineering  
6       judgment to the best that we could.

7               As I said, and as described in our meeting  
8       back in March, we use scale to generate inventory,  
9       decay heat, power shapes, and all these sorts of  
10      things. Then we analyzed two classes of transients  
11      from the Safety Analysis Technical Report.  
12      Specifically, the insertion of excess radioactivity  
13      scenario, and then a couple flavors of loss of for  
14      circulation.

15             Okay. So to kind of walk through the  
16      MELCOR modeling approach. So as you know, and you've  
17      heard many, many times over the course of these  
18      meetings, we are very much in preliminary space here  
19      so we don't have a whole lot of detail design  
20      information available to us.

21             We have focused our modeling efforts on  
22      what we know in the primary system. The intermediate  
23      loop and the DHRS are both represented basically by  
24      boundary conditions at this point. We just don't have  
25      any better information to build models based off of.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           In fact, some of the flow geometry and  
2 structures at the top of the core specifically. I  
3 don't think we have enough detailed information to  
4 really know how everything is specifically arranged,  
5 but we think we know enough to generate models that  
6 can come to meaningful conclusions.

7           The pebble bed itself is modeled via porous  
8 media approach. We have made the geometry and the  
9 nodalization between the scale models and the MELCOR  
10 models be consistent in order to simplify the mapping  
11 process.

12           The reflector itself, I'll say that I think  
13 it was judged that we just didn't have enough  
14 information about what the flow splits looked like,  
15 what was bypass, what was active core, so we just  
16 neglected to model bypass at this stage. I think that  
17 would be something that we would definitely revisit  
18 when more detail was available.

19           Is there anything else I wanted to make  
20 sure to mention at this point? I think that's pretty  
21 much it. Again, the reflector, I think, that's  
22 another thing where we don't have a whole lot of  
23 specifics on what this thing looks like yet. It was  
24 modeled approximately within the uncertainties that we  
25 -- within the information we had available, but we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 would certainly like to sharpen out pencils as far as  
2 that goes.

3 One more point. Since the fluidic diodes  
4 were relied upon to provide a natural circulation of  
5 flow path under accident scenarios, we do explicitly  
6 model those. You can kind of see that flow path there  
7 at the top of the model underneath the primary salt  
8 pump. The model is basically very simple. Kind of  
9 check valve almost with a very high loss coefficient  
10 in one direction and a very low one in the other  
11 direction.

12 Okay. Specifically talking to the DHRS, so  
13 the whole goal here is to basically be able to model  
14 effectively the heat transfer from the core out to the  
15 ultimate heat removal system in as much detail as we  
16 need to. We start in the core and we work out way  
17 through all the layers, through the pebble bed to the  
18 reflector, through the reflector out through the  
19 downcomer to the core vessel.

20 Then from the reactor vessel we allow  
21 radiation and convection within that compartment to  
22 transfer heat into these DHRS thimbles basically.

23 Then the DHRS model, you know, basically we have a  
24 boundary condition that looks like 100 degree C model,  
25 infinitely replenishable 100 degree C boiling water.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

Right? So when we want to model degraded conditions within the DHRS itself, we can do that by basically turning on and off heat transfer surfaces based on the number of trains that we want to evaluate.

Yeah, there are certain parameters within this analysis, like when you're talking about radiation heat transfer you have to worry about emissivity and that's something that we have available to us to do sensitivity analysis or calculations with. Convective heat transfers is something else that we have looked into. Then the specifics of the thermal resistance within the DHRS itself.

Then just to kind of point out that we basically took the Hermes system and plopped it into the UCD1 building, right? We know that's not what the real thing is going to look like. There's a lot of kind of uncertainty or approximations made within the specific dueling geometry itself, which is another reason why we didn't go forth and do like specific source term calculations because, you know, we know the real thing is going to be different.

Okay. Next slide. Okay. So before I get into describing the specifics of these simulations, I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 wanted to point out first that these are simulating  
2 basically three days of simulation time. Those  
3 required about 10 hours of execution time to produce  
4 these curves.

5           The MHA -- the temperature curves that are  
6 provided by the MHA analysis are the solid lines on  
7 this graph. You'll see the green solid line is what  
8 the fuel temperature is allowed to get to. The red  
9 solid line is what the stainless steel structures are  
10 allowed to get to. The purple solid line is what the  
11 reflector or the graphite structures are allowed to  
12 experience.

13           Then the blue solid line is the flag  
14 freezing temperature. The whole idea of this approach  
15 is as long as your deterministic evaluation lies  
16 within this envelope, then you can say that you have  
17 met your dose requirements. And so our MELCOR models  
18 have a couple different flavors of hot pebble, if you  
19 will.

20           When you generate a peak fuel temperature  
21 plot, you have to find some way to make like -- to  
22 represent what the hottest part of the core is  
23 including all the uncertainties that you want to put  
24 on that hottest part of the core so you have  
25 operational flexibility. We have basically two

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 flavors of hot pebbles in our model.

2 The first one, the very fine dashes here,  
3 you can see those are basically -- as far as the  
4 MELCOR model is concerned, those are a pebble with  
5 TRISO particles that have been bumped up to the very  
6 top edge of the allowable power envelope from the AGR  
7 sequence of tests.

8 Then we have another -- we noticed when we  
9 ran the initial set of calculations that, hey, we  
10 don't match initial peak temperature very well with  
11 the applicant so we have another version of a hot  
12 pebble where we just like turned the power up on that  
13 pebble until we got something that was reasonably  
14 comparable.

15 I think, you know, in retrospect maybe we  
16 should have looked at some of the sensitivity co-  
17 efficients on the different heat transfer models that  
18 we have available to us in MELCOR and done some  
19 adjustments on that as well as power uncertainties.  
20 You know, suffice it to say that we have some  
21 treatment of this hot pebble in the MELCOR models.

22 Before I get into the specific results,  
23 does that seem -- you know, are there any questions at  
24 this point?

25 MEMBER REMPE: Sure. I have a question

1 just to make sure I'm understanding what you're  
2 saying. There's like a green dash line with very  
3 small dots and it only gets to about 1120C.

4 MR. BIELEN: Right.

5 MEMBER REMPE: And then you've got  
6 something where you just arbitrarily jacked up the  
7 power to 1380 or something like that? Is that what  
8 you're telling me? And it's still below the 1400  
9 something or other limit?

10 MR. BIELEN: Yes. I don't know if I would  
11 use the word arbitrarily necessarily but, yes.  
12 Essentially what we've done is we -- so we're not  
13 doing any direct manipulation of the heat transfer  
14 models themselves. Right? So the knob we're turning  
15 is particle power.

16 The fine dashes are the -- or the dots  
17 basically are what happens if we have a hot pebble  
18 that bumps up the power with nominal heat transfer  
19 coefficients, although this pebble has been placed in  
20 the hottest location of the core.

21 Let me be clear about that. But what  
22 happens when we bump the particle power of that pebble  
23 up to the AGR limit? I don't remember specifically.  
24 It's like 255 milliwatts per pebble or -- I can't  
25 remember the specific number.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1                   MEMBER REMPE: So you kind of picked a peak  
2 value that was in a representative range of values?

3                   MR. BIELEN: Right. From the AGR test  
4 basically. So we know that we have an envelope that  
5 lives there and we can go and push a single pebble up  
6 there. This is what the temperature looked like.  
7 Now, clearly when you look at the applicant's  
8 analysis, they have done some other manipulations that  
9 I think are, you know, under the proprietary wall that  
10 are getting their peak temperatures even higher than  
11 that.

12                   In lieu of going in and manipulating our  
13 heat transfer mechanisms, what we've done is basically  
14 just, yes, we have tuned the power of the peak pebble  
15 to try to get a temperature that looks like what the  
16 applicant has produced.

17                   MEMBER REMPE: Okay. And I'm guessing you  
18 don't have enough information yet to really see what  
19 parameters are really important. For the future when  
20 the real design comes in and you try and model it more  
21 with the actual design details, do you know yet, you  
22 know, this parameter is going to be really important  
23 rather than the peak power of the pebble?

24                   MR. BIELEN: Right, yeah. And I think, you  
25 know, that is a good question. I think with robust --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 a little bit more robust kind of long-term planning of  
2 the analysis we would provide to support DANU in this  
3 particular case, we would be prepared to perform some  
4 sensitivities up front and say, okay, well -- and look  
5 at hot channel methodologies that are out there.

6 Ideally we would have access -- our model  
7 developers would have access to the hot channel  
8 methodology that Kairos is using and being able to  
9 specifically adjust the different aspects of this heat  
10 transfer that they are adjusting and see if we get  
11 kind of simpatico affects on how your figures of merit  
12 change as you change your model parameters.

13 MEMBER REMPE: Thank you.

14 MR. BIELEN: Sure. Okay.

15 Yes.

16 MEMBER KIRCHNER: This is Walt Kirchner.  
17 Just one quick question. Did you assume one of the  
18 DHSR trains down for this particular plot?

19 MR. BIELEN: I think the base case was one  
20 DHSR train unavailable of the four.

21 K.C., you can step in if that's wrong.

22 MR. WAGNER: I think that's what the  
23 applicant used, too.

24 APPLICANT: Yes, that's correct. We used  
25 three.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. BIELEN: Okay. Right. The analysis  
2 that I'm going to present to you here is just very  
3 base case as close to the technical report as we could  
4 generate. There are a lot of additional work that we  
5 did behind the scenes to kind of get a feel for the  
6 importance of various systems' availabilities and  
7 other parameters, but we can't really discuss that  
8 here unfortunately.

9 So, okay. In terms of the reactivity  
10 insertion event, as Kairos kind of discussed in their  
11 part of the presentation here, you're reporting a lot  
12 of reactivity and relatively quickly. Three dollars,  
13 you know, in LWR space is like impossible and, you  
14 know, not a thing that can even physically happen.  
15 Three dollars in 100 seconds is a lot.

16 But basically 10 seconds into the  
17 withdrawal, you end up tripping out on high power. As  
18 an additional conservatism here they have a primary  
19 salt pump trip and a flow coast down. You see here we  
20 do get a fuel temperature increase initially due to  
21 that power increase, which is pretty quickly stamped  
22 out by the trip.

23 You can see the latent effects of that heat  
24 leaving the fuel and getting into other parts of the  
25 system as the transient progresses. Then you just

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 sort of sit there for a long time until the scenario  
2 is terminated.

3           Again, we think that our results -- you  
4 know, given all the uncertainty we have in the  
5 specifics of the sand models versus the MO core  
6 models, we think our agreement is, you know, pretty  
7 reasonable. We feel fairly comfortable that what  
8 Kairos has presented is reasonable.

9           I think I forgot to mention this, but the  
10 reference results we're using are that little box on  
11 the upper right. The PSAR results are the little box  
12 on the upper right. The MELCOR calculations are the  
13 big box.

14           Okay. Next slide. As Kairos has eluded  
15 to, they have two flavors of loss of for circulation;  
16 one for overheating trying to maximize temperatures,  
17 and then one for over-cooling to try to see if they  
18 can freeze the flood.

19           We looked at both those scenarios I'm going  
20 to present here on this slide what the MELCOR results  
21 were for the overheating scenario. You have a primary  
22 salt pump trip that is actually a seizure so you have  
23 a very rapid decrease in flow rate. You end up with  
24 a trip over temperature. The temperature is coming up  
25 during the transient.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1           Then again, as soon as the reactor trips,  
2           you have some kind of latent heat that leads the fuel.  
3           Over the course of time it's transferred out through  
4           all the heat transfer pathways in the system to the  
5           DHRS.

6           Eventually your heat removal exceeds your  
7           heat generation and then you start coming down in  
8           temperature after about a day or so, or a little after  
9           a day. Again, a case where you're clearly within DMHA  
10          envelope. As the DMHA envelope is appropriately  
11          defined, these transient scenarios would be pretty,  
12          you know, within the acceptance criteria.

13          MR. SCHULTZ: Andrew, this is Steve  
14          Schultz. The relative comparison between the results  
15          that you've obtained and those that Kairos has  
16          developed is encouraging thinking about moving forward  
17          to the operating license analyses. Didn't you feel  
18          that?

19          MR. BIELEN: Oh, yes. I mean, you know, we  
20          were working on this project in close collaboration  
21          with DANU. They are under a lot of time pressure to  
22          get these reviews done quickly and efficiently.

23          I think Jeff can speak to this himself but,  
24          you know, my impression throughout the whole course of  
25          the project has been, hey, you know, by virtue of you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 guys doing these things and us seeing some very  
2 promising kind of agreement between different  
3 completely independent methods doing the same sorts of  
4 simulations.

5 It's a lot easier to say, okay, I have some  
6 comfort here. We know that we're going to need to do  
7 some more work when the OL comes in, but at least we  
8 have -- it definitely cushioned that ability to get to  
9 a reasonable assurance for a construction permit.

10 MR. SCHULTZ: That was impressive to me.  
11 I really appreciate you showing us the detail.

12 MR. SCHMIDT: This is Jeff. I just want to  
13 say my two piece here. I was amazed the general  
14 trends of the curves were so similar. That was --

15 MEMBER MARCH-LEUBA: Also submission of  
16 energy.

17 MR. SCHMIDT: Yeah, right, but there are  
18 ways to screw that up, as you well know, Jose. I  
19 don't know. I --

20 MR. BIELEN: Jose has never messed anything  
21 up.

22 MR. SCHMIDT: Yes. I was encouraged by  
23 the results; the shape of the curves, the times to  
24 trip, the general trends of the curves. The fact  
25 that, you know, even when we were pushing particle

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 powers to the edge of the AGR envelope, we still had  
2 a lower temperature than the applicant.

3 That's kind of what I was referring to.  
4 It's part of the audit that there were conservatism in  
5 the applicant's calculations. This clearly helped  
6 highlight some of those.

7 I can get some comfort in the fact that  
8 there were conservatism. I generally was very  
9 impressed with the likeness of the results based on  
10 the information that we had available and the time  
11 that researchers in Sandia had to do this.

12 MEMBER MARCH-LEUBA: I've seen the slide  
13 you mentioned of the cooling and freezing. Could you  
14 give us some thoughts on that?

15 MR. SCHMIDT: You know, the over-cooling  
16 analysis in the PSAR is from the loss of poor  
17 circulation and with four trains. We didn't put --  
18 while we did it for comparison, we don't necessarily  
19 think it's the limiting condition.

20 MEMBER MARCH-LEUBA: The important thing is  
21 if it leads to a pathway for reuse, which is  
22 different. I don't know.

23 MR. SCHMIDT: Right now the working  
24 assumption is that freezing will be prevented. I just  
25 wanted to point out that, you know, I didn't spend

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 much time talking about the over-cooling analysis in  
2 the PSAR because I don't necessarily think it's the  
3 limiting over-cooling event. While it is informative,  
4 I think there could be other situations that may be  
5 more limiting and that will have to just be flushed  
6 out as part of the OL.

7 MEMBER MARCH-LEUBA: The thing is with  
8 reactors we have to worry about a number of events.  
9 Clear thing that we flag is freezing. You have to use  
10 some thought and make sure that doesn't produce any  
11 unexpected events.

12 MR. SCHMIDT: Yeah, as we discussed in the  
13 decay heat removal, that is clearly on the mind of the  
14 staff of like what scenarios after you were to say we  
15 are to activate the system that you could get to, say,  
16 a freeze within 72 hours.

17 MEMBER MARCH-LEUBA: Is the bundling  
18 condition 100 degrees C?

19 MR. SCHMIDT: Yeah, yeah. Right.

20 MEMBER MARCH-LEUBA: On the vessel?

21 MR. SCHMIDT: Well, on the decay heat  
22 removal system, yeah. Right.

23 MEMBER MARCH-LEUBA: And the freezing  
24 is --

25 MR. SCHMIDT: 450.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER MARCH-LEUBA: 450?

2 MR. SCHMIDT: 459 C, I think.

3 MEMBER REMPE: When you finally get the OL  
4 are you planning to do some sort of confirmatory dose  
5 calculations? I mean, right now what I think I'm  
6 reading is we're going to use the MHA and that's all  
7 we're going to do for a dose calculation. Then we'll  
8 do analyses and compare it to metrics. These are  
9 being compared to those metrics. They are not dose  
10 calculations. Are you going to --

11 MEMBER MARCH-LEUBA: You will do these  
12 calculation versus the figure.

13 MEMBER REMPE: Right. Is that all staff is  
14 going to do, too? Are you going to do confirmatory on  
15 the MHA?

16 MR. SCHMIDT: I don't think it's been  
17 decided. We have not laid out a path in detail where  
18 we're going to go. This was just to inform our  
19 reasonable assurance finding for the construction  
20 permit.

21 MEMBER REMPE: Sure.

22 MR. SCHMIDT: And to reinforce what we  
23 thought our engineering judgement was. Beyond that,  
24 we're not committing to anything at this point other  
25 than we have the models and capability to do it.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. BIELEN: That's exactly right, Jeff.  
2 The only thing I'll say about that right now is, first  
3 of all, DANU is our customer and we aim to please our  
4 customer, but we have the models and capabilities.  
5 You know, I think a reasonable person would say, uh,  
6 if you can do this thing, why don't you? That's all  
7 I'll say about that at this point.

8 MEMBER REMPE: So then I'm going to mention  
9 to you then you've got the capabilities in MELCOR to  
10 look at oxidation of the pebbles and the reflector  
11 graphic. I think you probably also have the ability  
12 to predict Co and Co2 forms. Is that true? I'm not  
13 sure actually. I shouldn't say I think. I don't know  
14 what all models you put in for gas reactors.

15 MR. BIELEN: Yeah, we'll have to defer to  
16 K.C. on this.

17 MR. WAGNER: Yes, we have empirical  
18 correlation and the ratio of Co versus Co2's function  
19 of temperature.

20 MEMBER REMPE: So you could do that type of  
21 calculation, too.

22 MR. WAGNER: Yep.

23 MEMBER REMPE: Thank you.

24 MR. SCHMIDT: This is Jeff Schmidt. Do  
25 you have more that you want to go through or are you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 done?

2 MR. BIELEN: I mean, I'm prepared to  
3 respond to any additional questions, but I think  
4 that's my last slide.

5 MR. SCHMIDT: Let's go on to the next  
6 slide then. I'm going to do this one. Overall staff  
7 conclusions. The staff found that postulated event  
8 methodologies can be used to predict conservative  
9 event temperatures and dose releases. This is really  
10 the calculational framework of some of the things I  
11 talked about like dust generation, associated  
12 activities associated with that dust generation,  
13 oxidation and Oxidation correlations.

14 I has, I think, a very reasonable  
15 framework. Staff reviewed PSAR Table 13.1-1,  
16 Acceptance Criteria, and found these acceptable as  
17 described in SE Section 13.2.2 because they account  
18 for the physical phenomena and release pathways that  
19 are not part of the MHA to ensure that the MHA remains  
20 founding.

21 The OL application will provide dose  
22 analysis for events honored by the MHA release, along  
23 with the comparison to the acceptance criteria for the  
24 figures of merit in PSAR Table 13.1-1.

25 Next slide. Because the figures of merit

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 and associated acceptance criteria ensure that the MHA  
2 releases remain amnii, the staff has reasonable  
3 assurance that the radiological consequences of the  
4 postulated events will also meet regulatory  
5 requirements of 10 CFR 100.11, and 10 CFR 50.34(a).

6 Staff concludes information in the Hermes  
7 PSAR Chapter 13 is sufficient for the issuance of a  
8 construction permit (CP) in accordance with 10 CFR  
9 50.35 and 50.40. Further information can be  
10 reasonably left to the OL application.

11 MEMBER REMPE: I'm sorry. I guess I  
12 misunderstood. The third bullet, they will provide  
13 dose analyses for events -- for each category events  
14 even though it's down by MHA. I thought they said no,  
15 we're just going to do the MHA and --

16 MR. SCHMIDT: Yeah. So my expectation is  
17 like specific classes of events the limiting of that  
18 will be compared to the MHA.

19 MEMBER REMPE: Will be compared with the  
20 metrics. Here it says they will provide dose  
21 analysis.

22 MR. SCHMIDT: Dose analysis.

23 MEMBER REMPE: Someone asked that today and  
24 I thought they came back and said no, we're just going  
25 to do the MHA.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 MEMBER MARCH-LEUBA: My understanding of  
2 the answer was that they wouldn't.

3 MEMBER REMPE: That's what I thought, too,  
4 but you are confident what you have here is true.

5 MR. SCHMIDT: As far as I'm aware, yes.

6 MEMBER REMPE: Is that documented enough in  
7 the SE that we can be confident? That's why I was  
8 pushing for the staff to do the dose analysis if they  
9 are not going to.

10 MR. SCHMIDT: It's not our responsibility to  
11 do the dose analysis.

12 MEMBER REMPE: Yeah, I know, but --

13 MR. SCHMIDT: I think it basically says in  
14 the SE that they -- I would have to go back.

15 MEMBER REMPE: Let's ask the applicant  
16 again but Jose came away with the same response.

17 MEMBER MARCH-LEUBA: SE is bounding. You  
18 can put an additional condition but --

19 MR. SCHMIDT: The SE does not --

20 MEMBER MARCH-LEUBA: -- the oil --

21 MR. SCHMIDT: That's true. The SR -- the  
22 PSAR in this case dictates.

23 MEMBER MARCH-LEUBA: All the staff can do  
24 is wait for the applicant to make up their mind and  
25 then decide whether --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER REMPE: So we don't necessarily  
2 believe this third bullet. I think I heard you say  
3 I'm not sure.

4 MR. SCHMIDT: I mean, that's my  
5 expectation.

6 MEMBER REMPE: Is that expectation  
7 documented in your SE?

8 MR. SCHMIDT: That I would have to go back  
9 and see if it's clearly documented.

10 MEMBER REMPE: can we just ask the  
11 applicant to clarify because Jose and I kind of came  
12 away with a different response.

13 MEMBER MARCH-LEUBA: Let's be realistic.  
14 The II process is a work in progress.

15 MR. SCHMIDT: I mean, we can ask our --

16 MEMBER REMPE: Jose, I thought he asked  
17 them that and they said something different.

18 MR. SCHMIDT: He did. He did. My bullet  
19 is likely different than the response earlier.

20 MEMBER REMPE: Okay. Do we want to clarify  
21 it or let it go?

22 MEMBER MARCH-LEUBA: It's clear that the  
23 applicant doesn't have to commit now to do anything.

24 MEMBER REMPE: Okay.

25 MEMBER MARCH-LEUBA: Just provide a --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER REMPE: Okay. We're both puzzled at  
2 the difference, I guess.

3 MR. SCHMIDT: Okay. I thought so.

4 MEMBER REMPE: I'm sorry, what?

5 MR. SCHMIDT: He was giving me guidance  
6 reminding me what's in our SE. We believe it's in our  
7 SE.

8 MEMBER REMPE: Good. Okay.

9 MEMBER KIRCHNER: This is Walt. I believe  
10 it's in your SE. It's my understanding that your last  
11 bullet is correct.

12 MEMBER REMPE: I would like to see what --  
13 point me to the place. I've got the SE here and it  
14 would help.

15 MR. SCHMIDT: It's listed in the Appendix  
16 A.

17 MEMBER REMPE: So it's in Appendix A?  
18 That's great. Okay.

19 CHAIR PETTI: Is that it?

20 MR. SCHMIDT: It is.

21 CHAIR PETTI: So, members, any questions?  
22 With that, the presentations are done. I think at  
23 this point we probably should go to public comments  
24 and then we can talk about next steps after that.

25 MEMBER MARCH-LEUBA: The memo is -- the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 discussion needs to be transcribed.

2 CHAIR PETTI: Right.

3 MEMBER MARCH-LEUBA: The public comments  
4 also.

5 CHAIR PETTI: Okay. Any member of the  
6 public that has a comment, please unmute yourself,  
7 identify who you are, and state your comments.

8 Okay. Not hearing any, I think we are done  
9 with presentations. We have to decide whether you  
10 would like -- we will go off the record, court  
11 reporter.

12 (Whereupon, the above-entitled matter went  
13 off the record at 4:20 p.m.)

14

15

16

17

18

19

20

21

22

23

24

25

April 11, 2023

Docket No. 50-7513

US Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555-0001

Subject: Kairos Power LLC  
Presentation Materials for Kairos Power Briefing to the Advisory Committee on Reactor Safeguards, Kairos Power Subcommittee on Hermes Preliminary Safety Analysis Report Section 12.9 and Chapter 13

References: Letter, Kairos Power LLC to Document Control Desk, "Submittal of the Preliminary Safety Analysis Report for the Kairos Power Fluoride Salt-Cooled, High Temperature Non-Power Reactor (Hermes), Revision 2," February 24, 2023 (ML 23055A673)

This letter transmits the presentation slides for the April 18-19, 2023 briefing for the Advisory Committee for Reactor Safeguards (ACRS), Kairos Power Subcommittee. During the April 18 meeting, participants will discuss Hermes Preliminary Safety Analysis Report (PSAR) Section 12.9 and Chapter 13. During the April 19 meeting, participants will have additional discussion on Hermes PSAR Chapter 13.

Enclosure 1 provides the non-proprietary slides for the April 18, 2023 briefing. Enclosure 2 provides the non-proprietary slides for the April 19, 2023 briefing. Kairos Power authorizes the Nuclear Regulatory Commission to reproduce and distribute the submitted content, as necessary, to support the conduct of their regulatory responsibilities.

If you have any questions or need additional information, please contact Rachel Haigh at [haigh@kairospower.com](mailto:haigh@kairospower.com) or (704) 412-5920, or Darrell Gardner at [gardner@kairospower.com](mailto:gardner@kairospower.com) or (704) 769-1226.

Sincerely,



Peter Hastings, PE  
Vice President, Regulatory Affairs and Quality

Enclosures:

- 1) Presentation Slides for the April 18, 2023 ACRS Kairos Power Subcommittee Meeting (Non-Proprietary)
- 2) Presentation Slides for the April 19, 2023 ACRS Kairos Power Subcommittee Meeting (Non-Proprietary)

xc (w/enclosure):

William Jessup, Chief, NRR Advanced Reactor Licensing Branch  
Benjamin Beasley, Project Manager, NRR Advanced Reactor Licensing Branch  
Edward Helvenston, Project Manager, NRR Advanced Reactor and Licensing Branch  
Samuel Cuadrado de Jesus, Project Manager, NRR Advanced Reactor Licensing Branch  
Matthew Hiser, Project Manager, NRR Advanced Reactor Licensing Branch  
Weidong Wang, Senior Staff Engineer, Advisory Committee for Reactor Safeguards

**Enclosure 1**  
**Presentation Slides for the April 18, 2023**  
**ACRS Kairos Power Subcommittee Meeting**  
**(Non-Proprietary)**



# Kairos Power

## Hermes PSAR 12.9 Quality Assurance

---

JORDAN HAGAMAN – DIRECTOR OF RELIABILITY ENGINEERING AND QUALITY ASSURANCE

ACRS KAIROS POWER SUBCOMMITTEE MEETING

APRIL 18, 2023



# 12.9 Quality Assurance

---

- 10 CFR 50.34 (a)(7) “A description of the quality assurance program to be applied to the design, fabrication, construction, and testing of the structures, systems, and components of the facility.
- The Quality Assurance Program Description (QAPD) for the design, construction, and operation of the Hermes reactor is based on ANSI/ANS 15.8–1995 (R2005), “Quality Assurance Program Requirements for Research Reactors”
  - Endorsed by NRC Regulatory Guide 2.5, “Quality Assurance Program Requirements for Research and Test Reactors” (RG 2.5)

# Quality Assurance Program Description

---

- The Hermes QAPD applies to design-phase, construction-phase, and operations-phase activities affecting the quality and performance of safety-related structures, systems, and components (SSCs).
- Safety-related SSCs within the scope of the Hermes QAPD are identified by design documents. Technical aspects are considered when determining program applicability including, as appropriate, the SSCs design safety function.

# Quality Assurance Program Description

---

- The Hermes QAPD includes discussion of eighteen design, construction, and modifications program elements:
  - Organization
  - Quality Assurance Program
  - Design Control
  - Procurement Document Control
  - Procedures, Instructions, and Drawings
  - Document Control
  - Control of Purchased Items and Services
  - Identification and Control of Items
  - Control of Special Processes
  - Inspections
  - Test Control
  - Control of Measuring and Test Equipment
  - Handling, Storage, and Shipping
  - Inspection, Test, and Operating Status
  - Control of Non-Conforming Items and Services
  - Corrective Actions
  - Quality Records
  - Assessments



# Kairos Power

## Hermes PSAR Chapter 13 Accident Analysis

---

DR. MATTHEW DENMAN – DISTINGUISHED ENGINEER, RELIABILITY

ACRS KAIROS POWER SUBCOMMITTEE MEETING

APRIL 18, 2023


# Safety Case Summary

---

- 10 CFR 50.34(a)(4) requires a preliminary safety analysis to assess the risk to public health and safety from operation of the facility, including determination of the margins of safety
- To demonstrate compliance with 10 CFR 100.11 dose reference values, a Maximum Hypothetical Accident (MHA) that bounds the postulated events is analyzed for dose consequences by challenging the performance of functional containment
  - The Hermes MHA approach is consistent with guidance in NUREG-1537
  - The Hermes MHA is not physical
  - The Hermes MHA includes conservatisms that maximize source term
  - The Hermes MHA includes a postulated release of radionuclides
- To ensure that the postulated events are bounded by the MHA:
  - The list of postulated events is comprehensive to ensure that any event with the potential for significant radiological consequences has been considered
    - Initiating events and scenarios are grouped, so that a limiting case for each group can be qualitatively described in CPA (quantitative results will be provided with OLA)
    - Acceptance criteria are provided for the important figures of merit in each postulated event group to ensure that the potential consequences of that event group remain bounded by the MHA as the design progresses
  - Prevention of an event initiator is justified in the PSAR


# Relationship between Dose Limits, the Maximum Hypothetical Accident, and Postulated Events

- The Maximum Hypothetical Accident (MHA) is constructed to:
  - Be conservatively non-physical to overestimate potential off-site dose consequences
  - Provide confidence that sufficient safety margin exists
  - Ensure that reasonable design constraints will result in bounded postulated event doses
- At the PSAR stage, only the MHA dose is:
  - Quantitatively evaluated
  - Needed to ensure that sufficient margin exists to 10 CFR 100.11 dose reference values



# Maximum Hypothetical Accident: Narrative (1 of 2)

The shutdown and heat removal systems are assumed to perform their safety functions but are not modeled. Instead, hypothetical temperature curves are used to conservatively drive radionuclide movement through the functional containment. Individual release pathways are discussed on the next slide.



# Maximum Hypothetical Accident: Narrative (2 of 2)

---

- Radionuclides are postulated to diffuse from TRISO particles
  - The distribution of TRISO particles account for both manufacturing defects and in-service failures
  - Pre-transient diffusion of radionuclides from the fuel kernels are hypothetically and conservatively not modeled to maximize fuel inventory for release
- Radionuclides are postulated to evaporate and degas from the Flibe driven by conservative natural convection boundary conditions. No holdup of gases in Flibe is credited.
- Tritium is conservatively assessed to maximize both its inventory and release
  - The initial inventory of tritium is conservatively assessed
  - The release of tritium is conservatively postulated to:
    - desorb from in-vessel graphite as a function of temperature
    - instantaneously release from both steel and Flibe
- The Ar-41 inventory that is held up by closed graphite pores is instantaneously released



# MHA: Methodology (1 of 3)

---

The Hermes MHA uses the methodology from the approved KP-FHR Mechanistic Source Term Methodology Topical (KP-TR-012-P-A). The following concepts directly leverage the topical report:

- Radionuclide grouping and transport approaches for the TRISO Fuel and Flibe coolant
- Mass transfer correlations for tritium into graphite reflectors and pebbles
- The gas space is not credited for confinement of the radionuclides that release from the Flibe free-surface
- “Two-hour holdup” assumptions for radionuclides transporting through the reactor building
- Conservative, unfiltered, ground level releases are modeled to maximize offsite doses

# MHA: Methodology (2 of 3)


---

The following non-physical conditions provide additional hypothetical challenges to the functional containment (beyond what is described in KP-TR-012-P-A):

- Prescribed hypothetical temperature histories are applied to the transient. This ensures that the MHA will bound the system temperatures from the postulated event groups.
- Pre-transient diffusion of radionuclides from the fuel in the reactor core is neglected. This ensures that the maximum inventory is available for release at the initiation of the transient.
- A bounding vessel void fraction is assumed to facilitate the release of low volatility species in the vessel via bubble burst.
- Additional conservatism in tritium modeling to address limitations associated with tritium modeling in graphite is described in KP-TR-012-P-A.

# MHA: Methodology (3 of 3)

1. Identify and account for the sources of material at risk (MAR) and the barriers to release
2. Evaluate release fractions for every combination of barrier, radionuclide group, and time interval
3. RADTRAD and ARCON evaluate dose consequences at the exclusion area boundary (EAB) and the low population zone (LPZ)



# Maximum Hypothetical Accident: Sources of MAR (1 of 2)

---

## 1. TRISO Fuel

- Serpent 2 evaluation provides fuel inventory
- Pre-transient depletion of radionuclides from the fuel is neglected to maximize inventory available for release

## 2. Circulating Activity

- Bounding value of circulating activity is assumed in the analysis
- Expected to be a variable controlled by technical specification

# Maximum Hypothetical Accident: Sources of MAR (2 of 2)



---

## 3. Structural (steel, reflector, pebbles)

- Tritium
  - The inventory conservatively bounds the operating lifetime at full capacity factor with margin while accounting for differential uptake rates for pebbles and reflector
  - Transfer from Flibe to structures
    - Born in the Flibe but transferred to and sorbed in structures (primarily graphite)
    - Transport speciation is conservatively assigned as tritium fluoride to maximize tritium sorption
    - Transfer from Flibe to structures determined by mass transfer coefficients from Flibe flow characteristics
  - Sorption within structures
    - Sorbed solely as a function of mass transfer from the Flibe to structures (i.e., no diffusion resistance)
    - Retained without modeling steady state release mechanisms (i.e., perfect absorber)
- Argon-41
  - Produced via neutron activation of Ar-40 to Ar-41
  - The inventory available for release consists of Ar-41 contained within the graphite's closed porosity



# Maximum Hypothetical Accident: Release models for the TRISO Fuel

- Transport through TRISO fuel layers is modeled using Fick's laws of diffusion
  - The CORSOR model is used for kernel diffusion
  - IAEA correlations are used for layer diffusion
- Diffusion is driven by the fuel's hypothetical temperature curve
- Transient diffusion of fission products:
  - Is negligible if even a single PyC layer remains intact
  - Total releases are thus dominated by releases from exposed kernels



# Maximum Hypothetical Accident: Release models for the Flibe Coolant



- Flibe provides a secondary functional containment barrier to:
  - Bounding circulating activity
  - In-transient release of fission products from TRISO
- Two release mechanisms are modeled for Flibe
  - Bubble burst
  - Evaporation



- Certain radionuclide groups bypass the Flibe's functional containment
  - No credit for gas retention
  - High volatility noble metals evaporate near instantaneously

# Maximum Hypothetical Accident: Release models for the Structural MAR


- Tritium in graphite grains
  - No-holdup of tritium in the Flibe instantly drops the concentration of tritium outside of graphite grains drops to zero
  - Tritium rapidly diffuses out of the graphite grain due to the non-physical concentration gradient
- MAR outside of graphite grains (e.g., steel, pores) are instantly released at the start of the transient





# Maximum Hypothetical Accident: Release models for the Gas/Atmospheric Transport

- RADTRAD:
  - Input: Mobilized material-at-risk activities
  - Depletion mechanisms
    - Radioactive decay
    - Aerosol settling (i.e., Henry correlation)
  - Leakage rates (two-hour holdup)
- ARCON96:
  - Inputs
    - Hourly Meteorological Data
    - Distance from the reactor building to the following areas:
      - Exclusion area boundary
      - Low population zone
    - Approved values from KP-TR-012
  - Outputs
    - Time averaged dispersion values



**ARCON96**

Distance (m)	$\frac{x}{Q}$ (s/m <sup>3</sup> )				
	0-2 hrs	2-8 hrs	8 hrs – 1 day	1 – 4 days	4 – 30 days
<b>250</b>	1.51x10 <sup>-4</sup>	N/A	N/A	N/A	N/A
<b>800</b>	3.61x10 <sup>-5</sup>	3.51 x10 <sup>-5</sup>	1.45 x10 <sup>-5</sup>	1.54 x10 <sup>-5</sup>	1.49 x10 <sup>-5</sup>

# Maximum Hypothetical Accident: Dose Consequences

---

Dose results meet 10 CFR 100.11 reference values at the EAB and LPZ with significant margin

Location and Duration	Whole Body Dose (rem)		Thyroid Dose (rem)	
	10 CFR 100	MHA Result	10 CFR 100	MHA Result
Exclusion Area Boundary (First 2 hrs at 250m)	25	0.227	300	0.235
Low Population Zone (30 days at 800m)	25	0.059	300	0.081

# Summary

---

- The MHA dose consequence results meet the site dose reference values in 10 CFR 100.11(a)(1-2) at the EAB and LPZ with significant margin
- The MHA dose is bounding because it employs non-physical conditions that are beyond the design basis

**Enclosure 2**  
**Presentation Slides for the April 19, 2023**  
**ACRS Kairos Power Subcommittee Meeting**  
**(Non-Proprietary)**



# Kairos Power

## Hermes PSAR Chapter 13 Accident Analysis

---

DR. MATTHEW DENMAN – DISTINGUISHED ENGINEER, RELIABILITY

DR. TIMOTHY DRZEWIECKI – MANAGER, SAFETY ANALYSIS

ACRS KAIROS POWER SUBCOMMITTEE MEETING

APRIL 19, 2023


# Safety Case Summary

---

- 10 CFR 50.34(a)(4) requires a preliminary safety analysis to assess the risk to public health and safety from operation of the facility, including determination of the margins of safety
- To demonstrate compliance with 10 CFR 100.11 dose reference values, a Maximum Hypothetical Accident (MHA) that bounds the postulated events is analyzed for dose consequences by challenging the performance of functional containment
  - The Hermes MHA approach is consistent with guidance in NUREG-1537
  - The Hermes MHA is not physical
  - The Hermes MHA includes conservatisms that maximize source term
  - The Hermes MHA includes a postulated release of radionuclides
- To ensure that the postulated events are bounded by the MHA:
  - The list of postulated events is comprehensive to ensure that any event with the potential for significant radiological consequences has been considered
    - Initiating events and scenarios are grouped, so that a limiting case for each group can be qualitatively described in CPA (quantitative results will be provided with OLA)
    - Acceptance criteria are provided for the important figures of merit in each postulated event group to ensure the potential consequences of that event group remain bounded by the MHA as the design progresses
  - Prevention of an event initiator is justified in the PSAR

# Relationship between Dose Limits, the Maximum Hypothetical Accident, and Postulated Events

- The Maximum Hypothetical Accident (MHA) is constructed to:
  - Be conservatively non-physical to overestimate potential off-site dose consequences
  - Provide confidence that sufficient safety margin exists
  - Ensure that reasonable design constraints will result in bounded postulated event doses
- In PSAR Chapter 13, the MHA dose is:
  - Quantitatively evaluated
  - Ensures that sufficient margin exists to 10 CFR 100.11 dose reference values



# Postulated Event Analysis Methodology

---

- Postulated events are identified in Chapter 13 of the PSAR
  - Postulated events include any potential upset to plant operations, within the plant design basis, that causes an unplanned transient to occur
  - Justification is provided for those events excluded from the design basis (Prevented Events, PSAR Section 13.1.10)
- Figures of merit provide the means to measure and demonstrate that the resulting dose of a postulated event is bounded by the dose consequences of the MHA
- The preliminary methods and sample calculations of the postulated event groups are provided in KP-TR-018, Rev. 2. The methodology describes:
  - How to analyze figures of merit for each postulated event group
  - How the acceptance criteria ensure that the off-site dose consequences of postulated events are bounded by the MHA
- The final safety analysis results will be provided with the Operating License Application (including verification and validation of the evaluation models used)



# Postulated Event Analysis Methodology (cont.)

---

- The evaluation model development activities for the postulated events follow a process similar to the Evaluation Model Development and Assessment Process (EMDAP) from Reg. Guide 1.203
- Postulated events with similar characteristics and modeling approaches are grouped into categories, consistent with NUREG-1537
- The limiting event for each event category is identified and qualitatively assessed from event initiation until a safe state is reached
- The safe state is defined in the methods for each category of events as a point where the transient figures of merit have stabilized in a safe condition

# Input Parameters for Postulated Event Analysis

---


- Input parameters considered for postulated event analysis include a range of values to be evaluated for the final design (Table 4-4 of KP-TR-018)
- A range of values are assessed to identify the limiting scenario for each postulated event
- Key model uncertainties and initial conditions are conservatively applied to the methods to ensure figures of merit are conservatively predicted

# Limiting Postulated Events (1 of 3)


---

- Loss of Forced Circulation
  - Pump seizure disables the primary salt pump
  - Reactor protection system detects high coolant temperature and initiates a reactor trip
  - Grouped events include locked rotor and loss of normal heat sink
- Insertion of Excess Reactivity
  - Control system or operator error causes highest worth control element to withdraw continuously at the maximum control element drive speed
  - Reactor protection system detects the reactivity insertion due to a high neutron flux or high coolant temperature and initiates a reactor trip
  - Grouped events include fuel loading error, reflector shifting, and venting of gas bubbles
- General Challenges to Normal Operation
  - Includes challenges to normal operation not covered by another event category that require automatic or manual shutdown of the reactor
  - Bounded by the limiting loss of forced circulation postulated event
  - Grouped events include spurious trips, operator errors, and equipment failures

# Sample Transient Analysis – Loss of Forced Circulation (Overheating)



KP-TR-018, Figure A4-1



Adapted from KP-TR-018, Figure A4-1

- Loss of forced circulation initiated by pump seizure/locked rotor
- Reactor trip on high plenum temperature reached ~30 seconds into event
- A second peak occurs ~20 hours into event followed by monotonic temperature decrease

# Limiting Postulated Events (2 of 3)

---

- Mishandling or Malfunction of Pebble Handling and Storage System
  - Break in a fuel transfer line during removal from the core results in a spill of pebbles within the transfer line to the room
  - The reactor protection system detects this condition and initiates a pebble handling and storage system trip
  - Grouped events include transfer line break when pebbles are inserted into empty core, core at power, storage canisters, and mishandling of fuel outside the reactor
- Radioactive Release from a Subsystem or Component
  - Limiting event assumed to be a seismic event that results in a failure of all systems containing radioactive material that are not qualified to maintain structural integrity during a design basis earthquake
  - Design requirement on the amount of MAR for SSCs to be below the amount of MAR derived from the MHA
  - Grouped events include releases from the tritium management system, inert gas system, chemistry control system, and inventory management system

# Limiting Postulated Events (3 of 3)

---

- Salt Spills
  - A hypothetical double-ended guillotine break occurs in the PHTS hot leg piping
  - Reactor protection system detects the salt spill due to a low coolant level and initiates a reactor trip
  - Grouped events include spurious draining of the PHTS, leaks from other Flibe containing systems, mechanical impact or collision of Flibe bearing SSCs, and HRR tube breaks
- Internal and External Hazard Events
  - Internal and external events include internal fire, internal water flood, seismic event, high wind, toxic release, mechanical impact or collision with SSCs, and external flood as described in Chapter 2
  - Events in this category are bounded by or considered as initiators in other event categories

# Summary

---

Postulated events within the design basis are identified and grouped by characteristics and modeling approaches

- Design features which are credited with mitigating the effects of postulated events are described
- Figures of merit are derived for the postulated events to provide surrogate metrics which demonstrate that the resulting doses are bounded by the dose consequences of the MHA analysis
- The acceptance criteria for these figures of merit represent design limits that ensure the MHA is bounding



# **NRC Staff Review for PSAR Section 12.9 and Chapter 13**

---

**Briefing for the Advisory Committee on Reactor Safeguards**

**April 18-19, 2023**

Office of Nuclear Reactor Regulation



# Agenda

- PSAR Section 12.9, “Quality Assurance”
- PSAR Chapter 13, “Accident Analyses”
  - Maximum Hypothetical Accident (MHA) – PSAR Sections 13.1.1 and 13.2.1
  - Postulated Events and Other Sections – PSAR Sections 13.1.2 to 13.1.10 and 13.2.2
- Common Agenda for Each Chapter
  - Overview of PSAR Chapter and Principal Design Criteria (PDC)
  - Referenced topical reports (if applicable)
  - Staff technical evaluation
  - Findings and conclusions

# Common Regulatory Basis

- 10 CFR 50.34(a), “Preliminary safety analysis report.”
- 10 CFR 50.35, “Issuance of construction permits.”
- 10 CFR 50.40, “Common standards.”
- **Guidance:** NUREG-1537, “Guidelines for Preparing and Reviewing Applications for the Licensing of Non-Power Reactors,” Part 2, “Standard Review Plan and Acceptance Criteria.”



# **NRC Staff Review for PSAR Section 12.9 Quality Assurance**

---

**Briefing for the Advisory Committee on Reactor Safeguards**

**April 18, 2023**

By the Division of Reactor Oversight  
Office of Nuclear Reactor Regulation

# Overview of PSAR Section 12.9, “Quality Assurance”

---

- PSAR Section 12.9, “Quality Assurance” states that the description of Kairos’ quality assurance (QA) program for the design, construction, and operation of Hermes is based on:
  - Regulatory Guide (RG) 2.5, “Quality Assurance Program Requirements for Research and Test Reactors,” Revision 1, which endorses:
    - American National Standards Institute/American Nuclear Society (ANSI/ANS) 15.8-1995, “Quality Assurance Program Requirements for Research Reactors.”
- Kairos provided its Quality Assurance Program Description (QAPD) as Appendix B to PSAR Chapter 12 (i.e., PSAR Appendix 12B).

# Additional Regulatory Guidance

---

- NRC RG 2.5, “Quality Assurance Program Requirements for Research and Test Reactors,” Revision 1 endorses:
  - ANSI/ANS 15.8-1995, “Quality Assurance Program Requirements for Research Reactors.”

# Staff Evaluation

---

- Reviewed QAPD using the guidance in ANSI/ANS 15.8-1995, which is endorsed by NRC RG 2.5, Revision 1.
  - Evaluated QAPD Section 1, “Introduction,” and Section 2, “Design, Construction, and Modifications,” for the issuance of a construction permit (CP) because those sections apply to Hermes’ design, fabrication, construction, and testing.
    - Staff found Kairos followed ANSI/ANS 15.8-1995 in most sections. The following slides focus on areas where Kairos deviated from the standard.
  - Did not evaluate QAPD Section 3, “Facility Operations,” because it would apply to Hermes’ operation and is therefore not relevant to the issuance of a CP.

# Staff Evaluation

---

- Staff evaluation of QAPD sections not in accordance with ANSI/ANS 15.8-1995:
  - Kairos proposed an alternate definition of “safety-related” to match the definition of “safety-related” in PSAR Chapter 3
    - The staff found this to be acceptable
  - PSAR Appendix 12B, Section 2.19 – Experimental Equipment:
    - Kairos did not provide description of controls for experimental equipment
    - PSAR Section 10.1 states that Hermes will not include special facilities dedicated to the conduct of reactor experiments or experimental programs.
    - Based on this, the NRC staff finds it acceptable that the QAPD does not include controls for experimental equipment.

## Staff Evaluation (continued)

---

- Staff evaluation of QAPD sections not in accordance with ANSI/ANS 15.8-1995:
  - PSAR Appendix 12B, Section 4 – Applicability to Existing Facilities & Section 5 – Decommissioning:
    - ANSI/ANS-15.8-1995, Sections 4 and 5, are not applicable to the Hermes CP application
    - Acceptable that the QAPD did not include this recommended information, because Kairos did not indicate that the QAPD will apply to any existing facilities, and because submission of decommissioning plans and associated quality assurance provisions is not required until a licensee applies for license termination after permanent cessation of operations.



# Recommended Construction Permit Condition

---

- The staff recommends that the construction permit include the following condition:
  - Kairos shall implement the QA program described, pursuant to 10 CFR 50.34(a)(7), in Chapter 12, Appendix B, of Revision 2 of the Hermes PSAR, including revisions to the QA program in accordance with the provisions below:
    - Kairos may make changes to its previously accepted QA program description without prior NRC approval, provided the changes do not reduce the commitments in the QA program description as accepted by the NRC.
      - Changes to the QA program description that do not reduce the commitments must be submitted to the NRC within 90 days.
    - Changes to the QA program description that do reduce the commitments must be submitted to the NRC and receive NRC approval prior to implementation.

# Conclusion

---

- NRC staff finds the preliminary design information is consistent with the applicable criteria in NUREG-1537
- The staff concludes information in Hermes PSAR Section 12.9 and Appendix 12B is sufficient for the issuance of a CP in accordance with 10 CFR 50.35 and 50.40
  - Further information as may be required to complete the review of Kairos's QA program for the conduct of operations and decommissioning can be reasonably left for the OL application.

Questions?



# **NRC Staff Review for PSAR Section 13 Accident Analysis – Maximum Hypothetical Accident**

---

**Briefing for the Advisory Committee on Reactor Safeguards**

**April 18, 2023**

By the Division of Advanced Reactors and  
Non-Power Production and Utilization Facilities

Office of Nuclear Reactor Regulation

# Overview of PSAR 13 – Maximum Hypothetical Accident (MHA)

- Preliminary analysis
- Consequences bounding for postulated events
- MHA event description and assumptions in PSAR Section 13.1.1
- MHA consequence analysis in PSAR Section 13.2.1
- PSAR Section 13.2.2 describes the postulated event methodology and assurance that the MHA consequence analysis is bounding for postulated events
  - Staff's evaluation will be presented tomorrow

# Referenced Topical Reports

---

- KP-TR-011-NP-A, Revision 1, “Fuel Qualification Methodology for the Kairos Power Fluoride-Salt Cooled High Temperature Reactor (KP-FHR)”
- KP-TR-012-NP-A, Revision 1, “Mechanistic Source Term Methodology for the Kairos Power Fluoride Salt-Cooled High-Temperature Reactor”

# MHA Description and Assumptions

---

- PSAR Figure 13.2-1 MHA hypothetical temperature vs. time profile to give bounding radionuclide releases
  - Not based on a specific scenario
  - Fission product release and transport mainly through diffusion driven by temperature
  - Final determination that temperature vs. time curve is conservative to postulated events at the OL review
- Assumes safety-related systems function as designed but includes consideration of the single failure criterion
- No incremental fuel particle coating failures from transient

# MHA Consequence Analysis

---

- Accident source term methodology
  - Model system as sources of radioactive material at risk of release (MAR) and barriers to release
  - Apply release fraction to each barrier to eventually result in release to environment
    - Consistent with functional containment
  - Gravitational settling of Flibe aerosols in reactor building



# MHA Source Term Modeling

---

- Radionuclide diffusion releases from fuel, Flibe, and graphite as a function of hypothetical temperature vs. time profile in PSAR Figure 13.2-1
- MHA assumes conservative fuel, Flibe, structural, and cover gas releases
  - The complete fuel inventory is available for release into the Flibe
  - Bounding failed fuel fractions by cohort are assumed
  - Flibe and cover gas radionuclide inventories are set to technical specification values
- Except for fuel transient releases, tritium, and Argon-41, the MHA uses approved mechanistic source term (MST) models from KP-TR-012-P-A
  - Fuel releases are modelled using accepted methods
  - Staff reviewed the fuel release references and found the models acceptable
  - Tritium modeling resulting in higher total releases
  - Staff evaluated the modeling assumptions for Ar-41 and found them to be conservative
    - Audit of Ar-41 calculation

# Staff Evaluation – MHA Consequence Analysis

---

- Preliminary MHA dose analysis methods and assumptions are consistent with the approved MST methodology KP-TR-012-P-A
  - Staff will review details of final implementation in OL
- Staff evaluation of the site-characteristic short-term atmospheric dispersion factors is discussed in SE Section 2.3

# Staff Evaluation – MHA Consequence Analysis

---

- Staff audit of preliminary consequence analysis and MHA source term information
  - Confirmed PSAR description of MHA analysis
  - Kairos calculations and reference reports
    - Initial radionuclide inventory/MAR sources
      - Fuel, Flibe
      - Tritium and Ar-41 inventories in graphite
    - Releases from graphite
    - Modeling of radionuclide transport across barriers/release fractions
  - In-person discussion with Kairos staff showing example of how to take information from the MHA to develop the RADTRAD code input to calculate doses

## Staff Evaluation Findings – MHA

---

- The MHA serves as a bounding hypothetical analysis for Hermes
- The combination of bounding conditions analyzed are beyond what is assumed for postulated events
- Preliminary dose results for MHA are substantially below the regulatory dose reference values for test reactor siting in 10 CFR 100.11
- Because assumptions of the MHA are bounding, calculated doses will likely not be exceeded by any accident considered credible
  - Staff will confirm calculations as part of the OL application review

# Staff Evaluation – Control Room Habitability

---

- SE Section 13.2.1 also includes staff evaluation of preliminary information on control room radiological habitability described in PSAR Section 7.4
  - Identifies relevant design basis as PDC 19
  - Additional description of the control room habitability design and dose analysis corresponding to the final detailed design will be provided in the OL application

# Conclusion

---

- NRC staff finds the preliminary design information and analysis are consistent with the applicable criteria in NUREG-1537
- The staff concludes information in Hermes PSAR Chapter 13 on the MHA is sufficient for the issuance of a CP in accordance with 10 CFR 50.35 and 50.40 and further information can be reasonably left for the OL application



# **NRC Staff Review for PSAR Chapter 13 Accident Analysis – Postulated Events and Other Sections**

---

**Briefing for the Advisory Committee on Reactor Safeguards**

**April 19, 2023**

Office of Nuclear Reactor Regulation and  
Office of Nuclear Regulatory Research

# Overview of PSAR Chapter 13, “Accident Analysis”

---

- Kairos uses a Maximum Hypothetical Accident (MHA) approach to bound other postulated events
  - Postulated events are bounded by the MHA radionuclide release
- Approach uses figure of merit and acceptance criteria in PSAR Table 13.1-1 to ensure MHA remain bounding if different radionuclide release pathways exist
- Postulated events considered are consistent with those listed in NUREG-1537
  - Some technology-specific events or event sequences are precluded by design, such as Flibe interaction with concrete or water (e.g., decay heat removal system (DHRS) water leak)
  - Some technology-specific events (e.g., increased pebble bed packing fraction) have been evaluated



# Postulated Event Methodology – Generic Aspects

---

- Postulated event methodology is described in technical report KP-TR-018, Rev 2
- KP-TR-018, Table 4-4, “Input Parameters for Postulated Events,” identifies parameters and their ranges to be considered for all Chapter 13 events
  - Examples: initial power level, reactor coolant temperature
  - The NRC staff finds that KP-TR-018 specifies acceptable ranges for parameters to ensure the most limiting scenarios are analyzed
- FSAR analyses will consider a full range of sensitivities based on Table 4-4
- KP-SAM and KP-BISON have the capability to model postulated events and the corresponding fuel releases
  - Code verification and validation will be reviewed prior to, or as part of, the OL application

# PSAR Section 13.1.2, Insertion of Excess Reactivity Event

- PSAR analysis assumes continuous withdrawal of highest worth control element at the maximum speed
  - Reactor trips on high power or high outlet temperature
  - A range of reactivity insertion rates and initial core powers will be evaluated in the OL application
  - Uncertainties will be quantified as part of the OL application
  - Control element ejection is precluded due to the low differential pressure
- Temperatures stay below the assumed MHA hypothetical temperature vs. time curve except for the maximum reflector temperature, which slightly exceeds the MHA free surface and graphite temperature limits for a short period of time
- Staff's scoping analysis yielded similar results as will be shown in following slides
- The staff has reasonable assurance the MHA dose bounds that of the insertion of excess reactivity event because of conservatism in the MHA analysis

## PSAR Section 13.1.3, Salt Spill Event

---

- Salt spill is a loss of coolant inventory resulting in different release pathways than the MHA
  - Assumes safety-related systems work as intended
  - Assumes water or concentrate interactions are precluded by design
  - Methodology includes evaluating a range of break sizes and locations
- Release pathways different from the MHA include radionuclides mobilized by the break, evaporation from the spilled pool, and oxidation of any exposed graphite
- Heat up due to the loss inventory is expected to be low and bounded by the assumed MHA temperature vs. time curve

## PSAR Section 13.1.3, Salt Spill Event (continued)

---

- Methodologies for break aerosol generation and Flibe vessel free-surface evaporation methodologies are from the approved mechanistic source term (MST) topical report
- Salt spill uses lower, event-specific temperatures, hence lower fuel, wetted graphite surface tritium, and lower Flibe vessel free-surface releases
- Staff has reasonable assurance that MHA would bound the salt spill event based on the minimum heat up and low salt mass spilled
- A quantitative dose comparison between the salt spill event and MHA will be performed in the OL application

# PSAR Section 13.1.4, Loss of Forced Circulation

---

- PSAR analysis assumes a primary salt pump seizure
  - Reactor trips on high outlet temperature
  - Uncertainties will be quantified as part of the OL application
- Temperatures stay below the assumed MHA hypothetical temperature vs. time curve except for the maximum reflector temperature and upper plenum temperature, which slightly exceed the MHA free surface and graphite temperature limits for a short period of time
- Staff's scoping analysis yielded similar results, as will be shown in following slides
- The staff has reasonable assurance the MHA dose bounds that of the loss of forced circulation

# PSAR Section 13.1.5, Pebble Handling and Storage System (PHSS) Event

---

- PHSS event is a break in a pebble handling line resulting in different release pathways than the MHA
  - Reactor protection system trips the PHSS to stop pebble movement
  - Pebbles spill into the transfer line room and no active heat removal (i.e., room HVAC) is credited to limit spilled pebbles temperature
  - Criticality is precluded by design and pebbles are assumed to remain intact
- Release pathways different from the MHA include radionuclides mobilized graphite dust from the break and pebble oxidation
- Spilled pebbles are assumed at their maximum burnup and hence pebble matrix material at risk is conservative for oxidation and dust activity determinations

# PSAR Section 13.1.5, Pebble Handling and Storage System (PHSS) Event (continued)

- Staff reviewed methodologies for pebble matrix oxidation and dust generation rate and transport and found them acceptable
  - Fuel Qualification (FQ) topical report (KP-TR-011) states pebble matrix oxidation tests will be performed to validate the PSAR assumed oxidation correlation
  - FQ topical report states pebble wear against SS-316 will be tested to inform the PHSS dust generation rate
  - MST topical report Section 7.3.3.2.2. evaluates the dust resuspension methodology
- PHSS event uses lower temperatures (event specific) temperatures hence lower fuel, wetted graphite surface tritium and lower Flibe vessel free-surface releases
- A quantitative dose comparison is between the PHSS event and MHA will be performed in the OL application

# PSAR Section 13.1.6, Radioactive Release from a Subsystem or Component

---

- Radioactive material at risk of release (MAR) is limited such that the release, assuming no retention, is bounded by the MHA
  - This includes all locations not qualified to maintain structural integrity during a postulated event (e.g., seismic event).
- Potential area with MAR limits include the tritium management system, inert gas system, chemistry control system (including filters), and inventory management system



## PSAR Section 13.1.8, General Challenges to Normal Operation

- PSAR Section 13.1.8 addresses events caused by inadvertent operator action, failure of a control system or instrumentation
- The reactor protection system (RPS) will sense and terminate the event assuming the setpoints are reached
- Events caused by operator action, control system or instrument failures are typically bounded by the events analyzed in Chapter 13 due to the use of bounding assumptions and analysis
- Consequences caused by inadvertent operator action, control system or instrumentation failure will be reviewed in more detail as part of the OL application

## PSAR Section 13.1.9, Internal or External Hazard Events

---

- Limiting internal events are primarily addressed by Chapter 13
  - Fire protection systems and programs are addressed in PSAR Section 9.4 and will protect safety-related SSCs that perform event mitigation
- Most external events are addressed by designing SSCs commensurate with the hazard or applicable standard
- A seismic-induced reactivity event is unique to pebble bed reactors
  - Potential increase in pebble packing fraction and associated reactivity increase expected to be bounded by the Chapter 13 insertion of excess reactivity event
  - Reactivity insertion due to pebble bed slumping (i.e., elevation change of the active core) is not expected in a buoyant molten salt pebble bed
  - Staff to review detailed seismic induced packing fraction reactivity analysis as part of the OL application review

# PSAR Section 13.1.10, Prevented Events

---

- Prevented events are potential events which are prevented due to design features and hence are not evaluated
- Of the PSAR prevented events listed, the staff issued requests for additional information (RAI) on two of the prevented events
  - RAI 348 (ML22227A180) asked the basis for why recriticality and unprotected events are excluded from consideration
    - Kairos modified PSAR Section 4.2.2.3 to further describe the shutdown element insertion testing to ensure the shutdown margin analysis remains valid and, in part, to lower the probably of an unprotected event
  - RAI 350 (ML22227A192) asked, in part, how component integrity is ensured for the duration of an air ingress event including air ingress beyond the heat rejection blower trip
    - SE Section 5.1.3.2.6 addresses material qualification testing out to 7 days
      - Beyond 7 days compensatory measures could reasonably to be established to ensure the final reactor state protects public health and safety

# Staff Scoping Analysis of Hermes


- NRC developed several ‘representative’ non-LWR systems models since 2020
  - Part of “Non-LWR Vision and Strategy, Volume 3” covering severe accidents/source term
  - Included UC Berkeley Mark 1 design, representing TRISO pebble fueled/molten salt cooled FHR
  - SCALE code suite used for inventory and reactor physics data generation (ORNL)
  - MELCOR used for accident progression using SCALE-produced data (Sandia)

# MELCOR Analysis Approach

- Original SCALE/MELCOR FHR work used the UCB Mark I design and focused on fission product release from TRISO and molten salt during beyond design basis events
- The UCB Mark I model was modified (January-March 2022) for the Kairos Hermes design and applied to select Chapter 13 postulated events
  - Modifications based on PSAR information and engineering judgement
  - SCALE-generated inventory and decay heat input
  - Transients from technical report KP-TR-018: insertion of excess reactivity, loss of forced circulation


# MELCOR Model Description

- Model focuses on primary system
  - Intermediate loop and DHRS represented via boundary conditions
  - Necessary given lack of detailed design info
- Detailed representation of flow paths within pebble bed
- Fluidic diodes represented as flow path with different forward and reverse loss coefficients



# MELCOR DHRS Model Description

Figure 6.3-1: Functional Diagram of the DHRS




PSAR Schematic

- Heat transfer between the reactor vessel (RV), DHRS, and cavity wall
  - Multi-surface radiation enclosure model
  - Natural convection heat transfer from all surfaces
  - Surface emissivities (variable - uncertainty parameter)
  - Convective heat transfer coefficients (variable - uncertainty parameter)
- DHRS model
  - 0, 6, 12, 18, or 24 DHRS thimbles
  - Water (constant boundary condition at 100°C)
  - Water to DHRS evaporator tube wall uses boiling heat transfer coefficient
  - Thermal resistance between evaporator tube to thimble casing (variable - uncertainty parameter)
- Cavity wall
  - Fire brick, steel liner, concrete wall
  - No liner cooling

# MELCOR Results: Insertion of Excess Reactivity

- Withdrawal of control element inserts 3.02\$\* over 100 seconds
- Reactor trips on high power (120%) at ~9 s, concurrent with PSP trip and flow coastdown
- Temperatures maintained within MHA envelope

\* "\$" is a unit of reactivity used in nuclear reactor analysis.




MELCOR results as compared with PSAR (upper right)



# MELCOR Results: Loss of Forced Circulation

- Concurrent trip of primary and intermediate coolant pumps results in flow coastdown
- Two cases presented:
  - Overheating
  - Overcooling (Flibe freezing)
- Reactor trips on overtemperature
- System remains within MHA envelope



MELCOR results for overheating case as compared with PSAR (upper right)

## Overall Staff Conclusions

---

- The staff found the postulated event methodologies can be used to predict conservative event temperatures and dose releases
- The staff reviewed PSAR Table 13.1-1, “Acceptance Criteria for Figures of Merit” and found these acceptable as described SE Section 13.2.2 because they account for physical phenomena and additional release pathways that are not part of the MHA to ensure the MHA remains bounding
- OL application will provide dose analyses for events bounded by the MHA release, along with a comparison to the acceptance criteria for the figures of merit in PSAR Table 13.1-1

## Overall Staff Conclusions

---

- Because the figures of merit and associated acceptance criteria ensure that the MHA releases remain bounding, the staff has reasonable assurance that the radiological consequences of the postulated events will also meet regulatory requirements of 10 CFR 100.11 and 10 CFR 50.34(a)
- The staff concludes information in the Hermes PSAR Chapter 13 is sufficient for the issuance of a CP in accordance with 10 CFR 50.35 and 50.40 and further information can be reasonably left for the OL application