



August 31, 2023
NRC-23-0054

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555-0001

Enrico Fermi Atomic Power Plant, Unit 1
NRC Docket No. 50-16
NRC License No. DPR-9

Subject: Enrico Fermi Atomic Power Plant, Unit 1 – Annual Report for Period Ending
June 30, 2023

Pursuant to Section F.7, Reporting Requirements, of the Technical Specifications for the Enrico Fermi Atomic Power Plant, Unit 1 (Fermi 1), the Annual Report for the period ending June 30, 2023, for the SAFSTOR Fermi 1 facility is enclosed.

No new commitments are being made in this submittal.

Should you have any questions or require additional information, please contact D. Moss, Fermi 1 Custodial Delegate at 734-250-2375.

Sincerely,

A handwritten signature in blue ink, appearing to read "Eric Frank".

Eric Frank
Manager - Nuclear Licensing

Enclosure: Enrico Fermi Atomic Power Plant, Unit 1 – Annual Report for Period July 1, 2022, through June 30, 2023

cc: NRC Project Manager
Regional Administrator, Region III

**Enclosure to
NRC-23-0054**

**Fermi 1 NRC Docket No. 50-16
License No. DPR-9**

**Enrico Fermi Atomic Power Plant, Unit 1 – Annual Report for Period July 1, 2022, through
June 30, 2023**

**ENRICO FERMI ATOMIC POWER PLANT, UNIT 1
ANNUAL REPORT
JULY 1, 2022 THROUGH JUNE 30, 2023**

1.0 PREFACE

This report provides a summary of the activities performed and the results of the facility surveillance program of the Enrico Fermi Atomic Power Plant, Unit 1, during the past twelve (12) months ending June 30, 2023.

In summary, required activities were conducted in accordance with the Possession-Only License and Technical Specifications. Fermi 1 is in Passive Monitoring SAFSTOR status.

2.0 SAFSTOR STATUS

2.1 Health Physics

2.1.1 Personnel Exposure

From July 1, 2022, through June 30, 2023, all monitored Fermi 1 personnel wore Dosimeters of Legal Record (DLRs). Additionally, Electronic Dosimeters (EDs) were worn throughout the reporting period as secondary dosimetry. All visitors were appropriately escorted and wore EDs, as a minimum, when entering all Fermi 1 Radiologically Controlled Areas (RCA).

The accumulated whole-body dose for personnel assigned to Fermi 1 was 0.003 REM for this reporting period. The total dose is based on data from the following:

0.000 REM (DLR-based) 01JUL22 – 31DEC22

0.003 REM (ED Based, Pre DLR Read) 01JAN23 - 30JUN23

Note: The 01JAN23 - 30JUN23 ED Based reading will be reconciled with a DLR reading in Fermi's next annual Radiation Exposure Information and Reporting System (REIRS) submittal.

2.2 Surveillance Program

2.2.1 Environmental Surveys

No liquid radiological releases occurred during this period; therefore, environmental monitoring samples were not required.

2.2.2 Weekly Tests and Inspections

General area --- The Fermi 1 staff performed walk throughs and visual inspections as required by Technical Specifications. During the period,

there have been Controlled Area roof leaks and a approx. 5' by 8' hole in the Fuel and Repair Building (FARB) high roof that resulted in rain-water intrusion into the facility. Funding was approved to perform further investigation of damage. Once extent of condition is complete, strategy for repair will be presented to Senior Management for further funding. The roof area is monitored for any new leaks, which will be documented in weekly and monthly PMs and input into repair plan as necessary.

2.2.3 Monthly Inspections

Controlled Area Inspections --- During the specified interval, Fermi 1 staff surveyed the sump water levels from the top access of all active sumps. Visual inspections of the fences, gates, and doors were conducted. No significant issues were identified during the inspections.

2.2.4 Quarterly Surveillances

Radiological Surveys --- The Radiation Protection technicians surveyed the Reactor Building and the FARB for presence of gamma radiation, as well as beta, gamma, and alpha contamination. There were no unexpected radiological conditions detected. The results of the quarterly contamination surveys indicated general area walkways remain < 1000 dpm/100 cm² beta/gamma and < 20 dpm/100 cm² alpha.

3.0 GROUNDWATER MONITORING

The Fermi 1 staff collected groundwater monitoring well samples during the period which were then analyzed by the site's contract laboratory. No plant-related radioactive tritium isotopes were detected above the laboratory detection limit (less than 500 pCi/L).

4.0 RADIOLOGICAL SHIPMENTS

There were no radiological materials shipped offsite from Fermi 1 during the reporting period.

5.0 RADIOLOGICAL EFFLUENTS

There were no radiological gaseous effluent releases during the reporting period.

6.0 50.59 EVALUATIONS, DESIGN CHANGES AND LERs

6.1 10 CFR 50.59

There were no 10 CFR 50.59 evaluations performed during this period. Screenings determined that 50.59 evaluations were not required.

6.2 Design Changes

There were no Design Changes during this reporting period.

6.3 Licensee Event Reports

There were no Licensee Event Reports during this reporting period.

7.0 AUDIT SUBCOMMITTEE

The Audit Subcommittee inspected the physical facility and reviewed the Technical Specification surveillance records during the reporting period. No significant problems were identified.

All audit reports are maintained on file.