

United States Nuclear Regulatory Commission

Protecting People and the Environment

# ACRS MEETING WITH THE U.S. NUCLEAR REGULATORY COMMISSION

**December 6, 2018** 



United States Nuclear Regulatory Commission

Protecting People and the Environment

## **Overview**

## **Mike Corradini**

#### **Accomplishments**

Since our last meeting with the Commission on April 5, 2018, we issued 13 Reports

 Draft Proposed Rule, "Emergency Preparedness for Small Modular Reactors and Other New Technologies"

- Draft Digital Instrumentation & Controls Interim Staff Guidance, Digital I&C-ISG-06, "Licensing Process," Revision 2
- Report on the Safety Aspects of the APR1400

- Draft SECY Paper, "Functional Containment Performance Criteria for Non-Light Water Reactor Designs
- Safety Evaluation for WCAP-17936-P, Revision 2, "AP1000 In-Containment Cables and Non-Metallic Insulation Debris Integrated Assessment"

- Long-Term Core Cooling for the APR1400
- Safety Evaluation for Topical Report APR1400-F-A-TR-12004-P, Revision 1, "Realistic Evaluation Methodology for Large-Break Loss of Coolant Accident of the APR1400"

 Safety Evaluation of the NuScale **Power, LLC Topical Report TR-0616-**48793, Revision 0, "Nuclear Analysis **Codes and Methods Qualification**" and Safety Evaluation of the **NuScale Power, LLC Topical Report TR-0116-21012, Revision 1, "NuScale Power Critical Heat Flux Correlations**"

- Brunswick Steam Electric Plant Units 1 and 2 Maximum Extended Load Line Limit Analysis Plus License Amendment Request
- Interim Letter: Chapters 7 and 8 of the NRC Staff's Safety Evaluation Report with Open Items Related to the Certification of the NuScale Small Modular Reactor

- Safety Evaluation of the NuScale Power, LLC Topical Report TR-0915-17564-P, Revision 1, "Subchannel Analysis Methodology"
- Report on the Safety Aspects of the License Renewal for the Waterford Steam Electric Station, Unit 3

 Report on the Safety Aspects of the License Renewal for the River Bend Station, Unit 1

Design Certification

– NuScale

- Early Site Permit
  Clinch River
- License Renewal
  - Seabrook
- MELLLA+

- Browns Ferry Units 1, 2 & 3

- Guidance and Bases
  - Draft Regulatory Guide DG-1327,
    "Reactivity-Initiated Accidents"
  - NUREG-2224 on High Burnup Fuel Storage and Transportation
  - NUREG/BR-0058, "Regulatory Analysis Guidelines"
- Licensing Modernization
  Framework

- Digital I&C
  - Integrated Action Plan
- Rulemaking
  - Non-Power Production or Utilization
    Facility

- Thermal-Hydraulic Phenomenology
   GSI-191
  - OWR Owners Group In-vessel Debris
    Test Results
  - Framatome
    - AURORA-B Transient Code Suite: LOCA
    - **RAMONA5 for ATWS**

- Thermal-Hydraulic Phenomenology
   Westinghouse
  - D5 Critical Power Correlation for SVEA-96 Optima3 Fuel

 WCAP-16260P, Revision 2, "The Spatially Corrected Inverse Count Rate Methods for Subcritical Reactivity Measurement"

- Reliability and PRA
  - Level 3 PRA
  - Human Reliability Analysis Method
    Development
    - **OIDHEAS program**
    - Control Room Abandonment Risk



United States Nuclear Regulatory Commission

Protecting People and the Environment

### Draft Proposed Rule, "Emergency Preparedness For Small Modular Reactors and Other New Technologies"

#### **Dennis Bley**

### **History Leading to Rule**

- SECY-10-0034: EP key issue for SMRs
- SECY-11-0152: Intent to develop tech-neutral, dose-based, consequence-oriented EP
- SECY-14-0038: Requested to revise EP toward more performance-based oversight regimen
- SECY-15-0077: Proposed rulemaking EP framework for SMRs & ONTs

#### **Related Activities**

- WASH-3 uncontrolled release  $\rightarrow$  exclusion area of R = 0.01  $\sqrt{P}$
- Practical power reactors must rely more on containment than isolation
- 1960 Siting criteria considered: ACRS recommended caution
- 1962 10 CFR Part 100 site criteria pointed to TID-14844: RG 1.3/1.4

#### **Related Activities**

- 1973 WASH-1400: source terms calculated for release categories
- 1978 NUREG-0396: planning basis for emergency response plans
- 1995 NUREG-1465 replaces TID-14844
- 2000 Alternative radiological source terms 10 CFR 50.67 & RG 1.183

#### **Related ACRS Letters**

- 1950 WASH-3
- 1964 Engineered Safeguards
- 1976 ACRS hearing testimony before JCAE
- 1984 Draft Task Action Plan on Containment Performance
- 1987 Source Term Uncertainty

#### **Related ACRS Letters**

- 1999 Defense-in-Depth in Riskinformed Regulation
- 2007 Technology-Neutral Framework
- 2013 NGNP Key Licensing Issues
- 2017 Non-LWR Vision & Strategy
  2018 Principal Design Criteria RG
- 2018 Functional Containment SECY

### **Proposed Rule (1)**

- Replicates most of 10 CFR 50.47
  & Appendix E, with two changes
  - Organizes Emergency Plan requirements
  - Alternative EPZ requirements
- Emergency Plan requirements
  - Organized into more logical order
  - Performance-based requirements

### **Proposed Rule (2)**

- EPZ requirements
  - Main purpose of new rule
  - Currently plume exposure pathway EPZ 10 miles & ingestion pathway EPZ 50 miles
- Proposed rule EPZ requirements
  - Plume exposure pathway <10 mSv i.e., <1 Rem</p>
  - Purpose: provide area where predetermined protective actions are implemented, which reduce dose and associated early health effects

### **Proposed Rule (3)**

- Proposed rule EPZ requirements
  - Applicant would consider plume exposure doses from a spectrum of credible accidents for the facility
  - The rule would allow SMR and ONT applicants to develop reduced EPZ sizes, commensurate with the accident source terms, fission product releases, and accident dose characteristics specific to their reactor designs

### **Guidance DG-1350**

- Guidance for preparing Emergency Plans is thorough and easy to follow
- Guidance for using the new alternative EPZ
  - Key to defending a smaller EPZ is the source term
  - Guidance for determination of release scenarios and source terms for possible accidents criteria is sparse

#### **Source Term**

 Developing mechanistic source terms is not an easy task; it involves complex physics and chemical phenomena including the evolution and transport of aerosols

### ACRS Findings & Recommendations

- 1. No technical obstacles to the rulemaking
  - Recommend that rulemaking moves forward
- 2. Staff will need to provide guidance to define their expectations for the technical adequacy of mechanistic source terms

### **ACRS Comment**

- Arguments presented in the draft rule and guidance apply equally well to all reactors
  - No technical basis for restricting use of the new rule to SMRs and ONTs with a limit on thermal power
  - Staff to request stakeholder input on this topic



United States Nuclear Regulatory Commission

Protecting People and the Environment

#### Draft Digital Instrumentation & Controls Interim Staff Guidance, Digital I&C-ISG-06, "Licensing Process," Revision 2

#### **Charles Brown**

#### **Background – Purpose & Scope**

- ISG-06 defines the licensing process for review of license amendment requests (LARs) for safety-related DI&C modifications in operating plants and in new plants once they become operational
- Provides industry guidance for pre-LAR activities and LAR review
- Revision 1 issued in 2011

## **Revision 1 vs Draft Revision 2**

- Incorporated Lessons Learned and Industry Feedback
- Added focus on fundamental design principles
  - Redundancy
  - Independence
  - Deterministic Processing
  - Diversity and Defense-in-Depth
  - Control of Access

#### **Revision 1 vs Draft Revision 2**

 Alternate Review Process added that provides LAR approval before completion of detailed design, implementation or factory acceptance testing

- ISG emphasizes software development but largely silent on hardware configuration control and management
- Did not address applicant ownership of the I&C system changes during the development process

- Staff has ensured that four of the five fundamental digital design principles are addressed in the ISG
- We remain concerned that the fifth critical fundamental design principle for architecture design of DI&C applications, Control of Access, is not included

- Currently, design approaches and administrative controls to restrict internal plant access to systems are used
- Control of Access also means preventing remote electronic access to in-plant systems and networks from sources external to the plant

- To ensure remote access is prevented, plant and system data transmission should be configured to be one-way from in-plant to external recipients using only hardware-based processes, which are not configured by software
- Our letter report urged the staff to formally incorporate this principle into the licensing design evaluation process

#### **Conclusions & Recommendations**

- Draft Digital ISG-06, "Licensing Process," Revision 2, should be issued for public comment
- Provide the draft final Digital I&C-ISG-06, Revision 2, for our review following resolution of public comments and address the configuration management concern before final publication

#### **EDO Response**

- The EDO response was satisfactory regarding the specific recommendations in the July 18, 2018 ACRS Letter
- However, the revised ISG did not address our concern regarding the fifth fundamental design principle for Control of Access

### **ACRS Continuing Concern**

- Our November 8, 2018 response letter requested staff to provide the basis for not explicitly addressing the Control of **Access critical fundamental design** principle for the architecture design of **DI&C** or any other revision that would help ensure prevention of remote electronic access from sources external to the plant
- We will continue to follow this concern



United States Nuclear Regulatory Commission Protecting People and the Environment

# Safety Aspects of the APR1400 Pressurized Water Reactor

**Ronald Ballinger** 

#### **ACRS Letter Reports Issued**

- APR1400 Design Certification July 2018
  - Four Interim Letter Reports
- Four Topical Reports
- Long-Term Core Cooling Report

## **APR1400 Design**

- Based on CE System 80+ with Safety Enhancement Features
  - Innovative ECCS-Fluidic Device
  - In-Vessel Retention Option
- Instrumentation & Control
  - Common Q Platform
- Probabilistic Risk Assessment Used for Design Decisions

### **Conclusion**

- The APR1400 design is mature and robust
- There is reasonable assurance that it can be constructed and operated without undue risk to the health and safety of the public

#### **Review: Lessons Learned**

- Essential that staff and applicant be supportive and responsive in their interactions with ACRS
- Scheduling flexibility is essential to successful and timely review

#### **Abbreviations**

ACRS	Advisory Committee on Reactor Safeguards	MELLLA+	Maximum Extended Load Line Limit Analysis Plus
ATWS CE CFR ECCS EDO EP EPZ GSI I&C IDHEAS ISG	Anticipated Transient Without Scram Combustion Engineering <i>Code of Federal Regulations</i> Emergency Core Cooling System Executive Directors for Operations Emergency Planning Emergency Planning Zone Generic Safety Issue Instrumentation and Control Integrated Human Event Analysis System Interim Staff Guidance	mSv NGNP Non-LWR NRC ONTS PRA RG SMR TR	milliSieverts Next Generation Nuclear Plant Non-Light Water Reactor Nuclear Regulatory Commission Other New Technologies Probabilistic Risk Assessment Regulatory Guide Small Modular Reactor Topical Report
JCAE Lar	Joint Committee on Atomic Energy License Amendment Request		
LOCA Lr	Loss-of-Coolant Accident License Renewal		